



- NOTES**
- THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION UNLESS STAMPED 'ISSUED FOR CONSTRUCTION'.
 - ALL DIMENSIONS ARE IN INCHES UNLESS OTHERWISE NOTED.
 - ALL HELDS TO BE 1/4" FILLET UNLESS OTHERWISE NOTED.
 - PAIN V-763 AS PER NINE SPEC: (1) COAT PRIMER, (2) COATS ENAMEL WARM GREY, SURFACE PREP: SSPC-SP3.
 - PAIN V-767 AS CUSTOM SPEC: (1) COAT AMERLOCK 400 EPOXY, (1) COAT POLYURETHANE WARM GREY.
 - ROOF & TRIM TO BE PRE-PAINTED (METRO BROWN-GC 228), EXTERIOR WALLS TO BE PRE-PAINTED (UW-GC 315). SURFACE PREP: SSPC-SP3.
 - DRY AIR RECEIVER (V-767) TO BE REMOVED OFF SKID PRIOR TO LIFTING THIS PACKAGE.

MAJOR EQUIPMENT LIST

TAG NO.	QTY.	DESCRIPTION	LBS.	AS BUILT	DATE	BY	CHK
K-761/762	2	COMPRESSOR, COMPANR L30, 139 SCFM@135 PSIG	4070	REVISD AS PER CUSTOMER MARK-UPS, L.F.C.	12-03-28	GE	SK
		40 HP MOTOR, 575V/3PH/60Hz		REVISD AS PER CUSTOMER MARK-UPS	12-01-23	GE	SK
V-763	1	WET AIR RECEIVER, 240 GAL STEEL FAB #C104715	959	ISSUED FOR CONSTRUCTION	12-01-04	PLC	SK
V-767	1	DRY AIR RECEIVER, 5500 GAL STEEL FAB #C104718X	12900	REVISD AS PER CUSTOMER MARK-UPS & RESUBMITTED	11-12-12	PLC	SK
D-765A/B	2	DESSICANT DRYER, AIRTEK TWOF130E	992	REVISD AS PER CUSTOMER MARK-UPS	11-11-22	PLC	SK
F-764A/B	2	PRE-FILTER, COALESCING, AIRTEK JCO150-C	10	ISSUED FOR APPROVAL	11-09-27	PLC/AJ	SK
F-766A/B	2	AFTER-FILTER, PARTICULATE, AIRTEK JCO150-F	10	REV			
BH-760A/B	2	BUILDING HEATER, CALORITECH, GE10BCT, 10kW	460				
S-765	1	STEELFAB A10029 HORIZONTAL 60 GAL	160				
BLDG	1	BUILDING, PRE-PAINTED STEEL, GABLE STYLE, 9'	3800				
		EAVE, 4:12 SLOPE, ICE RAKES, EAVE & DOWNSPOUT					
PJB-760	1	120V JUNCTION BOX	-				
UB-760	1	CONTROL JUNCTION BOX	-				
HS-7601A/B	2	ESD BUTTON-CROUSE HINDS DSD9185769	-				
		C/W NC-CH-1-QA OPEN FRONT COVER					
AT-7602A/B	2	NET SAFETY UV/IR-A C/W SWIVEL	-				
		M/N FL3100-1-1-3-1-1-1					
NW894SK	1	STRUCTURAL SKID, W10 x 33, 11' x 31'	9970				
		PIPING, ELECTRICAL & MISC.	750				
VF-760	1	EXHAUST FAN, 1/4 HP, 120V/1PH/60Hz	50				
		(APPROX.) TOTAL WEIGHT	34131				

Northwest Equipment Ltd.

GENERAL ARRANGEMENT
DUPLX COMPANR L30 AIR COMPRESSOR PACKAGE (M-760)

CLIENT	ENCANA CORP. c/o SOLARIS M.C. INC.	SCALE	1:43
LOCATION	SWAN GATHERING COMPRESSOR STATION, B.C.	DRAWN BY	PLC
LSD	P.O.# EN10-01048	DATE	11-09-08
JOB	NW894	DWG	NW894GA
REV		REV	6