



NO WCP

DISTANCE PIECE / PACKING VENT & DRAIN
STANDARD COMPARTMENT, R:J CLASS
(TYP EACH CYLINDER)

14-925-711 H6
14-925-711 H7

STANDARD TUBING SIZES	LINETYPE LEGEND	INSTRUMENTATION TAGGING LEGEND
*1/4" - 0.049"	PROCESS PIPING	○ LOCAL MOUNTED DEVICE
*3/8" - 0.049"	UTILITY PIPING	○ PANEL MOUNTED DEVICE
1/2" - 0.049"	SEAMLESS TUBING	○ OFF-SKID MOUNTED DEVICE
3/4" - 0.065"	ELECTRICAL WIRING	◇ SIGNAL TO PANEL
1" - 0.083"	INTERNAL LOGIC	◇ SIGNAL TO OFF-SKID
*PER CLIENT SPEC	OEM SUPPLIED	◇ PANEL LOGIC
	ASSEMBLY BOUNDARY	
	BUILDING WALL	
	DRIVETRAIN	
	CUSTOMER SUPPLIED	

ALL TUBING TO BE 316SS

THIS DRAWING IS SOLE PROPERTY OF BIDELL EQUIPMENT AND SHALL NOT BE REPRODUCED, COPIED, LENT, ALTERED NOR USED FOR ANY PURPOSE OTHER THAN WHICH IT IS FURNISHED EXCEPT WITH THE WRITTEN PERMISSION OF BIDELL EQUIPMENT

AS BUILT
AS BUILT
2015/10/08

REV	DATE	CREATED	REVIEWED	APPROVED	DESCRIPTION
0	15-10-07	CW	TT	GM	AS BUILT
REVISIONS					
MAIN SHOP / OFFICE 6900 - 112th AVENUE S.E. CALGARY, AB T2C 4Z1 PHONE: (403) 235-5877 FAX: (403) 272-7749					BIDELL™ GAS COMPRESSION APEGA PERMIT NUMBER P08318
COMPRESSOR DISTANCE PIECE, PACKING VENT & DRAIN UTILITY FLOW WEG 350HP ELECTRIC/ARIEL JGR/2/AIR-X-LIMITED 96AEF CUSTOMER: ENCAN c/o EQUINOX ENGINEERING LOCATION: KAYBOB GAS PLANT PHASE 3 (DE-ETHANIZER) SHEET#: 1 OF 1 LSD: 15-31-062-21 W5M JOB#: 14-925					
PAPER SIZE 11"x17"	SCALE NTS	DWG#	14-925-761 REV 0		