

EQUIPMENT STATIC DATA

REPORT No.: SD-2-3703-03-JDK

Client: Abbey Resources Corp.
 District: Shackleton S/L LSD: 14-36-020-19W3M
 Facility: Shackleton Compressor Station D/H LSD: _____
 Vessel Description: Inlet Separator
 Vessel Cooler Exchanger Plate Exchanger Heater
 Reboiler Furnace Column Other: _____
 Manufacturer: Westfab Industries Ltd. Year Built: 2003
 Status: Shut-In Process: Gas
 Op. Press.: 0.0 kPa Op. Temp.: 10.0°C

Page: 1 of 3
 ITS Job No.: 2-3703
 Date: 12-Apr-2017
 PRN: S05259/A0491789
 Equip. No.: Not Stated
 Serial No.: WF03.1272
 CRN: R2250.23
 Nat'l B. No.: Not Stated
 Service: Sweet

MAWP: 1965.0 kPa @ 38.0°C
 Code: ASME VIII DIV.1 Para.: Not Stated
 Size: W OD 1828.80 mm Length: Not Stated
 Shell Material: SA-516-70N Chan. Material: Not Applicable
 Shell Thickness: 15.90 mm Chan. Thickness: Not Applicable
 Cor. Allowance: Not Stated
 Head Location: East Head Location: West
 Head Type: Elliptical Head Type: Elliptical
 Head Material: SA-516-70N Head Material: SA-516-70N
 Head Thickness: 14.60 mm Head Thickness: 14.60 mm

MDMT: -29.0°C @ 1965.0 kPa
 RT: RT-2 HT: No
 Painted: Yes Insulated: No
 Internal Coating: Yes Type: Not Stated
 Internal Cladding: No Type: Not Applicable
 Manway: Yes Size: 609.60 mm
 No. of Courses: 2

Boot:	Vapor	Liquid
Length:	Not Applicable	Not Applicable
Diameter:	Not Applicable	Not Applicable
Shell Material:	Not Applicable	Not Applicable
Shell Thickness:	Not Applicable	Not Applicable
Head Material:	Not Applicable	Not Applicable
Head Thickness:	Not Applicable	Not Applicable

PRD:	1: One	2:
PRD Location:	Piping	
PRD Tag No.:	PSV-100	
Manufacturer:	Farris	
Model / Type:	26KA10-120	
Serial No.:	444145-1-A10	
CRN:	0G2369.5C	
Set Pressure:	1965.0 kPa	
Capacity:	10540.0 SCFM/Air	
Back Pressure:	0.0 kPa	
Code Stamp:	UV/NB	
Inlet Size:	76.20 mm	
Isolation Valve:	No	
Locked Open:	Not Applicable	
Car Seal Open:	Not Applicable	
Outlet Size:	101.60 mm	
Isolation Valve:	No	
Locked Open:	Not Applicable	
Car Seal Open:	Not Applicable	
Service Date:	10-Apr-2017	
Service Company:	Tel-Rite S.L.	
Safety Seal Intact:	Yes	
Service Seal Intact:	Yes	
PRD Vent To:	Flare	

Nozzles:	Inlet	Outlet
Flange Style:	Raised Face	Raised Face
Flange Rating:	150#	150#
Size:	203.20 mm	203.20 mm
Schedule:	STD	STD
	Drain	Other: _____
Flange Style:	Raised Face	Not Applicable
Flange Rating:	150#	Not Applicable
Size:	101.60 mm	Not Applicable
Schedule:	XH	Not Applicable

Tube / Coil(s):	1:	2:	3:
PRN:	Not Applicable	Not Applicable	Not Applicable
MAWP@Temp:	Not Applicable	Not Applicable	Not Applicable
MDMT@Press:	Not Applicable	Not Applicable	Not Applicable
Flange Style:	Not Applicable	Not Applicable	Not Applicable
Flange Rating:	Not Applicable	#	Not Applicable
Size:	Not Applicable	Not Applicable	Not Applicable
Schedule:	Not Applicable	Not Applicable	Not Applicable
Coil Material:	Not Applicable	Not Applicable	Not Applicable
Thickness:	Not Applicable	Not Applicable	Not Applicable
Cor. Allowance:	Not Applicable	Not Applicable	Not Applicable

Firetube(s):			
Size:	Not Applicable	Quantity:	Not Applicable
Code:	Not Applicable	Length:	Not Applicable
RT:	Not Applicable	HT:	Not Applicable
Tube Material:	Not Applicable	Thickness:	Not Applicable
Cor. Allowance:	Not Applicable	Return Type:	Not Applicable

Other Equipment Protected by this PRD:

PRD Comments:

Comments:

EQUIPMENT STATIC DATA

REPORT No.: SD-2-3703-03-JDK

Page: 2 of 3

Client: Abbey Resources Corp.

ITS Job No.: 2-3703

Vessel Description: **Inlet Separator**

Date: 12-Apr-2017

Photo(s):



S Number

NAMEPLATE

EQUIPMENT STATIC DATA

REPORT No.: SD-2-3703-03-JDK

Page: 3 of 3

Client: Abbey Resources Corp.

ITS Job No.: 2-3703

Vessel Description: **Inlet Separator**

Date: 12-Apr-2017

Photo(s):



OVERALL VIEW

Static Data Collected By:

Sign: 
Print: John David Kobelsky

Report Review: 
Initial

1 st Inspector			
Nat'l Bd	API	PESL	PEI
Level/Type: IS Comm.	510 570	IBPV	Class 1
Certification No.: 15019	28139 29975	274	169

2 nd Inspector / Assistant			
Nat'l Bd	API	PESL	PEI
Level/Type:			
Certification No.:			