Enerplus Resources Visual External Inspection Report – Pressure Vessels

Installation		tion	External																	AI FR 023	
Date:			September 28, 2015				Description:				Vessel			Exchanger 🔲 Boiler			er	r E# <mark>51</mark> 7		791	
Inspector:		:	John David Kobelsky				Equipment Name				: Inlet Separa			ator				CRN#		R7890.213	
Agent Co:			Integrity Testing Service				s Jurisdiction #				S051	S05117 / A0565666						Serial#		80396401C	
Owner:			Enerplus Corporation				Manufacturer: T				Tormont Process System			ms Yea			ear Built: 20		06		
District:			Shallow Gas: Shackleto				Field: Sceptre											I-29-021-23W3M			
Service:			Sweet 🗌 Sour												I			MDM	г -29)°C	
Zones MA		MAWP	P MAWT P		V Set PSV Ta		PSV	/ Manuf	acture	ər	PSV S/N#		¥	PSV Inlet size	PSV Outlet size	PSV Serv. Co	P:	PSV Serv Date	PS\ CSC Y/N	PSV Capacity	
Shell Side		1689 kPa	121°C	21°C 1689 k		E51792		Farris			490914-19-KE			25.40 mm	38.10 mm	Tel-Rite S.	L.	Sep-15	Not	4000 00514	
		Not Applicable	Not Applicable																		
Other		Not	Not e Applicable																		
		pplicable	Shell			Head		Channel			Tube			Co				Comment			
Material			A-516-70N SA-516-7							le	Not Applicable										
Nominal T			15.88 mm 14.29 m									Not Applicable									
CA						.18 mm	Not Applicable				Not Applicable										
	ntation	_	Hor Ver Foundation:				Concrete Gravel					<u> </u>	mbers								
	itatioi		Saddle			Nelded	Free to Move Condition:								.00						
Support			Skirt Free Of Deb																		
		_	Hangers Secure								Condition		Good								
			Other:								Condition		0000								
Ove	rall		eneral Condition: Good			od					0011011011	Electical Grounding Direct V Indirect						irect 🔲 None			
	Surfac					ulated	Fire-proofed Cladded Co					onditi	ndition:								
Ext. Fixtures Ladder Platform Other																					
Inspe	ection	Nozzle		/lanwa	_	Port		Size:	508.	00	mm			V F	Reinforce	ement Pa	ad	\checkmark	Veep	Hole Present	
	t Arm		Present Great								Condition:				Good	[
	✓ PSV ✓ Supported											V N	Well Coated Comment				nt: Good				
				_	Suppo						Free from leaks			Well Coated Commen				ent: Good			
Piping	V 0	outlet		Supported						~				Well Coated Comme			mmei	nent: Good			
Ē	✓ Drain ✓ Supported								Free from leaks			Well Coated Comm			mmei	nt: Goo					
	✓ Instrumentation ✓ Supported			orted				~	Free from leaks			Well Coated Comm			mmei	nent: Good					
	V P	Process fluid identified					Flow Direction marked Comment: Good														
		\checkmark	Manual Isolation Valve				Free from leaks				Commer	nt:	Goo	d							
Va	lves	/es Automated Control Valve				/alve								ood							
		Vents and Drains Plugged					Comment: Good														
			Pressure		Rea	ading:			Conc	litio	n:										
Ga	uges		Temperat	Rea	ading:	Condition:															
	nt Gla		🖊 Fluid L	evel	F	Reading %	5 0		Co	ondi	tion: G	ood									
Inspection Summary The vessel is in good condition.																					
Rec	omme	endatio	ons:															NCR			
None																					
Integ	rity St	atus	Suitable for continued S				Service 🖌 Yes 🔲 No 🗌 Imr						mme	diate re	pairs req	uired		Future r	epairs	required	
Inve	entory Status 🛛 🕢 In service				Out Out	Out of service Stock															
	Inspection Interval													Years or Changed to							
off	PSV Interval												Ye	Years or Changed to							
Sign off						A King							Nat'l Bd.: 15019 / API 510/570:								
S							12						.	28139/29975 / IBPV PESL: 274 Jurisdictional Inspector # PEI Class 1: 169						PV PESL: 274 /	
	Inspector Signature						10						Ju	risdicti	onal Ins	pector	F PE	I Class	1: 169	1	
Chief/Senior Signature (if needed)						ded)							Ju	risdicti	onal Ins	pector	¥				