



## NOTES:

OUANTITIES IN BOM, ARE FOR DNE (1) UNIT.

ALL PIPING TO BE IN ACCRDANCE WITH THE LATEST EDITION OF ASME B313 PRESSURE PIPING CODE.

VESSEL TO BE FABRICATED TO THE LATEST EDITION OF ASME SECTION VIII, DIVISION I PRESSURE VESSELS.

VELDED PIPING TO BE: SA-106B SMLS PIPE, SPEC '30048 150# ANSI', 2' & 3' @ SCH80

THREADED PIPING TO BE: SA-106B SMLS PIPE, SPEC '30048 150# ANSI', 2' & 3' @ SCH80

THREADED PIPING TO BE: SA-106B SMLS SPL60 -OFF SKID PIPE & CONNECTIONS TO BE LOW TEMP MATERIAL - SA-350-LF2 & SA-333-6

ALL FORGED FITTINGS TO BE: SA-105N, 3000# (mm.) RATING, 6000# (mm.) RATING ON 1500# ANSI PIPING

TUBING DETAILS: 3/8'316 SS TUBING, 316 SS. SWAGELOK FITTINGS

PAINTING PACKAGE TO BE CLEANED TO (SSPC-SP-6)

IST COAT OF CLOVA PRIME ZI (8302!)

VESSEL & PIPING EXTERNAL FINISH PAINT: ONE SHOP COAT OF COVERDALE GREY #416 MARINE ENAMEL SERIES !!!

DUAL CHAMBER METER RUN, 3°300# RF SCH.80 AGA 2003 FIG. 3C c/w DNE(1) 316 S.S. DRIFICE PLATE, DNE(1) TEFLDN SEAL RING, DNE (1)

NORTHSTAR

FE-1000

MAKE

QTY.

TAG

ATERIAL

-

[I  $\bigcirc$ 

BILL

1'3000# TOL & ONE(!) 3/4' 3000# TOL & FLOW CONDITIONER (70' F/F) SOUR SERVICE

1300HRF × 2150HRF RELIEF VALVE. TRIM, WCB BODY, SET @ 740 PSIg INCONEL SPRING, "D" ORIFICE

CONSOLIDATED

---

STRUCTURAL EXTERNAL FINISH COAT DNE SHOP CDAT OF CLOVERDALE BLUE#409, MARINE ENAMEL SERIES III PROJECT ALL FLOATS/DISPLACERS FROM ALL LEVAL CONTROLLERS/SYSTICHES TAG AND CRATE FOR SHIPMENT SALING TO SE SHIPMENT SALING THREE SHED WALL HEIGHTS II.PE TO EVILLOSE STORE AND GAS OF LEG EXTERNOR SALOR THREE SALUMINES AND SALOR WALL HEIGHTS II.PE AND ENER SALOR THREE SALOR WALL HEIGHTS II.PE AND MORN WITH PROJECT AND WALLS OF CONTAINMENT FLA DODRS OWE CHAIN WEATHER LUMINOW, R-12 INSULATION IN ROOF AND WALLS OF CONTAINMENT FLA CHECK CHAIN WEATHER-STRIP ING WINDOW. C'A SCREEN SLIDERS SCREEN DME (I) 38" x 36" HIGH BOUBLE GLIZED SLIDING TWDKR) 12" Sq. STAMPED ALUMINUM LJU.ERS c.m. VENTIL ATION

MINIMUM 30 300# ANST PIPING TO 1110 PSIG

133

3017×5108 PIPING

14 3UTWELDED PIPIUS TO BE V-RANED 1001, TO POWE B313 AND HYDROTEST 300# APSI P
15 MAWAR 3' SCABG C'A 300#RF FLG @ 100\*F IS 740 PSIG C'A 1.9° C.A
1 1.2° SCABG C'A 300#RF FLG @ 100\*F IS 740 PSIG C'A 1.9° C.A
1 1.2° SCABG C'A 150#RF FLG @ 100\*F IS 740 PSIG C'A 1.9° C.A
1 1.2° SCABG C'A 150#RF FLG @ 100\*F IS 740 PSIG C'A 1.9° C.A
1 1.2° SCABG C'A 150#RF FLG @ 100\*F IS 740 PSIG C'A 1.9° C.A
1 1.4° SCABG C'A 150 FRANT FLG @ 100\*F IS 265 PSIG C'A 1.9° C.A
1 1.4° SCABG C'A 1.9° C.A
1 1.4° C.A
1 1.4

## C CO

MODEL 67 CFR REGULATORS 1/4"FNPT 0-125 PSIg RANGE, 250 PSIg MAWP, SOUR TRIM.

IRIM.

MDDEL 67 CFR REGULATORS 1/1 0-35 PSIg RANGE, 250 PSIg MAWP,

FISHER

PCV-2100/2200 2210

C/\* SIZE 40 ACT SQUR SERVICE TRIM, 6-30 PSIG SPRING RANGE, FAIL CLOSED 10 1-2" F/F, 1/2"TRIN

NODEL 4150 PRESSURE CONTROLLER, 6-36 PSG OUTPUT, 316 S.S. BOUPDON FUBE, MACE COMPLIANT INTERNALS SUITBALE FOR SOUR INST GAS 0-1590 PSIG BOURDON TUBE c/w. IOKE MAIT PARTS

FISHER

 $\nu$  -1

PC-1000

METH RATE & LEVEL GAUGE. I/2\*MPT SITE GLASS ENCLOSED.

(A) (A) (H)

16-3000

DODI-HISA

j.J D

MODEL IRNS REFLEX TYPE LEVEL GAUGE, 3/4" NP c/w 330J VALVES, SOUR SER, DRAIN TIE-IN

PENBERTHY

LG-1000

BPCV-1000

I'NPT TURBINE METER, 5-50 GPM CAPACITY MAG, PICK-UP c/w MC II DIGITAL TOTALIZER, CUBIC METER READDUT, SDUR

HALIBURTON

FQI-1000

N.

MODEL 627 REGULATOR 1ºFNPT, 70-150 PSIG RN 2000# STEEL BODY, 1/8° TRIM, SOUR, NYLON DISC

FISHER

PRV-2010

FISHER

. ∭3.

PCV-2240/ 2220/2230

TEMPERATURE INDICATOR 3" DIAL, -40°F-160°F RANGE, DUAL SCALE, c.\* 1/2" x 3/4" x 6" 316 S.S.T THERMOWELL 6" STEM

TREND

PRESSURE INDICATOR & 1/27 DIALIG-200 PSI DUAL SCALE, 1/4º NPT BOTTOM MOUNT,SOUR

INDICATOR 4" DIAL 0-1000 172" NPT BOTTOM MOUNT,

 $\leqslant \frac{1}{X}$ 

(Y)

PI-2010 TI-1000

216-7 MDREL PS-1530C-624-C-JD-FS-NC PREUMATIC HIGH LEVEL SWITCH 1/41/IPT PILGT 316 SS FLDAT 303 SS BODY, SNAP DIPECT MAWP 1509 PSIG, SDUR SER, ICE TRIM

(A) (K)

CSH-1000

DE LIBUID CONTROL VALVE, 1º HPT TO OPEN 7 F41L CLOSED, 6-30 PSIG IN ADJ ORIFICE, SOUR SERVICE, 172° TRIN

01 01

FISHER

. . . . .

0001-7.07

3001-07

MODEL 9:00, I' NPT x I' NPT RELIEF VALVE, SOU TRIM WOS BODY SET 8 ISO PSIG ON THE FOS 19 TRIFITE

MERCER

DI02-ASd

CONTROLLERS SOLR SER. SYAR. 17/8: x 12 VERT, DISPLACER

Select to Fat. Markon Select VALVE LEGEND 1(1) ΩQ FLANGED RF= 1 FLANGED RF= 1 FLANGED RTJ= 2 BUTTWELDED= 3 CMERCHED= 4 SOCKTWENDED= 5 CMERCHED= 5 TUBING= 7

		present.	VALVES
TAG	QTY.	MAKE	DESCRIPTION
3/4"BA4N1	2	BALON	3/4' NPT 3000# R.P., BALL VALVE SOUR SERVICE
1/2"BA4N1	4	BALON	1/2' NPT 3000# R.P., BALL VALVE STD. SERVICE
1/2"BAF4N1S	S	NUTRON	172" NPT 3000# F.P. BALL VALVE SOUR SERVICE
1/2"NE4P1S	Pro	CENTURY	1/2' NPT 6000# MXF NEEDLE VALVE SS, SQUR SERVICE
1/4/NEAPIS	1.	CENTURY	1.4" MPT 6009 MXF NEEDLE VALVE SS SOUR SERVICE
1-BA4NIS	9	BALON	1' NPT 3000# BALL VALVE, R.P. SDJR SERVICE
2.BA131S	1	NUTRON	27300#RF BALL VALVE, R.P. SOUR SERVICE
I'C4H1S		WHEATLE	I' NPT CLASS 800 CHECK JALVE, SOUR SERVICE
174'CP7R1S	ſΝ	TAUPRO	1/4" NPT SST TUBING CHECK VALVE, SOUR SERVICE
1/2°Y4M]		1. T	1.2' NPT 2000# :-STRAINER, STD SERVICE
S[H57.1		4 J.4	1' NPT 2008 V-STRAINEP, SOUR SERVICE
10 to		F CE P	201430 8001 3 TO TO STORY SEBVICE
7.70		( )    -   -	100 miles 100 mi
		-1	
131	123	11	1.0
L -1			30 -30 -60 -60 -60 -60 -60 -60 -60 -60 -60 -6
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		0 0	0. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1.
0.72		ц, 	1 37 147 5000 3F 16E10.E 741 7E

	The state of the s	
_		
		eta erako
		ès, c

a, da

NGE OPDER NGE OFDER

MANUFACTURING LIMITED

C. C. C.	OU ACANAT NOVEC
21 - 21 - 40 82008	c/o MAJESTIC ENGINE
CO OL	LSD: GOODFISH
200000	
CPPITEDS	

	LANADA COE	IN CAINADA COIN	MAJESTIC ENGINE	LSD: GOODFISH	
The second second	DEVION	70,770	0/0	***************************************	10 · 21
		- N			SI ON SI

DEVON CANADA CORPC	LSD: G000FISH	16. OE × 7-6. S.	£ 60 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
EVON			1

<u>~</u>	4 3 S	
DEVON CANADA c/o MAJESTIC EN LSD: GDOD	9.9.	
ON (	in X	く・1・じし
JANA JESTI( LSD:	P	
9	e) (a)	
CORI INEER ISH	0) 0	1
22.2	E 6	

$\bigcirc =$	L. C.
0.7	35443
OZ G	I I
$\Xi$	in the
SAF	wH
DEVON CANADA CORPO c/o MaJESTIC ENGINEERING ISD: GOODEISH	S 5/3 8 8 8 8 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9
	63 1
-1, $0$	
$\Xi \supseteq .$	10 0
Z. C. C.	1
\Z.3.	CL × 7:
<b>○</b> ₩	1
	1 8 12
<u>_</u> _	自自由
$\mathcal{O}_{\mathcal{C}}$	1 1 1 11
= 0	1
$\Xi$	\$12
	je.
	lē.
	1 7
6.3	1
<u>C1</u>	

5 <u>2</u>	(2	1	
DEVOIN CANADA CORPO) c/o MAJESTIC ENGINEERINC LSD: GOODFISH	60 41 41 6	DE SCHERBERGE JEDILDE	2 1.00 1.1 1.00 1.00 1.00 1.00 1.00 1.00
SE F	15.1	8	L
) <u>급</u> SE	(2)	· I.	
4 G 6	63	0.	t
725		الما	1
ANADA SSTIC ENGIN USD: GOODFISH	7-6.573	1	1
3 <u>8</u> -	1.	0	2 4
~ <del>`</del>	×	i	
5.0	E)	L.	
$\Xi^{\circ}$	50		1
$\Box$	les est		
,	Ĕ.,		
C			
<u>C3</u>	en l		

49	L.	1	31
UEVOIN CAINADA COMPON c/o MAJESTIC ENGINEERING LSD: GOODFISH	6.1 1.1 0	FPTICAL SEPARATOR SACA	30 C St 57 L
EE	ő.	Œ	il.
34日	13.1	0	.,
.9 E	(1)	0.	1
Z 22 2	63	-1	
ANADA ESTIC ENGIN LSD: GOODFISH	200	Li	250161 PRESSURE
S 53	1	,	~?
	1.	1	(/)
¥.	×	1-	CY CL
50	ر ا د ا	O.	
-	50		므
7	SO.		L.
<b>-</b> 12	,		( )
, -	1		
C)			
	94		
	-1		

	1			
	1	L		1.4.
	Į.	12	10	
$\subseteq$	1	1	(_)	
	î	No. o	- 1	
c/o MAJESTIC ENGINEERING LTD.	- 1	9000 30HG S	EPTICAL SEPARATIOR PACKAG	PRESSURE 745 PS. 9 8
7.		4.3	-1	
$\simeq$	1	. 1	0	1 11
C+3	1	ī.		
(1)	- 1	10	CE	13
7	-		0	CL
- 1	20	113	3-	
0	-		· i.	* 1
7.	<u> </u>		().	1
	CSD: COODEISH	S/S .9-12 x 3C	·i	
	-51	~	a	1.1
$\mathcal{O}$	_		ليا	U
= :	~i	11,	61	
00	50			1.03
TJ.	-1	1-	11	1
-3	- 1		( )	أدهنا
≤:	1	X		CF
-	8		1-	12.
_	- 3	1-11	Ü.	3
	1	1.1	111	
-	- 1		*	N.S.
-	ļ	sD.		· .
	- 2	41.00		41
	\$1.0			1 3
	1.5			
	-1			
1	1	- 1		
1	1	- 1		
. 1	Į.		1.0	
	1.5	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		
	1 :	ol .		

LSD: GOODFISH	61 11 61	EPTICAL SEPARATOR PAC	ch di	
]	Ó	Œ	UL.	
ISE	1.7	J 5	3.5	
00	1	a:	I	
, 8		ا شا الما	L1 0	
LSD: GOODFISH	210 . 5	3 CJ	23	
	1-	- 1	(Z)	
	,	1-	C.	
	E. 7	) [1]	DESTRUCT PRESSURE	
7	, si	2	<u> </u>	
İs			( )	
2				
-	(Ti)			
	14P P.	à		