


# Codeware, Inc.

ASME SEC VIII, DIV I, 2010ED, 2011AD



## COMPRESS Pressure Vessel Design Calculations

**Item:** 30" O/D x 10' S/S Separator

**Vessel No:** SN1667 to 1674, DWG 2013-070-300R2

**Customer:**

**Rev:** 0

**Designer:** Wilfred Cao

**Date:** Nov 08, 2013

## Table Of Contents

1. Ellipsoidal Head #1
2. Nozzle #2 (N2)
3. Cylinder #1
4. Nozzle #1 (N1)
5. Nozzle #3 (N3)
6. Nozzle #5 (N6)
7. Ellipsoidal Head #2
8. Nozzle #4 (N5)

**Ellipsoidal Head #1****ASME Section VIII, Division 1, 2010 Edition, A11 Addenda**

Component: Ellipsoidal Head  
 Material Specification: SA-516 70 (II-D p.18, In. 19)  
Straight Flange governs MDMT

Internal design pressure:  $P = 1,360 \text{ psi} @ 194 ^\circ\text{F}$

**Static liquid head:**

$P_s = 0 \text{ psi}$  (SG=1,  $H_s = 0"$  Operating head)  
 $P_{th} = 1 \text{ psi}$  (SG=1,  $H_s = 27.72"$  Horizontal test head)

Corrosion allowance: Inner C = 0.125" Outer C = 0"

Design MDMT = -20 °F	No impact test performed
Rated MDMT = -32.3 °F	Material is normalized
	Material is not produced to fine grain practice
	PWHT is not performed
	Do not Optimize MDMT / Find MAWP

Radiography: Category A joints - Seamless No RT  
 Head to shell seam - Full UW-11(a) Type 1

Estimated weight\*: new = 374.7 lb corr = 337.4 lb  
 Capacity\*: new = 17.2 US gal corr = 17.7 US gal  
 \* includes straight flange

Outer diameter	= 30"
Minimum head thickness	= 1.14"
Head ratio D/2h	= 2 (new)
Head ratio D/2h	= 1.9823 (corroded)
Straight flange length $L_{sf}$	= 2"
Nominal straight flange thickness $t_{sf}$	= 1.25"

**Results Summary**

The governing condition is internal pressure.

Minimum thickness per UG-16	= 0.0625" + 0.125" = 0.1875"
Design thickness due to internal pressure ( $t$ )	= 1.0756"
Maximum allowable working pressure (MAWP)	= <u>1,458.12</u> psi

**K (Corroded)**

$$K = (1/6) * [2 + (D / (2 * h))^2] = (1/6) * [2 + (27.97 / (2 * 7.055))^2] = 0.98824$$

**K (New)**

$$K = (1/6) * [2 + (D / (2 * h))^2] = (1/6) * [2 + (27.72 / (2 * 6.93))^2] = 1$$

**Design thickness for internal pressure, (Corroded at 194 °F) Appendix 1-4(c)**

$$\begin{aligned} t &= P \cdot D_o \cdot K / (2 \cdot S \cdot E + 2 \cdot P \cdot (K - 0.1)) + \text{Corrosion} \\ &= 1,360 \cdot 30 \cdot 0.98824 / (2 \cdot 20,000 \cdot 1 + 2 \cdot 1,360 \cdot (0.98824 - 0.1)) + 0.125 \\ &= 1.0756" \end{aligned}$$

The head internal pressure design thickness is 1.0756".

**Maximum allowable working pressure, (Corroded at 194 °F) Appendix 1-4(c)**

$$\begin{aligned} P &= 2 \cdot S \cdot E \cdot t / (K \cdot D_o - 2 \cdot t \cdot (K - 0.1)) - P_s \\ &= 2 \cdot 20,000 \cdot 1 \cdot 1.015 / (0.98824 \cdot 30 - 2 \cdot 1.015 \cdot (0.98824 - 0.1)) - 0 \\ &= 1,458.12 \text{ psi} \end{aligned}$$

The maximum allowable working pressure (MAWP) is 1,458.12 psi.


**% Extreme fiber elongation - UCS-79(d)**

$$\begin{aligned} EFE &= (75 \cdot t / R_f) \cdot (1 - R_f / R_o) \\ &= (75 \cdot 1.25 / 5.3374) \cdot (1 - 5.3374 / \infty) \\ &= 17.5647\% \end{aligned}$$

The extreme fiber elongation exceeds 5 percent and the thickness exceeds 5/8 inch;. Heat treatment per UCS-56 is required if fabricated by cold forming.

## Nozzle #2 (N2)

ASME Section VIII Division 1, 2010 Edition, A11 Addenda



$$\begin{aligned}
 t_{w(lower)} &= 1.14 \text{ in} \\
 \text{Leg}_{41} &= 1.125 \text{ in} \\
 \text{Leg}_{43} &= 0.875 \text{ in} \\
 h_{new} &= 1.25 \text{ in}
 \end{aligned}$$

Note: round inside edges per UG-76(c)

**Location and Orientation**

Located on:	Ellipsoidal Head #1
Orientation:	0°
End of nozzle to datum line:	143 in
Calculated as hillside:	No
Distance to head center, R:	0 in
Passes through a Category A joint:	No

**Nozzle**

Access opening:	No
Material specification:	SA-106 B Smls pipe (II-D p. 10, ln. 40)
Description:	NPS 4 XXS
Inside diameter, new:	3.152 in
Nominal wall thickness:	0.674 in
Corrosion allowance:	0.125 in
Projection available outside vessel, Lpr:	8.7713 in
Internal projection, $h_{new}$ :	1.25 in
Projection available outside vessel to flange face, Lf:	13.0213 in
Local vessel minimum thickness:	1.14 in
Liquid static head included:	0 psi
Longitudinal joint efficiency:	1

**ASME B16.5-2009 Flange**

Description:	NPS 4 Class 600 WN A105
Bolt Material:	SA-193 B7 Bolt $\leq 2\frac{1}{2}$ (II-D p. 334, ln. 32)
Blind included:	No
Rated MDMT:	-27.6°F per UCS-66(b)(1)(b)
Liquid static head:	0 psi

DWG 2013-070-300R2, SN1667 to 1674

MAWP rating: 1,367.2 psi @ 194°F  
MAP rating: 1,480 psi @ 70°F  
Hydrotest rating: 2,225 psi @ 70°F  
PWHT performed: No  
Circumferential joint radiography: Full UW-11(a) Type 1

**Reinforcement Calculations for MAWP**

The attached ASME B16.5 flange limits the nozzle MAWP.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Nozzle Wall Thickness Summary (in)	
For P = 1,367.2 psi @ 194 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
3.1706	3.6227	0.4043	0.9531	0.7685	--	1.4968	0.3324	0.5898

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.7875	weld size is adequate

Calculations for internal pressure 1,367.2 psi @ 194 °F

Fig UCS-66.2 general note (1) applies.

Nozzle is impact test exempt to -155 °F per UCS-66(b)(3) (coincident ratio = 0.3074).

Nozzle UCS-66 governing thk: 0.5898 in

Nozzle rated MDMT: -155 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(3.402, 1.701 + (0.674 - 0.125) + (1.14 - 0.125)) \\
 &= 3.402 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_e) \\
 &= \text{MIN}(2.5*(1.14 - 0.125), 2.5*(0.674 - 0.125) + 0) \\
 &= 1.3725 \text{ in}
 \end{aligned}$$

**Inner Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_I &= \text{MIN}(2.5*(t - C), 2.5*(t_i - C_n - C)) \\
 &= \text{MIN}(2.5*(1.14 - 0.125), 2.5*(0.674 - 0.125 - 0.125)) \\
 &= 1.06 \text{ in}
 \end{aligned}$$

Nozzle required thickness per UG-27(c)(1)

$$\begin{aligned} t_{rn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 1,367.2 \cdot 1.701 / (17,100 \cdot 1 - 0.6 \cdot 1,367.2) \\ &= 0.1429 \text{ in} \end{aligned}$$

Required thickness  $t_r$  from UG-37(a)(c)

$$\begin{aligned} t_r &= P \cdot K_1 \cdot D_o / (2 \cdot S \cdot E + 0.8 \cdot P) \\ &= 1,367.2 \cdot 0.892 \cdot 30 / (2 \cdot 20,000 \cdot 1 + 0.8 \cdot 1,367.2) \\ &= 0.8903 \text{ in} \end{aligned}$$

Area required per UG-37(c)

Allowable stresses:  $S_n = 17,100$ ,  $S_v = 20,000$  psi

$f_{r1}$  = lesser of 1 or  $S_n / S_v = 0.855$

$f_{r2}$  = lesser of 1 or  $S_n / S_v = 0.855$

$$\begin{aligned} A &= d \cdot t_r \cdot F + 2 \cdot t_n \cdot t_r \cdot F \cdot (1 - f_{r1}) \\ &= 3.402 \cdot 0.8903 \cdot 1 + 2 \cdot 0.549 \cdot 0.8903 \cdot 1 \cdot (1 - 0.855) \\ &= \underline{3.1706} \text{ in}^2 \end{aligned}$$

Area available from FIG. UG-37.1

$A_1$  = larger of the following = 0.4043 in<sup>2</sup>

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 3.402 \cdot (1 \cdot 1.015 - 1 \cdot 0.8903) - 2 \cdot 0.549 \cdot (1 \cdot 1.015 - 1 \cdot 0.8903) \cdot (1 - 0.855) \\ &= 0.4043 \text{ in}^2 \\ \\ &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 2 \cdot (1.015 + 0.549) \cdot (1 \cdot 1.015 - 1 \cdot 0.8903) - 2 \cdot 0.549 \cdot (1 \cdot 1.015 - 1 \cdot 0.8903) \cdot (1 - 0.855) \\ &= 0.3702 \text{ in}^2 \end{aligned}$$

$A_2$  = smaller of the following = 0.9531 in<sup>2</sup>

$$\begin{aligned} &= 5 \cdot (t_n - t_{rn}) \cdot f_{r2} \cdot t \\ &= 5 \cdot (0.549 - 0.1429) \cdot 0.855 \cdot 1.015 \\ &= 1.7621 \text{ in}^2 \\ \\ &= 5 \cdot (t_n - t_{rn}) \cdot f_{r2} \cdot t_n \\ &= 5 \cdot (0.549 - 0.1429) \cdot 0.855 \cdot 0.549 \\ &= 0.9531 \text{ in}^2 \end{aligned}$$

$A_3$  = smaller of the following = 0.7685 in<sup>2</sup>

$$\begin{aligned} &= 5*t_i*t_i*f_{r2} \\ &= 5*1.015*0.424*0.855 \\ &= \underline{1.8398} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*t_i*t_i*f_{r2} \\ &= 5*0.424*0.424*0.855 \\ &= \underline{0.7685} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*h*t_i*f_{r2} \\ &= 2*1.125*0.424*0.855 \\ &= \underline{0.8157} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= Leg^2*f_{r2} \\ &= 1.125^2*0.855 \\ &= \underline{1.0821} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{43} &= Leg^2*f_{r2} \\ &= 0.6964^2*0.855 \\ &= \underline{0.4147} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_3 + A_{41} + A_{43} \\ &= 0.4043 + 0.9531 + 0.7685 + 1.0821 + 0.4147 \\ &= \underline{3.6227} \text{ in}^2 \end{aligned}$$

As Area  $\geq A$  the reinforcement is adequate.

### UW-16(c) Weld Check

Fillet weld:  $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.549 \text{ in}$   
 $t_{c(min)} = \text{lesser of } 0.25 \text{ or } 0.7*t_{min} = \underline{0.25} \text{ in}$   
 $t_{c(actual)} = 0.7*Leg = 0.7*1.125 = 0.7875 \text{ in}$

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

### UG-45 Nozzle Neck Thickness Check

Interpretation VIII-1-83-66 has been applied.

$$\begin{aligned} t_{a, UG-27} &= P*R / (S*E - 0.6*P) + \text{Corrosion} \\ &= 1,367.2*1.701 / (17,100*1 - 0.6*1,367.2) + 0.125 \end{aligned}$$

DWG 2013-070-300R2, SN1667 to 1674

$$= 0.2679 \text{ in}$$

$$\begin{aligned} t_a &= \max[ t_{a \text{ UG-27}} , t_{a \text{ UG-22}} ] \\ &= \max[ 0.2679 , 0 ] \\ &= 0.2679 \text{ in} \end{aligned}$$

$$t_{b1} = 1.0803 \text{ in}$$

$$\begin{aligned} t_{b1} &= \max[ t_{b1} , t_{b \text{ UG16}} ] \\ &= \max[ 1.0803 , 0.1875 ] \\ &= 1.0803 \text{ in} \end{aligned}$$

$$\begin{aligned} t_b &= \min[ t_{b3} , t_{b1} ] \\ &= \min[ 0.3324 , 1.0803 ] \\ &= 0.3324 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{UG-45} &= \max[ t_a , t_b ] \\ &= \max[ 0.2679 , 0.3324 ] \\ &= 0.3324 \text{ in} \end{aligned}$$

Available nozzle wall thickness new,  $t_n = 0.875 * 0.674 = 0.5898 \text{ in}$

The nozzle neck thickness is adequate.

**Reinforcement Calculations for MAP**

The attached ASME B16.5 flange limits the nozzle MAP.

UG-37 Area Calculation Summary (in <sup>2</sup> ) For P = 1,480 psi @ 70 °F The opening is adequately reinforced							UG-45 Nozzle Wall Thickness Summary (in) The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
3.248	5.2874	0.5826	1.5274	1.4407	--	1.7367	0.2074	0.5898

UG-41 Weld Failure Path Analysis Summary	
The nozzle is exempt from weld strength calculations per UW-15(b)(1)	

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg41)	0.25	0.7875	weld size is adequate

Calculations for internal pressure 1,480 psi @ 70 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(3.152, 1.576 + (0.674 - 0) + (1.14 - 0)) \\
 &= 3.39 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_e) \\
 &= \text{MIN}(2.5*(1.14 - 0), 2.5*(0.674 - 0) + 0) \\
 &= 1.685 \text{ in}
 \end{aligned}$$

**Inner Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_I &= \text{MIN}(2.5*(t - C), 2.5*(t_i - C_n - C)) \\
 &= \text{MIN}(2.5*(1.14 - 0), 2.5*(0.674 - 0 - 0)) \\
 &= 1.685 \text{ in}
 \end{aligned}$$

**Nozzle required thickness per UG-27(c)(1)**

$$\begin{aligned}
 t_{rn} &= P * R_n / (S_n * E - 0.6 * P) \\
 &= 1,480 * 1.576 / (17,100 * 1 - 0.6 * 1,480) \\
 &= 0.1439 \text{ in}
 \end{aligned}$$

**Required thickness  $t_r$  from UG-37(a)(c)**

$$\begin{aligned} t_r &= P \cdot K_1 \cdot D_o / (2 \cdot S \cdot E + 0.8 \cdot P) \\ &= 1,480 \cdot 0.9 \cdot 30 / (2 \cdot 20,000 \cdot 1 + 0.8 \cdot 1,480) \\ &= 0.9703 \text{ in} \end{aligned}$$

**Area required per UG-37(c)**

Allowable stresses:  $S_n = 17,100$ ,  $S_v = 20,000$  psi

$$f_{r1} = \text{lesser of } 1 \text{ or } S_n / S_v = 0.855$$

$$f_{r2} = \text{lesser of } 1 \text{ or } S_n / S_v = 0.855$$

$$\begin{aligned} A &= d \cdot t_r \cdot F + 2 \cdot t_n \cdot t_r \cdot F \cdot (1 - f_{r1}) \\ &= 3.152 \cdot 0.9703 \cdot 1 + 2 \cdot 0.674 \cdot 0.9703 \cdot 1 \cdot (1 - 0.855) \\ &= \underline{3.248 \text{ in}^2} \end{aligned}$$

**Area available from FIG. UG-37.1**

$$A_1 = \text{larger of the following} = \underline{0.5826 \text{ in}^2}$$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 3.152 \cdot (1 \cdot 1.14 - 1 \cdot 0.9703) - 2 \cdot 0.674 \cdot (1 \cdot 1.14 - 1 \cdot 0.9703) \cdot (1 - 0.855) \\ &= 0.5018 \text{ in}^2 \\ \\ &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 2 \cdot (1.14 + 0.674) \cdot (1 \cdot 1.14 - 1 \cdot 0.9703) - 2 \cdot 0.674 \cdot (1 \cdot 1.14 - 1 \cdot 0.9703) \cdot (1 - 0.855) \\ &= \underline{0.5826 \text{ in}^2} \end{aligned}$$

$$A_2 = \text{smaller of the following} = \underline{1.5274 \text{ in}^2}$$

$$\begin{aligned} &= 5 \cdot (t_n - t_m) \cdot f_{r2} \cdot t \\ &= 5 \cdot (0.674 - 0.1439) \cdot 0.855 \cdot 1.14 \\ &= 2.5834 \text{ in}^2 \\ \\ &= 5 \cdot (t_n - t_m) \cdot f_{r2} \cdot t_n \\ &= 5 \cdot (0.674 - 0.1439) \cdot 0.855 \cdot 0.674 \\ &= \underline{1.5274 \text{ in}^2} \end{aligned}$$

$$A_3 = \text{smaller of the following} = \underline{1.4407 \text{ in}^2}$$

$$\begin{aligned} &= 5 \cdot t_i \cdot t_i \cdot f_{r2} \\ &= 5 \cdot 1.14 \cdot 0.674 \cdot 0.855 \\ &= \underline{3.2847 \text{ in}^2} \\ \\ &= 5 \cdot t_i \cdot t_i \cdot f_{r2} \end{aligned}$$

$$= 5 * 0.674 * 0.674 * 0.855$$

$$= \underline{1.942} \text{ in}^2$$

$$= 2 * h * t_i * f_{r2}$$

$$= 2 * 1.25 * 0.674 * 0.855$$

$$= \underline{1.4407} \text{ in}^2$$

$$A_{41} = \text{Leg}^2 * f_{r2}$$

$$= 1.125^2 * 0.855$$

$$= \underline{1.0821} \text{ in}^2$$

$$A_{43} = \text{Leg}^2 * f_{r2}$$

$$= 0.875^2 * 0.855$$

$$= \underline{0.6546} \text{ in}^2$$

$$\text{Area} = A_1 + A_2 + A_3 + A_{41} + A_{43}$$

$$= 0.5826 + 1.5274 + 1.4407 + 1.0821 + 0.6546$$

$$= \underline{5.2874} \text{ in}^2$$

As Area >= A the reinforcement is adequate.

### **UW-16(c) Weld Check**

Fillet weld:  $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.674 \text{ in}$

$t_{c(min)} = \text{lesser of } 0.25 \text{ or } 0.7 * t_{min} = \underline{0.25} \text{ in}$

$t_{c(actual)} = 0.7 * \text{Leg} = 0.7 * 1.125 = 0.7875 \text{ in}$

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

### **UG-45 Nozzle Neck Thickness Check**

Interpretation VIII-1-83-66 has been applied.

$$t_{a, UG-27} = P * R / (S * E - 0.6 * P) + \text{Corrosion}$$

$$= 1,480 * 1.576 / (17,100 * 1 - 0.6 * 1,480) + 0$$

$$= 0.1439 \text{ in}$$

$$t_a = \max[ t_{a, UG-27}, t_{a, UG-22} ]$$

$$= \max[ 0.1439, 0 ]$$

$$= 0.1439 \text{ in}$$

$$t_{b1} = 1.0407 \text{ in}$$

DWG 2013-070-300R2, SN1667 to 1674

$$\begin{aligned} t_{b1} &= \max[ t_{b1} , t_{b\text{ UG16}} ] \\ &= \max[ 1.0407 , 0.0625 ] \\ &= 1.0407 \text{ in} \end{aligned}$$

$$\begin{aligned} t_b &= \min[ t_{b3} , t_{b1} ] \\ &= \min[ 0.2074 , 1.0407 ] \\ &= 0.2074 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{\text{UG-45}} &= \max[ t_a , t_b ] \\ &= \max[ 0.1439 , 0.2074 ] \\ &= 0.2074 \text{ in} \end{aligned}$$

Available nozzle wall thickness new,  $t_n = 0.875 * 0.674 = 0.5898 \text{ in}$

The nozzle neck thickness is adequate.

**Cylinder #1****ASME Section VIII Division 1, 2010 Edition, A11 Addenda**

Component: Cylinder  
 Material specification: SA-516 70 (II-D p. 18, ln. 19)  
 Material impact test exemption temperature from Fig UCS-66 Curve D = -21 °F  
 Fig UCS-66.1 MDMT reduction = 11.3 °F, (coincident ratio = 0.8872)  
 UCS-66 governing thickness = 1.25 in

Internal design pressure:  $P = 1,360 \text{ psi} @ 194 \text{ °F}$

**Static liquid head:**

$$P_{lh} = 1 \text{ psi}_{\text{head}} \quad (\text{SG} = 1, H_s = 27.61", \text{Horizontal test})$$

Corrosion allowance      Inner C = 0.125"      Outer C = 0"

Design MDMT = -20 °F	No impact test performed
Rated MDMT = -32.3 °F	Material is normalized
	Material is not produced to Fine Grain Practice
	PWHT is not performed

Radiography:	Longitudinal joint -	Full UW-11(a) Type 1
	Top circumferential joint -	Full UW-11(a) Type 1
	Bottom circumferential joint -	Spot UW-11(a)(5)(b) Type 1

Estimated weight New = 3,823.5 lb      corr = 3,456.2 lb  
 Capacity      New = 308.55 US gal      corr = 314.18 US gal

OD      = 30"  
 Length    = 120"  
 $L_c$       = 1.25"

**Design thickness, (at 194 °F) Appendix 1-1**

$$\begin{aligned} t &= P * R_o / (S * E + 0.40 * P) + \text{Corrosion} \\ &= 1,360 * 15 / (20,000 * 1.00 + 0.40 * 1,360) + 0.125 \\ &= 1.118" \end{aligned}$$


**Maximum allowable working pressure, (at 194 °F) Appendix 1-1**

$$\begin{aligned} P &= S * E * t / (R_o - 0.40 * t) - P_s \\ &= 20,000 * 1.00 * 1.125 / (15 - 0.40 * 1.125) - 0 \\ &= 1,546.39 \text{ psi} \end{aligned}$$

**% Extreme fiber elongation - UCS-79(d)**

$$\begin{aligned} EFE &= (50 * t / R_f) * (1 - R_f / R_o) \\ &= (50 * 1.25 / 14.375) * (1 - 14.375 / \infty) \\ &= 4.3478\% \end{aligned}$$

The extreme fiber elongation does not exceed 5%.

**Nozzle #1 (N1)****ASME Section VIII Division 1, 2010 Edition, A11 Addenda**

Note: round inside edges per UG-76(c)

**Location and Orientation**

Located on:	Cylinder #1
Orientation:	90°
Nozzle center line offset to datum line:	84 in
End of nozzle to shell center:	23 in
Passes through a Category A joint:	No

**Nozzle**

Access opening:	No
Material specification:	SA-106 B Smls pipe (II-D p. 10, ln. 40)
Description:	NPS 4 XXS
Inside diameter, new:	3.152 in
Nominal wall thickness:	0.674 in
Corrosion allowance:	0.125 in
Projection available outside vessel, Lpr:	3.75 in
Internal projection, $h_{new}$ :	1.25 in
Projection available outside vessel to flange face, Lf:	8 in
Local vessel minimum thickness:	1.25 in
Liquid static head included:	0 psi
Longitudinal joint efficiency:	1

**ASME B16.5-2009 Flange**

Description:	NPS 4 Class 600 WN A105
Bolt Material:	SA-193 B7 Bolt $\leq 2 \frac{1}{2}$ (II-D p. 334, ln. 32)
Blind included:	No
Rated MDMT:	-27.6 °F per UCS-66(b)(1)(b)
Liquid static head:	0 psi
MAWP rating:	1,367.2 psi @ 194 °F

DWG 2013-070-300R2, SN1667 to 1674

MAP rating: 1,480 psi @ 70°F  
Hydrotest rating: 2,225 psi @ 70°F  
PWHT performed: No  
Circumferential joint radiography: Full UW-11(a) Type 1

**Reinforcement Calculations for MAWP**

The attached ASME B16.5 flange limits the nozzle MAWP.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Nozzle Wall Thickness Summary (in)	
For P = 1,367.2 psi @ 194 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
3.5545	3.981	0.4115	0.9531	0.7685	--	1.8479	0.3324	0.5898

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.7875	weld size is adequate

Calculations for internal pressure 1,367.2 psi @ 194 °F

Fig UCS-66.2 general note (1) applies.

Nozzle is impact test exempt to -155 °F per UCS-66(b)(3) (coincident ratio = 0.3074).

Nozzle UCS-66 governing thk: 0.5898 in

Nozzle rated MDMT: -155 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(3.402, 1.701 + (0.674 - 0.125) + (1.25 - 0.125)) \\
 &= 3.402 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_o) \\
 &= \text{MIN}(2.5*(1.25 - 0.125), 2.5*(0.674 - 0.125) + 0) \\
 &= 1.3725 \text{ in}
 \end{aligned}$$

**Inner Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_I &= \text{MIN}(2.5*(t - C), 2.5*(t_i - C_n - C)) \\
 &= \text{MIN}(2.5*(1.25 - 0.125), 2.5*(0.674 - 0.125 - 0.125)) \\
 &= 1.06 \text{ in}
 \end{aligned}$$

**Nozzle required thickness per UG-27(c)(1)**

$$\begin{aligned} t_n &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 1,367.2 \cdot 1.701 / (17,100 \cdot 1 - 0.6 \cdot 1,367.2) \\ &= 0.1429 \text{ in} \end{aligned}$$

**Required thickness  $t_r$  from UG-37(a)**

$$\begin{aligned} t_r &= P \cdot R_o / (S \cdot E + 0.4 \cdot P) \\ &= 1,367.2 \cdot 15 / (20,000 \cdot 1 + 0.4 \cdot 1,367.2) \\ &= 0.9981 \text{ in} \end{aligned}$$

**Area required per UG-37(c)**

Allowable stresses:  $S_n = 17,100$ ,  $S_v = 20,000$  psi

$f_{r1}$  = lesser of 1 or  $S_n / S_v = 0.855$

$f_{r2}$  = lesser of 1 or  $S_n / S_v = 0.855$

$$\begin{aligned} A &= d \cdot t_r \cdot F + 2 \cdot t_n \cdot t_r \cdot F \cdot (1 - f_{r1}) \\ &= 3.402 \cdot 0.9981 \cdot 1 + 2 \cdot 0.549 \cdot 0.9981 \cdot 1 \cdot (1 - 0.855) \\ &= 3.5545 \text{ in}^2 \end{aligned}$$

**Area available from FIG. UG-37.1**

$A_1$  = larger of the following = 0.4115 in<sup>2</sup>

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 3.402 \cdot (1 \cdot 1.125 - 1 \cdot 0.9981) - 2 \cdot 0.549 \cdot (1 \cdot 1.125 - 1 \cdot 0.9981) \cdot (1 - 0.855) \\ &= 0.4115 \text{ in}^2 \\ \\ &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 2 \cdot (1.125 + 0.549) \cdot (1 \cdot 1.125 - 1 \cdot 0.9981) - 2 \cdot 0.549 \cdot (1 \cdot 1.125 - 1 \cdot 0.9981) \cdot (1 - 0.855) \\ &= 0.4046 \text{ in}^2 \end{aligned}$$

$A_2$  = smaller of the following = 0.9531 in<sup>2</sup>

$$\begin{aligned} &= 5 \cdot (t_n - t_r) \cdot f_{r2} \cdot t \\ &= 5 \cdot (0.549 - 0.1429) \cdot 0.855 \cdot 1.125 \\ &= 1.9531 \text{ in}^2 \\ \\ &= 5 \cdot (t_n - t_r) \cdot f_{r2} \cdot t_n \\ &= 5 \cdot (0.549 - 0.1429) \cdot 0.855 \cdot 0.549 \\ &= 0.9531 \text{ in}^2 \end{aligned}$$

$A_3$  = smaller of the following = 0.7685 in<sup>2</sup>

$$\begin{aligned} &= 5*t_i*f_{r2} \\ &= 5*1.125*0.424*0.855 \\ &= \underline{2.0392 \text{ in}^2} \end{aligned}$$

$$\begin{aligned} &= 5*t_i*t_i*f_{r2} \\ &= 5*0.424*0.424*0.855 \\ &= \underline{0.7685 \text{ in}^2} \end{aligned}$$

$$\begin{aligned} &= 2*h*t_i*f_{r2} \\ &= 2*1.125*0.424*0.855 \\ &= \underline{0.8157 \text{ in}^2} \end{aligned}$$

$$\begin{aligned} A_{41} &= Leg^2*f_{r2} \\ &= 1.125^2*0.855 \\ &= \underline{1.0821 \text{ in}^2} \end{aligned}$$

$$\begin{aligned} A_{43} &= Leg^2*f_{r2} \\ &= 0.9464^2*0.855 \\ &= \underline{0.7658 \text{ in}^2} \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_3 + A_{41} + A_{43} \\ &= 0.4115 + 0.9531 + 0.7685 + 1.0821 + 0.7658 \\ &= \underline{3.981 \text{ in}^2} \end{aligned}$$

As Area  $\geq A$  the reinforcement is adequate.

### UW-16(c) Weld Check

Fillet weld:  $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.549 \text{ in}$   
 $t_{c(min)} = \text{lesser of } 0.25 \text{ or } 0.7*t_{min} = \underline{0.25 \text{ in}}$   
 $t_{c(actual)} = 0.7*Leg = 0.7*1.125 = 0.7875 \text{ in}$

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

### UG-45 Nozzle Neck Thickness Check

$$\begin{aligned} t_{a \text{ UG-27}} &= P*R / (S*E - 0.6*P) + \text{Corrosion} \\ &= 1,367.2*1.701 / (17,100*1 - 0.6*1,367.2) + 0.125 \\ &= 0.2679 \text{ in} \end{aligned}$$

$$t_a = \max[t_{a \text{ UG-27}}, t_{a \text{ UG-22}}]$$

DWG 2013-070-300R2, SN1667 to 1674

$$= \max[ 0.2679 , 0 ]$$

$$= 0.2679 \text{ in}$$

$$t_{b1} = P^*R_o / (S^*E + 0.4^*P) + \text{Corrosion}$$

$$= 1,367.2^*15 / (20,000^*1 + 0.4^*1,367.2) + 0.125$$

$$= 1.1231 \text{ in}$$

$$t_{b1} = \max[ t_{b1} , t_{b \text{ UG16}} ]$$

$$= \max[ 1.1231 , 0.1875 ]$$

$$= 1.1231 \text{ in}$$

$$t_b = \min[ t_{b3} , t_{b1} ]$$

$$= \min[ 0.3324 , 1.1231 ]$$

$$= 0.3324 \text{ in}$$

$$t_{\text{UG-45}} = \max[ t_a , t_b ]$$

$$= \max[ 0.2679 , 0.3324 ]$$

$$= 0.3324 \text{ in}$$

Available nozzle wall thickness new,  $t_n = 0.875^*0.674 = 0.5898 \text{ in}$

The nozzle neck thickness is adequate.

**Reinforcement Calculations for MAP**

The attached ASME B16.5 flange limits the nozzle MAP.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Nozzle Wall Thickness Summary (in)	
For P = 1,480 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
3.6089	5.7602	0.6279	1.5274	1.4407	--	2.1642	0.2074	0.5898

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(1)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.7875	weld size is adequate

Calculations for internal pressure 1,480 psi @ 70 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(3.152, 1.576 + (0.674 - 0) + (1.25 - 0)) \\
 &= 3.5 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_e) \\
 &= \text{MIN}(2.5*(1.25 - 0), 2.5*(0.674 - 0) + 0) \\
 &= 1.685 \text{ in}
 \end{aligned}$$

**Inner Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_I &= \text{MIN}(2.5*(t - C), 2.5*(t_i - C_n - C)) \\
 &= \text{MIN}(2.5*(1.25 - 0), 2.5*(0.674 - 0 - 0)) \\
 &= 1.685 \text{ in}
 \end{aligned}$$

**Nozzle required thickness per UG-27(c)(1)**

$$\begin{aligned}
 t_m &= P * R_n / (S_n * E - 0.6 * P) \\
 &= 1,480 * 1.576 / (17,100 * 1 - 0.6 * 1,480) \\
 &= 0.1439 \text{ in}
 \end{aligned}$$

**Required thickness  $t_r$  from UG-37(a)**

$$\begin{aligned} t_r &= P \cdot R_o / (S \cdot E + 0.4 \cdot P) \\ &= 1,480 \cdot 15 / (20,000 \cdot 1 + 0.4 \cdot 1,480) \\ &= 1.0781 \text{ in} \end{aligned}$$

**Area required per UG-37(c)**

Allowable stresses:  $S_n = 17,100$ ,  $S_v = 20,000$  psi

$f_{r1}$  = lesser of 1 or  $S_n / S_v = 0.855$

$f_{r2}$  = lesser of 1 or  $S_n / S_v = 0.855$

$$\begin{aligned} A &= d \cdot t_r \cdot F + 2 \cdot t_n \cdot t_r \cdot F \cdot (1 - f_{r1}) \\ &= 3.152 \cdot 1.0781 \cdot 1 + 2 \cdot 0.674 \cdot 1.0781 \cdot 1 \cdot (1 - 0.855) \\ &= \underline{3.6089 \text{ in}^2} \end{aligned}$$

**Area available from FIG. UG-37.1**

$A_1$  = larger of the following = 0.6279 in<sup>2</sup>

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 3.152 \cdot (1 \cdot 1.25 - 1 \cdot 1.0781) - 2 \cdot 0.674 \cdot (1 \cdot 1.25 - 1 \cdot 1.0781) \cdot (1 - 0.855) \\ &= 0.5083 \text{ in}^2 \\ \\ &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 2 \cdot (1.25 + 0.674) \cdot (1 \cdot 1.25 - 1 \cdot 1.0781) - 2 \cdot 0.674 \cdot (1 \cdot 1.25 - 1 \cdot 1.0781) \cdot (1 - 0.855) \\ &= 0.6279 \text{ in}^2 \end{aligned}$$

$A_2$  = smaller of the following = 1.5274 in<sup>2</sup>

$$\begin{aligned} &= 5 \cdot (t_n - t_m) \cdot f_{r2} \cdot t \\ &= 5 \cdot (0.674 - 0.1439) \cdot 0.855 \cdot 1.25 \\ &= 2.8327 \text{ in}^2 \\ \\ &= 5 \cdot (t_n - t_m) \cdot f_{r2} \cdot t_n \\ &= 5 \cdot (0.674 - 0.1439) \cdot 0.855 \cdot 0.674 \\ &= 1.5274 \text{ in}^2 \end{aligned}$$

$A_3$  = smaller of the following = 1.4407 in<sup>2</sup>

$$\begin{aligned} &= 5 \cdot t_i \cdot t_j \cdot f_{r2} \\ &= 5 \cdot 1.25 \cdot 0.674 \cdot 0.855 \\ &= \underline{3.6017 \text{ in}^2} \\ \\ &= 5 \cdot t_i \cdot t_j \cdot f_{r2} \end{aligned}$$

$$= 5 * 0.674 * 0.674 * 0.855$$

$$= \underline{1.942} \text{ in}^2$$

$$= 2 * h * t_i * f_r_2$$

$$= 2 * 1.25 * 0.674 * 0.855$$

$$= \underline{1.4407} \text{ in}^2$$

$$A_{41} = \text{Leg}^2 * f_{r2}$$

$$= 1.125^2 * 0.855$$

$$= \underline{1.0821} \text{ in}^2$$

$$A_{43} = \text{Leg}^2 * f_{r2}$$

$$= 1.125^2 * 0.855$$

$$= \underline{1.0821} \text{ in}^2$$

$$\text{Area} = A_1 + A_2 + A_3 + A_{41} + A_{43}$$

$$= 0.6279 + 1.5274 + 1.4407 + 1.0821 + 1.0821$$

$$= \underline{5.7602} \text{ in}^2$$

As Area >= A the reinforcement is adequate.

### **UW-16(c) Weld Check**

Fillet weld:  $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.674 \text{ in}$

$t_{c(min)} = \text{lesser of } 0.25 \text{ or } 0.7 * t_{min} = \underline{0.25} \text{ in}$

$t_{c(actual)} = 0.7 * \text{Leg} = 0.7 * 1.125 = 0.7875 \text{ in}$

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

### **UG-45 Nozzle Neck Thickness Check**

$$t_{a,UG-27} = P * R / (S * E - 0.6 * P) + \text{Corrosion}$$

$$= 1,480 * 1.576 / (17,100 * 1 - 0.6 * 1,480) + 0$$

$$= 0.1439 \text{ in}$$

$$t_a = \max[ t_{a,UG-27}, t_{a,UG-22} ]$$

$$= \max[ 0.1439, 0 ]$$

$$= 0.1439 \text{ in}$$

$$t_{b1} = P * R_o / (S * E + 0.4 * P) + \text{Corrosion}$$

$$= 1,480 * 15 / (20,000 * 1 + 0.4 * 1,480) + 0$$

$$= 1.0781 \text{ in}$$

$$\begin{aligned} t_{b1} &= \max[ t_{b1} , t_{b\text{ UG16}} ] \\ &= \max[ 1.0781 , 0.0625 ] \\ &= 1.0781 \text{ in} \end{aligned}$$

$$\begin{aligned} t_b &= \min[ t_{b3} , t_{b1} ] \\ &= \min[ 0.2074 , 1.0781 ] \\ &= 0.2074 \text{ in} \end{aligned}$$


$$\begin{aligned} t_{\text{UG-45}} &= \max[ t_a , t_b ] \\ &= \max[ 0.1439 , 0.2074 ] \\ &= 0.2074 \text{ in} \end{aligned}$$

Available nozzle wall thickness new,  $t_n = 0.875 * 0.674 = 0.5898 \text{ in}$

The nozzle neck thickness is adequate.

## Nozzle #3 (N3)

ASME Section VIII Division 1, 2010 Edition, A11 Addenda



$$\begin{aligned}
 t_{w(lower)} &= 1.25 \text{ in} \\
 \text{Leg}_{41} &= 1.125 \text{ in} \\
 \text{Leg}_{43} &= 0.75 \text{ in} \\
 h_{new} &= 1 \text{ in}
 \end{aligned}$$

Note: round inside edges per UG-76(c)

**Location and Orientation**

Located on:	Cylinder #1
Orientation:	90°
Nozzle center line offset to datum line:	64 in
End of nozzle to shell center:	23 in
Passes through a Category A joint:	No

**Nozzle**

Access opening:	No
Material specification:	SA-106 B Smls pipe (II-D p. 10, ln. 40)
Description:	NPS 3 XXS
Inside diameter, new:	2.3 in
Nominal wall thickness:	0.6 in
Corrosion allowance:	0.125 in
Projection available outside vessel, Lpr:	4.5 in
Internal projection, $h_{new}$ :	1 in
Projection available outside vessel to flange face, Lf:	8 in
Local vessel minimum thickness:	1.25 in
Liquid static head included:	0 psi
Longitudinal joint efficiency:	1

**ASME B16.5-2009 Flange**

Description:	NPS 3 Class 600 WN A105
Bolt Material:	SA-193 B7 Bolt $\leq 2 \frac{1}{2}$ (II-D p. 334, ln. 32)
Blind included:	No
Rated MDMT:	-27.6°F per UCS-66(b)(1)(b)
Liquid static head:	0 psi
MAWP rating:	1,367.2 psi @ 194°F

DWG 2013-070-300R2, SN1667 to 1674

MAP rating: 1,480 psi @ 70°F  
Hydrotest rating: 2,225 psi @ 70°F  
PWHT performed: No  
Circumferential joint radiography: Full UW-11(a) Type 1

**Reinforcement Calculations for MAWP**

The attached ASME B16.5 flange limits the nozzle MAWP.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Nozzle Wall Thickness Summary (in)	
For P = 1,367.2 psi @ 194 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
2.6827	3.0207	0.3886	0.7471	0.5237	--	1.3613	0.314	0.525

UG-41 Weld Failure Path Analysis Summary								
The nozzle is exempt from weld strength calculations per UW-15(b)(1)								

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.7875	weld size is adequate

Calculations for internal pressure 1,367.2 psi @ 194 °F

Fig UCS-66.2 general note (1) applies.

Nozzle is impact test exempt to -155 °F per UCS-66(b)(3) (coincident ratio = 0.2677).

Nozzle UCS-66 governing thk: 0.525 in

Nozzle rated MDMT: -155 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(2.55, 1.275 + (0.6 - 0.125) + (1.25 - 0.125)) \\
 &= 2.875 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_e) \\
 &= \text{MIN}(2.5*(1.25 - 0.125), 2.5*(0.6 - 0.125) + 0) \\
 &= 1.1875 \text{ in}
 \end{aligned}$$

**Inner Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_I &= \text{MIN}(2.5*(t - C), 2.5*(t_i - C_n - C)) \\
 &= \text{MIN}(2.5*(1.25 - 0.125), 2.5*(0.6 - 0.125 - 0.125)) \\
 &= 0.875 \text{ in}
 \end{aligned}$$

**Nozzle required thickness per UG-27(c)(1)**

$$\begin{aligned} t_n &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 1,367.2 \cdot 1.275 / (17,100 \cdot 1 - 0.6 \cdot 1,367.2) \\ &= 0.1071 \text{ in} \end{aligned}$$

**Required thickness  $t_r$  from UG-37(a)**

$$\begin{aligned} t_r &= P \cdot R_o / (S \cdot E + 0.4 \cdot P) \\ &= 1,367.2 \cdot 15 / (20,000 \cdot 1 + 0.4 \cdot 1,367.2) \\ &= 0.9981 \text{ in} \end{aligned}$$

**Area required per UG-37(c)**

Allowable stresses:  $S_n = 17,100$ ,  $S_v = 20,000$  psi

$$f_{r1} = \text{lesser of } 1 \text{ or } S_n / S_v = 0.855$$

$$f_{r2} = \text{lesser of } 1 \text{ or } S_n / S_v = 0.855$$

$$\begin{aligned} A &= d \cdot t_r \cdot F + 2 \cdot t_n \cdot t_r \cdot F \cdot (1 - f_{r1}) \\ &= 2.55 \cdot 0.9981 \cdot 1 + 2 \cdot 0.475 \cdot 0.9981 \cdot 1 \cdot (1 - 0.855) \\ &= \underline{2.6827} \text{ in}^2 \end{aligned}$$

**Area available from FIG. UG-37.1**

$$A_1 = \text{larger of the following} = \underline{0.3886} \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 2.55 \cdot (1 \cdot 1.125 - 1 \cdot 0.9981) - 2 \cdot 0.475 \cdot (1 \cdot 1.125 - 1 \cdot 0.9981) \cdot (1 - 0.855) \\ &= 0.3061 \text{ in}^2 \\ \\ &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\ &= 2 \cdot (1.125 + 0.475) \cdot (1 \cdot 1.125 - 1 \cdot 0.9981) - 2 \cdot 0.475 \cdot (1 \cdot 1.125 - 1 \cdot 0.9981) \cdot (1 - 0.855) \\ &= 0.3886 \text{ in}^2 \end{aligned}$$

$$A_2 = \text{smaller of the following} = \underline{0.7471} \text{ in}^2$$

$$\begin{aligned} &= 5 \cdot (t_n - t_m) \cdot f_{r2} \cdot t \\ &= 5 \cdot (0.475 - 0.1071) \cdot 0.855 \cdot 1.125 \\ &= 1.7694 \text{ in}^2 \\ \\ &= 5 \cdot (t_n - t_m) \cdot f_{r2} \cdot t_n \\ &= 5 \cdot (0.475 - 0.1071) \cdot 0.855 \cdot 0.475 \\ &= 0.7471 \text{ in}^2 \end{aligned}$$

$A_3$  = smaller of the following = 0.5237 in<sup>2</sup>

$$\begin{aligned} &= 5*t_i*t_{r2} \\ &= 5*1.125*0.35*0.855 \\ &= \underline{1.6833} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*t_i*t_i*f_{r2} \\ &= 5*0.35*0.35*0.855 \\ &= \underline{0.5237} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*h*t_i*f_{r2} \\ &= 2*0.875*0.35*0.855 \\ &= \underline{0.5237} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= Leg^2*f_{r2} \\ &= 1.125^2*0.855 \\ &= \underline{1.0821} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{43} &= Leg^2*f_{r2} \\ &= 0.5714^2*0.855 \\ &= \underline{0.2792} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_3 + A_{41} + A_{43} \\ &= 0.3886 + 0.7471 + 0.5237 + 1.0821 + 0.2792 \\ &= \underline{3.0207} \text{ in}^2 \end{aligned}$$

As Area  $\geq A$  the reinforcement is adequate.

### UW-16(c) Weld Check

Fillet weld:  $t_{min}$  = lesser of 0.75 or  $t_n$  or  $t = 0.475$  in  
 $t_{c(min)}$  = lesser of 0.25 or  $0.7*t_{min}$  = 0.25 in  
 $t_{c(actual)} = 0.7*Leg = 0.7*1.125 = 0.7875$  in

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

### UG-45 Nozzle Neck Thickness Check

$$\begin{aligned} t_{a\text{ UG-27}} &= P*R / (S*E - 0.6*P) + \text{Corrosion} \\ &= 1,367.2*1.275 / (17,100*1 - 0.6*1,367.2) + 0.125 \\ &= 0.2321 \text{ in} \end{aligned}$$

$$t_a = \max[t_{a\text{ UG-27}}, t_{a\text{ UG-22}}]$$

DWG 2013-070-300R2, SN1667 to 1674

$$\begin{aligned} &= \max[ 0.2321 , 0 ] \\ &= 0.2321 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{b1} &= P^*R_o / (S^*E + 0.4^*P) + \text{Corrosion} \\ &= 1,367.2^*15 / (20,000^*1 + 0.4^*1,367.2) + 0.125 \\ &= 1.1231 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{b1} &= \max[ t_{b1} , t_{b\text{ UG16}} ] \\ &= \max[ 1.1231 , 0.1875 ] \\ &= 1.1231 \text{ in} \end{aligned}$$

$$\begin{aligned} t_b &= \min[ t_{b3} , t_{b1} ] \\ &= \min[ 0.314 , 1.1231 ] \\ &= 0.314 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{\text{UG-45}} &= \max[ t_a , t_b ] \\ &= \max[ 0.2321 , 0.314 ] \\ &= 0.314 \text{ in} \end{aligned}$$

Available nozzle wall thickness new,  $t_n = 0.875^*0.6 = 0.525 \text{ in}$

The nozzle neck thickness is adequate.

**Reinforcement Calculations for MAP**

The attached ASME B16.5 flange limits the nozzle MAP.

UG-37 Area Calculation Summary (in <sup>2</sup> ) For P = 1,480 psi @ 70 °F							UG-45 Nozzle Wall Thickness Summary (in) The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.189	0.525

UG-41 Weld Failure Path Analysis Summary	
The nozzle is exempt from weld strength calculations per UW-15(b)(2)	

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.7875	weld size is adequate

Calculations for internal pressure 1,480 psi @ 70 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(2.3, 1.15 + (0.6 - 0) + (1.25 - 0)) \\
 &= 3 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_o) \\
 &= \text{MIN}(2.5*(1.25 - 0), 2.5*(0.6 - 0) + 0) \\
 &= 1.5 \text{ in}
 \end{aligned}$$

**Inner Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_i &= \text{MIN}(2.5*(t - C), 2.5*(t_i - C_n - C)) \\
 &= \text{MIN}(2.5*(1.25 - 0), 2.5*(0.6 - 0 - 0)) \\
 &= 1.5 \text{ in}
 \end{aligned}$$

**Nozzle required thickness per UG-27(c)(1)**

$$\begin{aligned}
 t_m &= P * R_n / (S_n * E - 0.6 * P) \\
 &= 1,480 * 1.15 / (17,100 * 1 - 0.6 * 1,480) \\
 &= 0.105 \text{ in}
 \end{aligned}$$

**Required thickness  $t_r$  from UG-37(a)**

$$\begin{aligned} t_r &= P \cdot R_o / (S \cdot E + 0.4 \cdot P) \\ &= 1,480 \cdot 15 / (20,000 \cdot 1 + 0.4 \cdot 1,480) \\ &= 1.0781 \text{ in} \end{aligned}$$

**This opening does not require reinforcement per UG-36(c)(3)(a)**

**UW-16(c) Weld Check**

Fillet weld:  $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.6 \text{ in}$   
 $t_{c(min)} = \text{lesser of } 0.25 \text{ or } 0.7 \cdot t_{min} = 0.25 \text{ in}$   
 $t_{c(actual)} = 0.7 \cdot \text{Leg} = 0.7 \cdot 1.125 = 0.7875 \text{ in}$

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

**UG-45 Nozzle Neck Thickness Check**

$$\begin{aligned} t_{a \text{ UG-27}} &= P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion} \\ &= 1,480 \cdot 1.15 / (17,100 \cdot 1 - 0.6 \cdot 1,480) + 0 \\ &= 0.105 \text{ in} \end{aligned}$$

$$\begin{aligned} t_a &= \max[ t_{a \text{ UG-27}}, t_{a \text{ UG-22}} ] \\ &= \max[ 0.105, 0 ] \\ &= 0.105 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{b1} &= P \cdot R_o / (S \cdot E + 0.4 \cdot P) + \text{Corrosion} \\ &= 1,480 \cdot 15 / (20,000 \cdot 1 + 0.4 \cdot 1,480) + 0 \\ &= 1.0781 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{b1} &= \max[ t_{b1}, t_{b \text{ UG16}} ] \\ &= \max[ 1.0781, 0.0625 ] \\ &= 1.0781 \text{ in} \end{aligned}$$

$$\begin{aligned} t_b &= \min[ t_{b3}, t_{b1} ] \\ &= \min[ 0.189, 1.0781 ] \\ &= 0.189 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{\text{UG-45}} &= \max[ t_a, t_b ] \\ &= \max[ 0.105, 0.189 ] \\ &= 0.189 \text{ in} \end{aligned}$$


Available nozzle wall thickness new,  $t_n = 0.875 \cdot 0.6 = 0.525 \text{ in}$

The nozzle neck thickness is adequate.

**Nozzle #5 (N6)****ASME Section VIII Division 1, 2010 Edition, A11 Addenda**

$$t_{w(lower)} = 1.25 \text{ in}$$

$$\text{Leg}_{41} = 0.375 \text{ in}$$



Note: round inside edges per UG-76(c)

**Location and Orientation**

Located on:	Cylinder #1
Orientation:	60°
Nozzle center line offset to datum line:	60 in
End of nozzle to shell center:	21 in
Passes through a Category A joint:	No

**Nozzle**

Access opening:	No
Material specification:	SA-106 B Smls pipe (II-D p. 10, ln. 40)
Description:	NPS 2 XXS
Inside diameter, new:	1.503 in
Nominal wall thickness:	0.436 in
Corrosion allowance:	0.125 in
Projection available outside vessel, Lpr:	2.87 in
Projection available outside vessel to flange face, Lf:	6 in
Local vessel minimum thickness:	1.25 in
Liquid static head included:	0 psi
Longitudinal joint efficiency:	1

**ASME B16.5-2009 Flange**

Description:	NPS 2 Class 600 WN A105
Bolt Material:	SA-193 B7 Bolt <= 2 1/2 (II-D p. 334, ln. 32)
Blind included:	No
Rated MDMT:	-27.6°F per UCS-66(b)(1)(b)
Liquid static head:	0 psi
MAWP rating:	1,367.2 psi @ 194°F
MAP rating:	1,480 psi @ 70°F

DWG 2013-070-300R2, SN1667 to 1674

Hydrotest rating: 2,225 psi @ 70°F  
PWHT performed: No  
Circumferential joint radiography: Full UW-11(a) Type 1

**Reinforcement Calculations for MAWP**

The attached ASME B16.5 flange limits the nozzle MAWP.

UG-37 Area Calculation Summary (in <sup>2</sup> ) For P = 1,367.2 psi @ 194 °F							UG-45 Nozzle Wall Thickness Summary (in) The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.2598	0.3815

UG-41 Weld Failure Path Analysis Summary			
The nozzle is exempt from weld strength calculations per UW-15(b)(2)			

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.2177	0.2625	weld size is adequate

Calculations for internal pressure 1,367.2 psi @ 194 °F

Fig UCS-66.2 general note (1) applies.

Nozzle is impact test exempt to -155 °F per UCS-66(b)(3) (coincident ratio = 0.287).

Nozzle UCS-66 governing thk: 0.3815 in

Nozzle rated MDMT: -155 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(1.753, 0.8765 + (0.436 - 0.125) + (1.25 - 0.125)) \\
 &= 2.3125 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_e) \\
 &= \text{MIN}(2.5*(1.25 - 0.125), 2.5*(0.436 - 0.125) + 0) \\
 &= 0.7775 \text{ in}
 \end{aligned}$$

**Nozzle required thickness per UG-27(c)(1)**

$$\begin{aligned}
 t_{rn} &= P * R_n / (S_n * E - 0.6 * P) \\
 &= 1,367.2 * 0.8765 / (17,100 * 1 - 0.6 * 1,367.2) \\
 &= 0.0736 \text{ in}
 \end{aligned}$$

Required thickness  $t_r$  from UG-37(a)

$$\begin{aligned} t_r &= P^*R_o / (S^*E + 0.4^*P) \\ &= 1,367.2^*15 / (20,000^*1 + 0.4^*1,367.2) \\ &= 0.9981 \text{ in} \end{aligned}$$

This opening does not require reinforcement per UG-36(c)(3)(a)

#### UW-16(c) Weld Check

Fillet weld:  $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.311 \text{ in}$   
 $t_{c(min)} = \text{lesser of } 0.25 \text{ or } 0.7^*t_{min} = 0.2177 \text{ in}$   
 $t_{c(actual)} = 0.7^*\text{Leg} = 0.7^*0.375 = 0.2625 \text{ in}$

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

#### UG-45 Nozzle Neck Thickness Check

$$\begin{aligned} t_{aUG-27} &= P^*R / (S^*E - 0.6^*P) + \text{Corrosion} \\ &= 1,367.2^*0.8765 / (17,100^*1 - 0.6^*1,367.2) + 0.125 \\ &= 0.1986 \text{ in} \end{aligned}$$

$$\begin{aligned} t_a &= \max[ t_{aUG-27}, t_{aUG-22} ] \\ &= \max[ 0.1986, 0 ] \\ &= 0.1986 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{b1} &= P^*R_o / (S^*E + 0.4^*P) + \text{Corrosion} \\ &= 1,367.2^*15 / (20,000^*1 + 0.4^*1,367.2) + 0.125 \\ &= 1.1231 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{b1} &= \max[ t_{b1}, t_{bUG16} ] \\ &= \max[ 1.1231, 0.1875 ] \\ &= 1.1231 \text{ in} \end{aligned}$$

$$\begin{aligned} t_b &= \min[ t_{b3}, t_{b1} ] \\ &= \min[ 0.2598, 1.1231 ] \\ &= 0.2598 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{UG-45} &= \max[ t_a, t_b ] \\ &= \max[ 0.1986, 0.2598 ] \\ &= 0.2598 \text{ in} \end{aligned}$$

Available nozzle wall thickness new,  $t_n = 0.875^*0.436 = 0.3815 \text{ in}$

The nozzle neck thickness is adequate.

**Reinforcement Calculations for MAP**

The attached ASME B16.5 flange limits the nozzle MAP.

UG-37 Area Calculation Summary (in <sup>2</sup> ) For P = 1,480 psi @ 70 °F							UG-45 Nozzle Wall Thickness Summary (in) The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1348	0.3815

UG-41 Weld Failure Path Analysis Summary		
The nozzle is exempt from weld strength calculations per UW-15(b)(2)		

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.2625	weld size is adequate

Calculations for internal pressure 1,480 psi @ 70 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(1.503, 0.7515 + (0.436 - 0) + (1.25 - 0)) \\
 &= 2.4375 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_e) \\
 &= \text{MIN}(2.5*(1.25 - 0), 2.5*(0.436 - 0) + 0) \\
 &= 1.09 \text{ in}
 \end{aligned}$$

**Nozzle required thickness per UG-27(c)(1)**

$$\begin{aligned}
 t_m &= P * R_n / (S_n * E - 0.6 * P) \\
 &= 1,480 * 0.7515 / (17,100 * 1 - 0.6 * 1,480) \\
 &= 0.0686 \text{ in}
 \end{aligned}$$

**Required thickness t<sub>r</sub> from UG-37(a)**

$$\begin{aligned}
 t_r &= P * R_o / (S * E + 0.4 * P) \\
 &= 1,480 * 15 / (20,000 * 1 + 0.4 * 1,480) \\
 &= 1.0781 \text{ in}
 \end{aligned}$$

This opening does not require reinforcement per UG-36(c)(3)(a)

### UW-16(c) Weld Check

Fillet weld:  $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.436 \text{ in}$

$t_{c(min)} = \text{lesser of } 0.25 \text{ or } 0.7*t_{min} = 0.25 \text{ in}$

$t_{c(actual)} = 0.7*\text{Leg} = 0.7*0.375 = 0.2625 \text{ in}$

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

### UG-45 Nozzle Neck Thickness Check

$$\begin{aligned} t_{aUG-27} &= P*R / (S*E - 0.6*P) + \text{Corrosion} \\ &= 1,480*0.7515 / (17,100*1 - 0.6*1,480) + 0 \\ &= 0.0686 \text{ in} \end{aligned}$$

$$\begin{aligned} t_a &= \max[ t_{aUG-27}, t_{aUG-22} ] \\ &= \max[ 0.0686, 0 ] \\ &= 0.0686 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{b1} &= P*R_o / (S*E + 0.4*P) + \text{Corrosion} \\ &= 1,480*15 / (20,000*1 + 0.4*1,480) + 0 \\ &= 1.0781 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{b1} &= \max[ t_{b1}, t_{bUG16} ] \\ &= \max[ 1.0781, 0.0625 ] \\ &= 1.0781 \text{ in} \end{aligned}$$

$$\begin{aligned} t_b &= \min[ t_{b3}, t_{b1} ] \\ &= \min[ 0.1348, 1.0781 ] \\ &= 0.1348 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{UG-45} &= \max[ t_a, t_b ] \\ &= \max[ 0.0686, 0.1348 ] \\ &= 0.1348 \text{ in} \end{aligned}$$

Available nozzle wall thickness new,  $t_n = 0.875*0.436 = 0.3815 \text{ in}$

The nozzle neck thickness is adequate.

**Ellipsoidal Head #2****ASME Section VIII, Division 1, 2010 Edition, A11 Addenda**

Component: Ellipsoidal Head  
 Material Specification: SA-516 70 (II-D p.18, ln. 19)  
Straight Flange governs MDMT

Internal design pressure:  $P = 1,360 \text{ psi} @ 194 ^\circ\text{F}$

**Static liquid head:**

$P_s = 0 \text{ psi}$  (SG=1,  $H_s = 0"$  Operating head)  
 $P_{th} = 1 \text{ psi}$  (SG=1,  $H_s = 27.72"$  Horizontal test head)

Corrosion allowance: Inner C = 0.125" Outer C = 0"

Design MDMT = -20°F	No impact test performed
Rated MDMT = -32.3°F	Material is normalized
	Material is not produced to fine grain practice
	PWHT is not performed
	Do not Optimize MDMT / Find MAWP

Radiography:	Category A joints -	Seamless No RT
	Head to shell seam -	Spot UW-11(a)(5)(b) Type 1

Estimated weight*: new = 378.4 lb	corr = 340.7 lb
Capacity*: new = 17.2 US gal	corr = 17.7 US gal

\* includes straight flange

Outer diameter	= 30"
Minimum head thickness	= 1.14"
Head ratio D/2h	= 2 (new)
Head ratio D/2h	= 1.9823 (corroded)
Straight flange length $L_{sf}$	= 2"
Nominal straight flange thickness $t_{sf}$	= 1.25"

**Results Summary**

The governing condition is internal pressure.

Minimum thickness per UG-16	= 0.0625" + 0.125" = 0.1875"
Design thickness due to internal pressure (t)	= <u>1.0756"</u>
Maximum allowable working pressure (MAWP)	= <u>1,458.12 psi</u>

**K (Corroded)**

$$K = (1/6) * [2 + (D / (2 * h))^2] = (1/6) * [2 + (27.97 / (2 * 7.055))^2] = 0.98824$$

**K (New)**

$$K = (1/6) * [2 + (D / (2 * h))^2] = (1/6) * [2 + (27.72 / (2 * 6.93))^2] = 1$$

**Design thickness for internal pressure, (Corroded at 194 °F) Appendix 1-4(c)**

$$\begin{aligned} t &= P \cdot D_o \cdot K / (2 \cdot S \cdot E + 2 \cdot P \cdot (K - 0.1)) + \text{Corrosion} \\ &= 1,360 \cdot 30 \cdot 0.98824 / (2 \cdot 20,000 \cdot 1 + 2 \cdot 1,360 \cdot (0.98824 - 0.1)) + 0.125 \\ &= 1.0756'' \end{aligned}$$

The head internal pressure design thickness is 1.0756".

**Maximum allowable working pressure, (Corroded at 194 °F) Appendix 1-4(c)**

$$\begin{aligned} P &= 2 \cdot S \cdot E \cdot t / (K \cdot D_o - 2 \cdot t \cdot (K - 0.1)) - P_s \\ &= 2 \cdot 20,000 \cdot 1 \cdot 1.015 / (0.98824 \cdot 30 - 2 \cdot 1.015 \cdot (0.98824 - 0.1)) - 0 \\ &= 1,458.12 \text{ psi} \end{aligned}$$

The maximum allowable working pressure (MAWP) is 1,458.12 psi.

**% Extreme fiber elongation - UCS-79(d)**


$$\begin{aligned} \text{EFE} &= (75 \cdot t / R_f) \cdot (1 - R_f / R_o) \\ &= (75 \cdot 1.25 / 5.3374) \cdot (1 - 5.3374 / \infty) \\ &= 17.5647\% \end{aligned}$$

The extreme fiber elongation exceeds 5 percent and the thickness exceeds 5/8 inch;. Heat treatment per UCS-56 is required if fabricated by cold forming.

**Nozzle #4 (N5)****ASME Section VIII Division 1, 2010 Edition, A11 Addenda**

$$t_{w(lower)} = 1.14 \text{ in}$$

$$\text{Leg}_{41} = 0.375 \text{ in}$$



Note: round inside edges per UG-76(c)

**Location and Orientation**

Located on:	Ellipsoidal Head #2
Orientation:	0°
End of nozzle to datum line:	-17 in
Calculated as hillside:	No
Distance to head center, R:	0 in
Passes through a Category A joint:	No

**Nozzle**

Access opening:	No
Material specification:	SA-106 B Smls pipe (II-D p. 10, ln. 40)
Description:	NPS 2 XXS
Inside diameter, new:	1.503 in
Nominal wall thickness:	0.436 in
Corrosion allowance:	0.125 in
Projection available outside vessel, Lpr:	3.8253 in
Projection available outside vessel to flange face, Lf:	6.9553 in
Local vessel minimum thickness:	1.14 in
Liquid static head included:	0 psi
Longitudinal joint efficiency:	1

**ASME B16.5-2009 Flange**

Description:	NPS 2 Class 600 WN A105
Bolt Material:	SA-193 B7 Bolt <= 2 1/2 (II-D p. 334, ln. 32)
Blind included:	No
Rated MDMT:	-27.6 °F per UCS-66(b)(1)(b)
Liquid static head:	0 psi
MAWP rating:	1,367.2 psi @ 194 °F

DWG 2013-070-300R2, SN1667 to 1674

MAP rating: 1,480 psi @ 70°F  
Hydrotest rating: 2,225 psi @ 70°F  
PWHT performed: No  
Circumferential joint radiography: Full UW-11(a) Type 1

**Reinforcement Calculations for MAWP**

The attached ASME B16.5 flange limits the nozzle MAWP.

UG-37 Area Calculation Summary (in <sup>2</sup> ) For P = 1,367.2 psi @ 194 °F							UG-45 Nozzle Wall Thickness Summary (in) The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.2598	0.3815

UG-41 Weld Failure Path Analysis Summary		
The nozzle is exempt from weld strength calculations per UW-15(b)(2)		

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.2177	0.2625	weld size is adequate

Calculations for internal pressure 1,367.2 psi @ 194 °F

Fig UCS-66.2 general note (1) applies.

Nozzle is impact test exempt to -155 °F per UCS-66(b)(3) (coincident ratio = 0.287).

Nozzle UCS-66 governing thk: 0.3815 in

Nozzle rated MDMT: -155 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(1.753, 0.8765 + (0.436 - 0.125) + (1.14 - 0.125)) \\
 &= 2.2025 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_o) \\
 &= \text{MIN}(2.5*(1.14 - 0.125), 2.5*(0.436 - 0.125) + 0) \\
 &= 0.7775 \text{ in}
 \end{aligned}$$

**Nozzle required thickness per UG-27(c)(1)**

$$\begin{aligned}
 t_m &= P * R_n / (S_n * E - 0.6 * P) \\
 &= 1,367.2 * 0.8765 / (17,100 * 1 - 0.6 * 1,367.2) \\
 &= 0.0736 \text{ in}
 \end{aligned}$$

Required thickness  $t_r$  from UG-37(a)(c)

$$\begin{aligned} t_r &= P \cdot K_1 \cdot D_o / (2 \cdot S \cdot E + 0.8 \cdot P) \\ &= 1,367.2 \cdot 0.892 \cdot 30 / (2 \cdot 20,000 \cdot 1 + 0.8 \cdot 1,367.2) \\ &= 0.8903 \text{ in} \end{aligned}$$

This opening does not require reinforcement per UG-36(c)(3)(a)

### UW-16(c) Weld Check

Fillet weld:  $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.311 \text{ in}$

$t_{c(min)} = \text{lesser of } 0.25 \text{ or } 0.7 \cdot t_{min} = 0.2177 \text{ in}$

$t_{c(actual)} = 0.7 \cdot \text{Leg} = 0.7 \cdot 0.375 = 0.2625 \text{ in}$

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

### UG-45 Nozzle Neck Thickness Check

Interpretation VIII-1-83-66 has been applied.

$$\begin{aligned} t_{a \text{ UG-27}} &= P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion} \\ &= 1,367.2 \cdot 0.8765 / (17,100 \cdot 1 - 0.6 \cdot 1,367.2) + 0.125 \\ &= 0.1986 \text{ in} \end{aligned}$$

$$\begin{aligned} t_a &= \max[ t_{a \text{ UG-27}}, t_{a \text{ UG-22}} ] \\ &= \max[ 0.1986, 0 ] \\ &= 0.1986 \text{ in} \end{aligned}$$

$$t_{b1} = 1.0803 \text{ in}$$

$$\begin{aligned} t_{b1} &= \max[ t_{b1}, t_{b \text{ UG16}} ] \\ &= \max[ 1.0803, 0.1875 ] \\ &= 1.0803 \text{ in} \end{aligned}$$

$$\begin{aligned} t_b &= \min[ t_{b3}, t_{b1} ] \\ &= \min[ 0.2598, 1.0803 ] \\ &= 0.2598 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{\text{UG-45}} &= \max[ t_a, t_b ] \\ &= \max[ 0.1986, 0.2598 ] \\ &= 0.2598 \text{ in} \end{aligned}$$

Available nozzle wall thickness new,  $t_n = 0.875 \cdot 0.436 = 0.3815 \text{ in}$

The nozzle neck thickness is adequate.

**Reinforcement Calculations for MAP**

The attached ASME B16.5 flange limits the nozzle MAP.

UG-37 Area Calculation Summary (in <sup>2</sup> ) For P = 1,480 psi @ 70 °F							UG-45 Nozzle Wall Thickness Summary (in) The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1348	0.3815

UG-41 Weld Failure Path Analysis Summary		
The nozzle is exempt from weld strength calculations per UW-15(b)(2)		

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg 41)	0.25	0.2625	weld size is adequate

Calculations for internal pressure 1,480 psi @ 70 °F

**Parallel Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(1.503, 0.7515 + (0.436 - 0) + (1.14 - 0)) \\
 &= 2.3275 \text{ in}
 \end{aligned}$$

**Outer Normal Limit of reinforcement per UG-40**

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_e) \\
 &= \text{MIN}(2.5*(1.14 - 0), 2.5*(0.436 - 0) + 0) \\
 &= 1.09 \text{ in}
 \end{aligned}$$

**Nozzle required thickness per UG-27(c)(1)**

$$\begin{aligned}
 t_{rn} &= P * R_n / (S_n * E - 0.6 * P) \\
 &= 1,480 * 0.7515 / (17,100 * 1 - 0.6 * 1,480) \\
 &= 0.0686 \text{ in}
 \end{aligned}$$

**Required thickness t<sub>r</sub> from UG-37(a)(c)**

$$\begin{aligned}
 t_r &= P * K_1 * D_o / (2 * S * E + 0.8 * P) \\
 &= 1,480 * 0.9 * 30 / (2 * 20,000 * 1 + 0.8 * 1,480) \\
 &= 0.9703 \text{ in}
 \end{aligned}$$

This opening does not require reinforcement per UG-36(c)(3)(a)

### UW-16(c) Weld Check

Fillet weld:  $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.436 \text{ in}$

$t_c(min) = \text{lesser of } 0.25 \text{ or } 0.7*t_{min} = 0.25 \text{ in}$

$t_c(actual) = 0.7*\text{Leg} = 0.7*0.375 = 0.2625 \text{ in}$

The fillet weld size is satisfactory.

Weld strength calculations are not required for this detail which conforms to Fig. UW-16.1, sketch (c-e).

### UG-45 Nozzle Neck Thickness Check

Interpretation VIII-1-83-66 has been applied.

$$\begin{aligned} t_{aUG-27} &= P*R / (S*E - 0.6*P) + \text{Corrosion} \\ &= 1,480*0.7515 / (17,100*1 - 0.6*1,480) + 0 \\ &= 0.0686 \text{ in} \end{aligned}$$

$$\begin{aligned} t_a &= \max[ t_{aUG-27}, t_{aUG-22} ] \\ &= \max[ 0.0686, 0 ] \\ &= 0.0686 \text{ in} \end{aligned}$$

$$t_{b1} = 1.0407 \text{ in}$$

$$\begin{aligned} t_{b1} &= \max[ t_{b1}, t_{bUG16} ] \\ &= \max[ 1.0407, 0.0625 ] \\ &= 1.0407 \text{ in} \end{aligned}$$

$$\begin{aligned} t_b &= \min[ t_{b3}, t_{b1} ] \\ &= \min[ 0.1348, 1.0407 ] \\ &= 0.1348 \text{ in} \end{aligned}$$

$$\begin{aligned} t_{UG-45} &= \max[ t_a, t_b ] \\ &= \max[ 0.0686, 0.1348 ] \\ &= 0.1348 \text{ in} \end{aligned}$$

Available nozzle wall thickness new,  $t_n = 0.875*0.436 = 0.3815 \text{ in}$

The nozzle neck thickness is adequate.

shell:

2013-070  
SN 1667 to 1674  
DRWG: 2013-070-300 Rev. 2

$$S = \frac{P(R - 0.4t)}{Et}$$

$$= \frac{2040(15 - 0.4 \times 1.25)}{1.25}$$

$$= 23664 \text{ psi}$$

$$< 0.9 \times 38,000$$

$$= 34,200 \text{ psi}$$