



VESSEL ID: 0218152

DATE OF INSPECTION: 2003 Aug 11



Certificate of Inspection

AGGLANT ENERGY INC
255 S AVENUE SW SUITE 1000
STINER GULLIAN
SAGINAW MI
48763

INSURED

PREFERRED RE-INSP INTERVAL: 5.00 Yr

YEAR BUILT: 1984

CRN: E8263.2

SERIAL #: 26971A

VOLUME: 72.7 M³

HEATING SURFACE
SURFACE AREA

COMPANY CODE: W1000

DESCRIPTION: LPG STORAGE TANK

LOCATION: LSD 19 2940-23 W56

MANUFACTURER: WESTERN ROCK BIT CO LTD

Safety Valves

PART	MAX AUTHORIZED WORKING PRESSURE	MAX TEMP	MIN TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	1724 KPA	49 C	-10 C	SV1	1724 KPA	18954 KG/H	SHLL
				SV2	1724 KPA	18954 KG/H	SHLL
				SV3	2198 KPA		SHLL

OWNER INSTRUCTIONS/REMARKS:

Safety Codes Officer: BILECKI, GARY

Signature:

NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER

Owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.