Login Home **Quality Assurance** Help Exit

FILTER INSPECTION REPORT

Inspection Report Print Back Cancel									Cancel				
Notification Number	607	6075961				Work	Work Order			6079051			
Notification Desc	FIL	FILTER, HORIZONTAL 60" OD X 16'0"				D X Maint	(Maintenance Plan			QPFILTER1264			
Tasklist Operation	(1)	(1Y Inspection Interval) 1Y Code Inspection Filter - Sweet Servi											
Equipment Static Data													
Equipment Number	661	66120331					Equipment Description			FILTER, HORIZONTAL 60" OD X 16'0"			
Class	FIL	FILTER					Tag Number			100			
Serial Number							Year Built			2006			
Manufacturer		BROMLEY MECHANICAL SERVICES											
Location	SS-	SS-SK-052-00003				Locat	Location Description			MATADOR 14-24 COMPRESSOR STATION			
Provincial Number	055	0557602				PM A	PM Activity			Code			
Status Codes	NOI	NOPR ORAS				Equip	Equipment Status		In Service - Fully Utilized				
CDN Number Fluid													
CRN Number			T4	T4927.231 Code S			Stamp U		Description				
Fluid Service			sv	VEET Intern Exists			nal Coating		Length		100	6.00 OOT	
MDMT - Min. Design Metal Temp			-20	DEGF	Sh	ell MAWP	MAWP 720 PS		SI Stress Relief				
Vessel Diameter			60	.0 " Volum		lume	e 317.33 CUFT		3 X-Ray				
PRD Static	Data												
Equip ID Lo	cation	_	ize Outlet	Set Pressu		Capacity	Manufa	acturer	Serial Number	Model Number	Nex	t Service Date	
					_			***************************************					
		-			_								
		<u></u>		<u></u>									
Process Data													
Product Description NATURAL GAS Fluid Service Sweet Sour PPM Operating Pressure 120 KPA Operating Temperature 11 °C													
Pressure Test Test Completed													
Test Completed Yes No Test Acceptable Yes No Test Report #													

Tag/Serial No.	Location		ize Outlet	Set Pressure	Capacity	Model / Type	Service Date
66120339	TOP SHELL PIPING	2"	3"	4964 KPA	11076 SCFM	FARRIS	2008.11.28

Inspection History

PSV Data

Inspected By BURTON D Inspection Date 2008.11.28

Inspection Summary

- -external,internal inspection completed Nov.28,2008
- -internal corrosion pitting found to be minor or corrosion rate minimal

at this time. -2" crash dump internal nozzle has a small erosion cut at top of nozzle of 0.035" depth (see photo) -please change static data to read Inlet Separator,not (Filter)										
Recommendations										
-recommend applying EC-124 gro and other minor corroded areas n										
Repairs Completed										
no grout repairs done at this time, temperature of vessel was below										
coating manufacturer recommendations of 10 C										
Integrity Status Suitable for Continued Service Immediate Repairs Required Repairs Required										
Inventory Status In Service	- Fully Utilized	Idle	Repairs Required Surplus	Scrap						
QA Activities										
Leave As-Is	Weld Overlayed		Part / Component	Replaced						
Equipment Replaced	Grind Dressed		Patch Installed							
MAWP Derated	Coating - Cleaned Patched	d &	Coating - Removed Replaced	1 &						
Defect Removed & Rewelded	Part Cleaned		Lapped & Dressed							
Epoxy Patched										
Noncompliances or Inspection Deficiencies Issued										
-shell has some minor oxidation or rust in s feww small areas -saddle supports are bolted (4 bolts),all weldments are acceptable condition -all attached piping,instrumentation,bolting,supports,clamps are secure -some pipes have a small amount of minimal rust oxidation -temperature and pressure gage appear operational -PSV was sent for servicing at inspection time,is secured to piping on north vessel end -nameplate secure,legible,registered correctly by plate data -new gasket was installed at manway entrance,bolting secure										
External NDE Examination										
-manway nozzle, blind plate, suppo-inlet nozzle has welded support a nozzle was nor removed at inspect corrosion -2" crash dump nozzle has a small nozzle -all other nozzles were in good cor-4" north nozzle with vortex break used, external side of nozzle is blin-22" ID x 36" deep belly pot is in glappers were found at bottom of provering nozzle, felt with fingers, codefects -all weldments are visually accepta-inlet nozzle and deflector are in genorth head has some small diame 2007 inspection as well, max pit denoted.	round expanded metal tion, no signs of any end and tion, no signs of any end and tion with no corrosion of the sign of the sig	,access to osion or vest side of on found . Nozzle is neck valve x breaker p ciceable	not late							
-upper shell has some minor scale with minor pitting up to 0.007"										
Internal NDE Evamination										

Pit Depth Gage Measurements

South head - towards top of head 0.063" x 0.250" diameter

-mid-lower west side - 0.033", 0.038", 0.054" (all approx. 0.250" diameter) Shell -Lower North West shell - 0.023" x 0.375" diameter Shell belly 2" crash dump nozzle - small erode cut approx. 0.035" depth x .187" width x 0.250" length **Data Integrity** -PSV serviced at inspection time, passed lift test at 721 psi, set is 720 -PSV service interval increases to 3 years service interval -corroded pit depths were at 0.050" in Sept. 2007 inspection, deepest pi t depth now is 0.063", corroded 0.013" in 14 months -CR appears to be 0.0108" annually -it may be possible that the north head had a few corrosion spots in metal when it was constructed otherwise the corrosion rate would be 0.0315" annually **Inspection Interval** -set at a 1 year interval, to have patch coating applied to eroded and small corroded areas, when temperatures are at least 10C for substrate **Damages Inspector Certification** I, the undersigned certify that the above equipment has been inspected in accordance with the assigned task list and that statements within this report are correct and represent inspection findings. Inspector Name BURTON D Inspector Signature Inspection Company HUSKY Date Lead Inspector's Acceptance & Schedule Confirmation Lead Inspector Signature Date Vessel Inspection Leave as-is / Change to: Interval **PSV Inspection Interval** Leave as-is / Change to: Top















































