



306-634-5304

### Relief Valve Report

321 Imperial Ave  
Box 355, S4A 2A4  
Estevan, Sask

Customer	EMS ID #	16418	Work Order #	SV-43873-4	Date Received	NOV.7/2017								
	Customer	FERUS	Vessel S/N	N/A	Phone #	403-302-8919								
	Facility	N/A	Vessel Description	N/A	Authorized By	TERRY KRASOWSKI								
	LSD	C1016	Vessel A#	N/A	Cost Centre #	N/A								
	Shipping Instructions	HFPU NOV.8/2017. TERRY WILL PICK UP ALL PSV'S.			Cust. Ref.	N/A								
Valve Data	Make	REGO	Connection	THREADED	Orifice Size	2"								
	Model #	A3149G	Inlet Size	2.5 MNPT	Trim Material	STD								
	Serial #	12077-4	Outlet Size	ATMOSPHERE	Seat Material	VITON								
	CRN#	OG8326.5	Capacity	9883 SCFM	Set Pressure	303 PSI								
	Customer Tag	N/A	Lever/Cap Ass'y	CAP	Back Pressure	0 PSI								
	ASME Code Symbol	UV/NB	Operating temp	AMBIENT	Cold/Diff Set Press	303 PSI								
Customer Instruction	Instruction	New	Repair	✓	Replace									
	Change Set Pressure	Yes	No	✓	New Set Pressure	N/A								
	Pretest Required?	✓			Prev. Set Pressure	N/A								
	Reset Required?	✓			Prev. Cold/Diff Set	N/A								
	Comments				Prev. Model #	N/A								
As Received	Visual Condition	ACC	Data Plate Condition	ACC	Last Service Date	N/A								
	Top Seal Condition	ACC	Inlet Condition	ACC	Last Service Co.	N/A								
	Bottom Seal Condition	N/A	Outlet Condition	ACC	Inspector Initials	N/A								
Pretest 1	Simmer	313 PSI	Set Press	315 PSI	Test Gauge	474628								
	Leakage	0 PSI	Reseat	281 PSI	Tested By	SM								
	Comments				Pass/Fail	PASS								
Pretest 2	Simmer	304 PSI	Set Press	306 PSI	Test Gauge	474628								
	Leakage	0 PSI	Reseat	278 PSI	Tested By	SM								
	Comments				Pass/Fail	PASS								
Pretest 3	Simmer	304 PSI	Set Press	306 PSI	Test Gauge	474628								
	Leakage	0 PSI	Reseat	276 PSI	Tested By	SM								
	Comments				Pass/Fail	PASS								
Component Inspection	Item	Clean	Oily	Rusty	Carbon	Other	Replaced	N/A	Acceptable	Comments				
	Disc	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Nozzle	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Cap-Lever Assy	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Comp Screw, Locknut	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Spring and Buttons	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Spindle/Stem	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Guide/Upper Ring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Gasket/Seal	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Connection Ends	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Data Plate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Stem Retainer	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Disc Holder	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Ring Pin(s)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
	Bellows	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>					
Other	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>						
	Minimum	Actual	Disassembled By:		N/A									
	Nozzle	N/A	Inspected By:		STEVE MAENPAA									
	Disc	N/A	Reassembled By:		N/A									
Final Test	Set Pressure	303 PSI	Adj Ring Upper	N/A	Test Medium	Air	<input checked="" type="checkbox"/>	Water	<input type="checkbox"/>					
	Simmer	301 PSI	Adj Ring Lower	FIXED	Test Gauge Tag #	474628								
	Reseat	274 PSI	Back Pressure Test	N/A	NB18 Set Press Def	POP								
	Leakage	0 PSI	Cold/Diff Set	303 PSI	Tested By	STEVE MAENPAA								
Final Inspection	Seal Top	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>	Painted	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	Final Inspection	STEVE MAENPAA
	Seal Bottom	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>	Paint Colour	ORANGE (2017)		Witnessed Inspection	N/A		
	End Caps Installed	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>	Palletized	NO		Customer Inspection	N/A		
	Gasket Supplied	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>	Shipping container	N/A		Picked Up By	N/A		
	Return Customer Fit'gs	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>				Pick Up Date	N/A		
	Report Emailed To													
Comments														

*2018-03-28*

Popped slightly over (4%) on first, but within tolerance for second two tests. To remain on 5 years, as there are multiple PSVs for protection for this unit.