



Z-100 INLET SEPARATOR SKID VENDOR: SURE WELD INTERNATIONAL	F-104/105 EXHAUST FANS MODEL: RUFFNECK AH-20A 115V/1/60 Hz DUTY: 68000 BTL/hr	H-805/806 BUILDING HEATERS MODEL: RUFFNECK AH-20A 115V/1/60 Hz DUTY: 68000 BTL/hr	V-101 INLET GAS SEPARATOR SIZE: 1887mm DIA. x 8096mm S/S D.P.: 1965 kPa @ 38 °C COATING: NO CRN./SN.:	P-103A/B CONDENSATE BOOSTER PUMPS MAKE: GOULD TYPE: CENTRIFUGAL, ELECTRIC CAP.: 9.8 m ³ /hr. DRIVER: 5.6/7.5 (kW/H.P.) 480V/3/60 Hz	V-102 RECYCLE CYCLONE SEPARATOR MAKE: PORTATEST CAPACITY: 40 MMSCFD @ 35 kPa dP O.P.: 690 kPa @ 10°C D.P.: 1965 kPa @ 38°C	V-935 UTILITY AIR RECEIVER SIZE: 355mm O.D. x 838mm LG CAP.: 75L D.P.: 1034 kPa D.T.: 49°C
---	--	--	---	---	--	--

NOTES:

- FIELD LOCATE TIE-IN TO HYDROCARBON DRAIN
2-F-A-4107-25HG

REV	REVISION	DATE	DRWN BY	CHKD BY	CIVIL APP	PROC APP	MECH APP	ELEC APP	INST APP	SYST APP	PROJ ENG	Q.A.	OWNER CHKD	OWNER APP
16	AS BUILT - CHINCHAGA PLANT EXPANSION (01-778.04)	02.03.13	GX											
15	PLANT EXPANSION 2001/2002 (CONCISE JOB No. 01-778.04) - ISSUED FOR CONSTRUCTION	01.11.30	CJB											
14	PLANT EXPANSION 2001/2002 (CONCISE JOB No. 01-778.04) - ISSUED FOR BID	01.11.01	CJB											
13	PLANT EXPANSION 2001/2002 (CONCISE JOB No. 01-778.04) - ISSUED FOR APPROVAL	01.09.28	CJB											
12	AS BUILT	01.02.21	GS											
11	CONDENSATE LINE ADDED (00-778.01) - ISSUED FOR CONSTRUCTION	00.11.06	DS											
10	AS-BUILT	00.04.25	A.M.											
18	2006 AS-BUILT (778.16)	06.03.31	GX											
17	GAS PLANT EXPANSION (778.16) - ISSUED FOR CONSTRUCTION	05.12.23	ME											

PERMIT	ENGINEER
--------	----------

Concise Design
Engineering Services
300, 736 - 6 Avenue S.W. Calgary, Alberta T2P 3W1 Telephone: (403) 237-7160 Fax: (403) 237-7166

Tartan Engineering
CALGARY ALBERTA

PIONEER
NATURAL RESOURCES CANADA INC.

CHINCHAGA GAS PLANT
c-32-H/94-H-8
INLET SEPARATOR SKID Z-100 P&ID

SCALE	PROJECT No.	DWG. No.	REV
NTS	226200	A1-2262-B-105	18

FILE NAME: G:\1778\00\MECH\2262B105.DWG -- MENU: C:\ACADUSER\SUPPORT\ACAD -- PLOTTED: 2006.06.19 11:15am -- jmolina