



88 6th Street, Suite 400
New Westminster, BC V3L 5B3

Phone: (604) 660 - 6286
Toll Free: 1-866-566-SAFE
Fax: (604) 660 - 6215
www.safetyauthority.ca

HTH HEATECH INC
8916 44TH STREET SE
CALGARY AB T2P 2P6

Date: April 21, 2007
Account #: 21053
Journal #: 42419
Our File #: 3472372

Attn: LAVERNE STADFELD

Re: Application for Design Registration

The design, as detailed in your, REF # H608-47, for a Boiler is accepted for registration as follows:

Registered To: PIONEER NATURAL RESOURCES CRN: K6154.1(R1)
CANADA INC

MAWT: 650 deg F

MAWP: 200 psig

Drawing #: 06274-CD-1

Drawing Revision: 1

Contact me if you have any questions.

ROMEO TUAZON
(604) 660-6246
Romeo.Tuazon@safetyauthority.ca
Design Engineer

cc:



the pressure equipment safety authority

9410 - 20 Ave N.W.

Edmonton, Alberta, Canada T6N 0A4

Tel: (780) 437-9100 / Fax: (780) 437-7787

May 15, 2007

Laverne Stadfeld
HTH HEATECH INC
8916 44 STREET SE
CALGARY, AB T2C 2P6

Dear Laverne Stadfeld,

The drawings, specifications and/or information received on April 26, 2007 are accepted for registration as follows:

CRN : K6154.12

Accepted on: May 15, 2007

Tracking No. : 2007-03031

Reg Type : New Design

Drawing No. : 06274-CD-1 Rev 1

Description	MAWP	Design Temperature
internal pressure	1379 kPa	343 ^o C

Registered under owner / manufacturer name HEATEC INC.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

Enclosed are stamped prints for your reference.

Sincerely,

FOK, PO, P. Eng.
Design Survey Engineer

