

V-610

DISCHARGE OIL TRAP / COALESCER

Quality Control Documentation





rain -		CIC	
, G	MANUFACTU	RED AND CERTIFIED BY	•
	(TE)	THERMO DESIGNE ENGINEERING LTD.	
W RT-2	EDMONTON	ALBERTA GANADA	
	UNITNAME	TAG NUMBE	ER
DISCHARGE	OILTRAP/	COALESCER V-610	434
CH. NUMBER	SERIAL NUMBER		
N-8389,21	# 1617		
260 PSIG	200°F	M.D.M.T. AT PRESSURE - 20°F 260 PSIG	
1998	0.0625 IN	9097-0850-204	· · · · · · · · · · · · · · · · · · ·
30 INOD	7-65/S	CAPACITY WEIGHT	、) See
SA-S16-70N	SA-105N SA-516-70N	TBSHT. MATL. COIL MATL.	Edwar .
0.875 IN	SHEADMIN. THK. 150# BLD. FLG 0.3451N	TESHT. THK. COIL.THK.	
	的构建区的形式	A集が探り、All All All All All All All All All All	1



TO:

THERMO DESIGN ENGINEERING LTD

Date:

Account #

19971

Jo

98/03/12

Journal #

1.8736

T6C 4E9

Attn:

JOHN HARGREAVES

BOX 5557 STATION L

EDMONTON ALTA

Re:

THERMO DESIGN ENGINEERING LTD

DESIGN REGISTRATION

C.R.N.

N8389 21

Drawings / Documents		•	Des	scription 			
DISCHG OIL TRAP/COALSCR 9097-0850-204 REV 1		MDMT		MAWT		MAWP	
9097-0850-204 REV I	Vessel	-20	F	200	F	260 psi	
,	Htg coil	-20	A64.60	350	(55)	150 psi	
REGISTERED	Code of Complia	ınce: ASMI	E Sec	VIII Div	1, 9	5 Ed., A96.	
	V						


Remarks: This design has been registered as noted above. An invoice for survey will follow in the amount of \$ 225.00

CRN issued in accordance with the ACI Policies on Reciprocal Recognition of Design Review for Registration. Alberta issued CRN N8389.2 on Sept. 5, 1997 for Dwg. # 9037-0220-205 Rev 2 which has same design conditions as above Dwg. # 9097-0850-204 Rev 1.

cb Encl: cc: Yours truly,

R. TUAZON

Design Surveyor





TAQA NORTH DATA **EQUIP NO.:** 603VS011

PLANT/FIELD: CHINCHAGA GAS PLANT

LSD: C-032-H / 094-H-08

PRN: N/A

CATEGORY:

LOCATION: GAS PLANT

RAMS ID TAG NO.: NEW

EQUIP. NAME: DISC	HARGE OIL	TRAP/COA	LESCER		CLA	ASS: VS				TYPE:	COAL	ESCER		
SERVICE: ⊠Sweet	Sour	H2S:	N/A	PPM	FLU	J ID : OII	L	S/D	REQT.:	:	□Yes □	□No [Partial	
OPERATING PRESSUE	RE:	965	⊠kPa	□PS	I OPI	ERATING	3 ТЕМРЕ	RATURE	: N	/A	□°C		□°F	
OPERATING STATUS:	⊠IN SERV	/ICE	□Not In	Service	M/V	VAY (16"A1	ND ABOVE):	: ⊠Ye	es 🗌	No :	SIZE: 16	,,		
MANUEL CEVIDIN	C D . T .													
MANUFACTURIN														
MFG.: THERMO ENG.		VG. NO.:				NO.: 16		YR. B		1998		MP: U		
CRN: N8389.21		IV.: ASME			PARA.:	N/							zzles N/A	
	kPa PSI	@ TEMP:			□°F	MDMT:				OLUMI		\square M ³	⊠FT³	
FLANGE RATING: 150		□Yes	⊠No			GRAPHY					4 □Spot			
	⊠mm. □inch			LENGTI		N/A	☐mm.			EIGHT				
INSULATION TYPE: [Fiberglass		□Low T		Asbestos	Other:	NONE		ATION	THK:	N/A			
SECTION			MATER	IAL			NOMIN	NAL mm				C.A. mn	1	
SHELL			SA-516-7	70N			9.5	MM				1.6 MM	<u> </u>	
TOP HEAD			SA-105	-N			8.8	MM				1.6 MM	<u> </u>	
BOTTOM HEA	AD		SA-516-7	70N			8.8	MM				1.6 MM	<u> </u>	
COMMENTS:														
TUBING DATA														
N/A				N/A										
MAWP:	□kPa □l	PSI @ T	ГЕМР:	N/A	□°C	□°F	TEMA	CLASS:	N/	A	TYPE:	TYPE: N/A		
TUBE SIZE: N/A	mm. 🔲 ID	□OD	NUMBE	E R (QTY O	F TUBES):	N/A	GAUGE	(BWG):	N/A	JOIN	T: W	elded	Rolled	
SECTION			MATER	RIAL			NOMIN	AL mm			C	C.A. mm		
N/A			N/A				N/	A				N/A		
N/A			N/A	L			N/	A			N/A			
N/A			N/A				N/	A			N/A			
TRAY/PACKING I	OATA													
TRAY TYPE:	N/A	NUM	BER (# OF	TRAYS):		N/A		PACKIN	G TYPI	E:		N/A		
MATERIAL:	N/A	MAN	UFACTU	JRER:					N/A		-			
COATING/LINING	CLADDII	NG DATA	4											
AREA		1	TYPE				M	ATERIAI	L			YR. AP	PPLIED	
EXTERNAL:		E	POXY					N/A				N/	/A	
INTERNAL:			N/A					N/A				N/	/A	
LINING:			N/A					N/A				N/	/A	
CLADDING:		N/A					N/A				N/	'A		
PRESSURE RELIE	F DEVICE	S DATA			PSV no	t locate	d				□No PS	No PSV		
EQUIP. NO.		SET		C	CAPACIT	Y		CAP	UNITS/O	THER				
603SVVS011	N/	/A	179	3	kPa 🔲	PSI	3451	⊠s	SCFM	□LB/hr	:.	L/min.		
N/A	N/	'A	N/A	A 🔲	kPa 🔲	PSI	N/A		SCFM	□LB/hr	: GAl	L/min.		
N/A	N/	/A	N/A	A 🔲	kPa 🔲	PSI	N/A		SCFM	LB/hr	. GAl	L/min.		

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS (Alternative Form fc ingle Chamber, Completely Shop-Fabricate Code Section As Required by the Provisions of the ASME Code Rules, Section Application 1

AIE, PG. 1 OF 2

Manufactured and certified by THERMO DESIGN PRONINCEPRING LTD, 1224 - 70 AVENUE, EDMONTON, ALBERTA. CANADA TOP 199 Macrificated for Chaevoo Real Ltd. of Tratan Eng. Ltd., 1700, 800 - 6th Avenue SW. Callagor, 49 T2P 303 Loca of Intellation. Chinchage Gas Plant, British Columbia, LSD. C32-195-148-148 Werfood Welfood William Columbia, LSD. C32-195-148-148 Were and the columbia of the Columbi	Manı	ufactured and ce	rtified	by THER	MO DESIGN EN	GINEERING LT	D., 1624 - 70 AV	ENUE, EDMONTO	ON, ALBERTA	CANADA T6P 1	P5	· · · · · · · · · · · · · · · · · · ·
Cocon-unit of Installation Chrischage Gas Plant. British Columbia. LSDC CS2-H9K-H9K-H9 Figure and Subsequent Local Degree Local Deg				***				(Name and address of	manufacturer)			
Type Vertical #1617 N-3899 21 S907-055-024/Rev.1 Type Vertical #1617 N-3899 21 S907-055-024/Rev.1 Type Version Type Type Version Type Type Version Type Type Version	. Man	rectured for (Chauv	co Hes. Li	ı. c/o ⊺aπan Eng	. Lta., 1700, 80	0 - 6th Avenue S (Nar	ne and address of purc	12P 3G3 haser)			5 - 80 - 10 10 - 10 - 10 10 - 10 10 - 10 10 - 10 10
1998 1998	Loca	of installatio اید	n <u>Ch</u>	inchaga Ga	as Plant, British	Columbia, LSD	: C-32-H/94-H-8	Olama and address	-1	· 12		
	. Type	e Vert	ical		#1617		N-8389.21					1998
VESSEL CODE		(Horiz, or	rert. lan	k)	(Mfg's seria	No.)				(Nat'l Bd	. No.) .	
Top 1986										e ASME BOILE		SOME
Shell: SA-51670N O.375' O.0625' Special Service prett 1910 T-9°SS	¥ L.	OOLL OODL. I	110 00	331911, 0017	ourdouon, und u	orminarioriip oo		14100, 00011011 11	., 2		1.55,000,00000	
Shell: SA-516-70N	to		1996 nda (Da	nte\	-	Code Case Nos			Special Service	per UG 120(d)		
Mart Spec No. Goods Mon. The (In) Corr. Allow (In) Sgr V CS:Spot 2	. Shel	l:	SA-51	6-70N				0.0625"				7'-6"S/S
Long (Weblack, Dis. R.T. (Spot or Full El. (Ph) H.T. Temp (F) Time (Ph) Scrib, Weblack, Dath R.T. (Spot, Parilla, Paul) S.A-516-70N		Mat'l		No., Grade)		851 3					V-5	
Sept. Lap. But) Sept. Lap. But Sept. Lap. But Sept. But	. Sear		1									
Cocation (Top. Minimum Corresion Crown Knuckle Elliptical Conical Hemispherical Fist Side to Pressure Buton, Ends Thickness Allowance Radius Radius Radius Radius Radius Apax Angle Radius Diameter Correx or Concave					. I. (Spot or Full)	EII. (%)	H.I. Temp (F)				aruar,	No. of Courses
Correspon Crown Rindum Correspon Crown Rindus Elliptical Corolal Hemispherical Flat Side to Pressure Concreton C	. Hea	ds: (a) Matl.						(b) Matl.				
Bottom, Ends Thickness Allowance Radius	Г	1 /**	1				l Variable	I Final I	Carles	Z BOODS - GRO DO - BOODS - DE TREE		Cide to Deserve
Top Dib Bottom 0.345" 0.0625" 12"Dia. 150/8Bld. Fig.			1 100			250 to 0000 to 000		- 1000		A CONTRACTOR OF THE PARTY OF TH	Water Name	
Bottom Discription Discr	(a)						A CONTRACTOR OF THE PARTY OF TH					1
Top: SA-193-87, 7/8* Diameter, (12) Mailt, Spec. No., Gr., Stax, No. No., Stax, No. No., Stax, No. No., Stax, No.	(b)	Bottom		0.345"	0.0625"			2:1				Concave
Mind, design metal temp. 20 "F at 260 psi at max, temp. 200 psi at max temp. 390 psi. Mind, design metal temp. 20 "F at 260 psi. Hydro, pneu, or comb. test pressure 390 psi. No. Nozzles, inspection and safety valve openings: Furpose Diam. (Incl., Outlet, Drain) No. or Size Type Mart. Thik. Mart. Attached Location N2 1 4" RFWN SA-106-B 15095ch.80 N/A UW-16.1(c) Shell N3 1 4" RFWN SA-106-B 15095ch.80 N/A UW-16.1(c) Shell N3 1 4" RFWN SA-106-B 15095ch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 15095ch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 15095ch.80 N/A UW-16.1(c) Shell 1. Supports: Skirt Yes Lugs Legs Other Attached Welded (Where and how) 12. Remarks: Manufacturer's Partial Data Reports property identified and signed by Commissioned Inspectors have been furnished for the following items of this report: We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 , 19 99 . Date 36 0.3 2.3 Co. Name TheRMO DESIGN ENGINEERING LTD. Signed Section And the State or Province of the component described in this fire pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector on have inspected the component described in this Manufacturer's Data Report on Market 23 and state that, to the best of my knowledge and belief, the employer makes any warranty, expressed or implied, concerning the		removable, bolts	used	(describe	other fastenings)		.1	Top: S	6A-193-B7, 7/8	Diameter, (12)	X120	
Min. design metal temp. -20 *F at 260 psi. Hydro., pneu., or comb. test pressure 390 psi. No. Nozzles, inspection and safety valve openings: Purpose Diem.				**	25. 1				Matl., Spec. No., G			
0. Nozzles, inspection and safety valve openings: Purpose Pur		entre					The state of the s	1996011-190014-190	0.000			
Purpose (Inlet, Outlet, Drain) No. or Size Type Mart. Nom. Reinforcement How Mart. Attached Location No. or Size Type Mart. Thk. Mart. Attached Location No. or Size Type Mart. Thk. Mart. Attached Location No. or Size Type Mart. Thk. Mart. Attached Location No. or Size Type Mart. Thk. Mart. Attached Location No. or Size Type Mart. Thk. Mart. Attached Location No. or Size Type No. or Size			The second of			°Fat26	0 psi. H	ydro., pneu., o	r comb. test pre	essure	390	psi.
(Inlet, Outlet, Drain) No. or Size Type Matt. This. Matt. Attached Location N2 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N3 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Cone N4 1 3" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 50#Sch.80 N/A UW-16.1(0, NO		and s			1		Nom.	Reir	nforcement	How	1
N3 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Cone N4 1 3" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell 1. Supports: Skirt Yes Lugs Legs Other Attached Welded (Yes or no) (No.) (No.) (No.) (Describe) (Where and how) 12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report: (Name of part, item number, Migr's name and identifying stamp) 30 "OD x 7'-6" S/S, Discharge Oil Trap / Coalescer "V-610" Zepacity: 41 Cu Ft. Impact Test: Exempt Per UG-20(f) See Attached U-4 Form CERTIFICATE OF SHOP COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 19 99. Date \$8.03.23 Co. Name THERMO DESIGN ENGINEERING LTD. Signed Garden (Representative) CERTIFICATE OF SHOP INSPECTION THERMO DESIGN ENGINEERING LTD. Signed Garden (Representative) CERTIFICATE OF SHOP INSPECTION THERMO DESIGN ENGINEERING LTD. THERMO DESIGN ENGINEERING LTD. Signed Garden (Representative) CERTIFICATE OF SHOP INSPECTION THERMO DESIGN ENGINEERING LTD. THERMO DESIGN ENGINEERING LTD. The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on May 19 PB 1 and safe that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-1 P	(Inle		No.	100000000000000000000000000000000000000	100		Mat'l.					Location
N4 1 3° RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell N5 1 4° RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell 1. Supports: Skirt Yes Lugs Legs Other Attached (Whore and how) (No.) (No.) (Describe) Attached (Whore and how) 12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report: (Name of part, item number, Migr's name and identifying stamp) 30 "OD x 7'-6" S/S, Discharge Oil Trap / Coalescer "V-610" Tapacity: 41 Cu Ft. Impact Test: Exempt Per UG-20 (f) See Attached U-4 Form CERTIFICATE OF SHOP COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 ,19 99. Date \$\mathref{S-O.3-2.2}\$ Co. Name THERMO DESIGN ENGINEERING LTD. (Manufacturer) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. (Manufacturer) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. At EDMONTON, ALBERTA CANADA T6P 1P5 .1, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on Mayer's Safety Association in Edmonton have inspected the Component described in this manufacturer's Data Report on Mayer's Safety Association this Manufacturer bas constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warrantly, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any p		N2	1	· 4"	RFWN	5	SA-106-B	150#Sch.80		N/A	UW-16.1(c)	Shell
N5 1 4" RFWN SA-106-B 150#Sch.80 N/A UW-16.1(c) Shell 1. Supports: Skirt Yes Lugs Legs Other (No.) (No.) (Describe) Attached Welded (Where and how) 12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report: (Name of part, item number, Migr's name and identifying stamp) 30 "OD x 7'-6" S/S, Discharge Oil Trap / Coalescer "V-610" 2apacity: 41 Cu Ft. Impact Test: Exempt Per UG-20(f) See Attached U-4 Form CERTIFICATE OF SHOP COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22, 19 99. Date \$\mathref{98} \cdot 0.3 \cdot 2.2 \text{ Co. Name} THERMO DESIGN ENGINEERING LTD. (Manufacturer) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. (Representative) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. (Representative) CERTIFICATE OF SHOP INSPECTION AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on May Lings 2, 19 98 and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind activer's Data Report. Furthermore, neither the Inspection or his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind activer's Data Report. Furthermore, neither the Inspection.		N3	1	4"	RFWN		SA-106-B			N/A	UW-16.1(c)	Cone
1. Supports: Skirt Yes Lugs Legs Other (No.) (Representativ		N4	+	7						N/A		
(Yes or no) (No.) (No.) (Describe) (Where and how) 12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report: (Name of part, item number, Migr's name and identifying stamp) 30 "OD x 7'-6" S/S, Discharge Oil Trap / Coalescer "V-610" Capacity: 41 Cu Ft. Impact Test: Exempt Per UG-20(f) See Attached U-4 Form CERTIFICATE OF SHOP COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 , 19 99. Date 36.0.3.2.3 Co. Name THERMO DESIGN ENGINEERING LTD. Signed George August 22 , 19 99. Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5 . I, the undersigned, holding a valid commission issued by The National Board of Boiter and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer shall be liable in any manner for any personal injury or properly damage or a loss of any kind arising from or connected with this inspection. D-** 9 R ~ 3 ~ 2.3 Signed A Afaixa Commissions Signed Commissions Signe		N5	1	4"	RFWN	8	SA-106-B	150#Sch.80		N/A	UW-16.1(c)	Shell
Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report: (Name of part, item number, Migr's name and identifying stamp)	1. Su	pports: Skirt			Lugs			Other		Attach	The second secon	
(Name of part, item number, Migr's name and identifying stamp) 30 "OD x 7'-6" S/S, Discharge Oil Trap / Coalescer "V-610" Capacity: 41 Cu Ft. Impact Test: Exempt Per UG-20(f) See Attached U-4 Form CERTIFICATE OF SHOP COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 ,19 99. Date 98.03.23 Co. Name THERMO DESIGN ENGINEERING LTD. (Manufacturer) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association AB and employed by Alberta Boilers' Safety Association The Aberta Boilers' Safety Association AB and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither	12 Re	marks: Manufac	turori		ita Renorts prope			missioned Inspect		furnished for the f		
CERTIFICATE OF SHOP COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 , 19 99 . Date \$\int_{0.03.23}\$ Co. Name THERMO DESIGN ENGINEERING LTD. Signed (Representative) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5 . I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of the component described in this Manufacturer's Data Report on Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-** 98-3-23 Signed CAAAAA Commissions SIGNE ACCOMPLIANCE Commissions 39 R	12.110	marks. Manarac	ituror c	o i amai be	на пороно ргор	my lacrillica an	a digited by Cont	пполопоа паросп	310 11470 50011	raminoned for the t	onoming homo c	a tino roponi.
CERTIFICATE OF SHOP COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 , 19 99 . Date \$\sumequal 0.000 \cdot 0.000 \text{ Name} \text{ THERMO DESIGN ENGINEERING LTD. } Signed \$\sumequal 0.000 Signed Under the component described in this Manufacturer's Data Report on Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5 . I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of the component described in this Manufacturer's Data Report on Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D				51 1	0'1 5	. 8		E	g stamp)			
CERTIFICATE OF SHOP COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 , 19 99 . Date \$\mathref{SHOP COMPLIANCE}\$ THERMO DESIGN ENGINEERING LTD. (Manulacturer) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5 . I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of the component described in this Manufacturer's Data Report on May 1, 19 98 , and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-** 98 - 3 - 23 Signed August 2 Commissions 39 R					arge Ull T	rap / Coa.	rescer "V-6	210.				
CERTIFICATE OF SHOP COMPLIANCE We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 , 19 99 . Date SB-03-23 Co. Name THERMO DESIGN ENGINEERING LTD. Signed Clearly (Representative) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5 . I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on May 23 , 19 9B , and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-198-3-23 Signed C Affacta					UG-20(f)			See	Attached	U-4 Form		
We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 , 19 99 . Date \$\frac{98.03.23}{2}\$ Co. Name THERMO DESIGN ENGINEERING LTD. Signed Central Community (Representative) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5 I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on March 23, 19 98, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-**OPR-3-23 Signed Community OF Property damage or a loss of any kind arising from or connected with this inspection.		- 1.1.				CE	DTIEICATE OF S	HOB COMBI IVA	CE .			
the ASMÉ Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 22,145 expires August 22 , 19 99 . Date \$\script{SC-3-23}\$ Co. Name THERMO DESIGN ENGINEERING LTD. Signed Belief (Representative) CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5 . I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on March 23 , 19 98 , and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-198-3-23 Signed L Afascal	We	certify that the	stater	nents mad	de in this report	0.000.000.0				n, and workmans	hip of this ves	sel conform to
CERTIFICATE OF SHOP INSPECTION Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5 I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on March 23, 19 98, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-198-3-23 Signed Afactal Commissions 39R												
Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5 I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on March 23, 19 98, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-198-3-23 Signed Afactal Commissions 39R	Date	98.03.23	5 (Co. Name		THERMO D	ESIGN ENGINE	ERING LTD.		Signed 3	lela	re
Vessel constructed by THERMO DESIGN ENGINEERING LTD. at EDMONTON, ALBERTA CANADA T6P 1P5. I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on March 23, 19 98, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D- 98-3-23 Signed C Harran											(Representat	tive)
I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on March 23, 19 9B, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-198-3-23 Signed Character Commissions 39R					THED					EDMONTON AL	DEDTA CANA	DA TOD 1DE
AB and employed by Alberta Boilers' Safety Association in Edmonton have inspected the component described in this Manufacturer's Data Report on March 23, 19 98, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-198-3-23 Signed Afascal Commissions 39R				ng a valid								
the component described in this Manufacturer's Data Report on March 23, 1998, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-198-3-23 Signed L Harria Commissions 39R		· · · · · · · · · · · · · · · · · · ·				150						58 52 31 39
Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-198-3-23 Signed Characa Commissions 39R	the								R , and	state that, to the t	est of my know	ledge and belief, the
nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. D-198-3-23 Signed Language Commissions 39R	Man	ufacturer has c	onstru	cted this	pressure vessel	in accordance v	vith ASME Code,	Section VIII, Divis	sion 1. By sig	ning this certificat	e neither the In	spector nor his
D- 98-3-23 Signed L'Assaid Commissions 39R												
United Signed A Phayer Commissions 5910 (Nat'l Board (incl. endorsements) Slate. Prov. and No.)		200			manner for any	personal injury	or property dama	Ti and the second			with this inspecti	on.
	D	98-3-2	23_	Signed _	Lata	Authorized Ins	nector)	Com	missions _		endorsements) State	e. Prov. and No.1


FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET ovisions of the ASME Code Rules, Sectio: I, Division 1

As Required by th

CTC, PG. 2 OF 2

Manufactured and certified	by THEF	RMO DE	SIGN ENGI	NEERING LT	D., 1624 - 70 AVENU	E, EDMONTON, A	ALBERTA CANAD	A T6P 1P5	
Manufactured for Cha	iuvco Res. L	td. c/o	Tartan Eng.	Ltd., 1700, 8					
Manufactured and certified by THERMO DESIGN ENGINEERING LTD., 1824-70 AVENUE, EDMONTON, ALBERTA CANADA TSP IPS Miner and states of Municipated									
Man-**r-dued for Chau-uco Res. Ltd. clo Tarlan Eng. Ltd., 1700, 800 - 5th Avarus S.W. Calaya, AB 179 3G3 Name and address of Pentassa)									
Man*+-dued for Chairveo Fees List of Darlam Eng. List., 1700, 800 - 801 Avenue S.M., Calagna, A8 1787 9G3 Pillam and address of Perchasin									
		ere)						V300 - 200 -	rial No.)
		= !	9	097-0850-20	- 10 Table 1	253 2 .			
Manufactured for		(Nat'l.	Bd. No.)	(Year built)				
Data Report	1887				is strandation is according	We have the second section of the section of the second section of the section of th			
- Nozzles									
		2							
	C3	11		110000000000000000000000000000000000000		The state of the s			
		1		CPLG		6000#			
	C5A-C	3		CPLG					
	C6A/B	2	1/2"	CPLG		6000#			
was a second of the second of	C7A/B	2			SA-105		- "		
	C8	1	3/4"	CPLG	SA-105	6000#	N/A	UW-16.1(c)	Shell
- Pemarks	Pegist	ered	Drawing	No - 90	37-0220-205/R	ew 2 For Al	lberta Regist	ration	
- Remarks	Regise	crca	Drawing						21 10 07000
					37 0030 201710				
	DCII. O	- D:-							
	PSV: U	n Pig	oing	*					
									w
					232 - 1100 1170000				
				102 kg 195				T-1121111	
					character and				sacravitor
							17	29	
									
						2007-2008			
	300				74.1117.717.00				
		0.0000000000000000000000000000000000000							
		-	32.392.48			100			10 3 20 3
									· · · · · · · · · · · · · · · · · · ·
	8 								
7 - 27 - 27 - 27 - 27 - 27 - 27 - 27 -								-	Acr 1
	7 <u></u>								
				415 1004		***			
				-	*				
	3								200000 - 200000 AND
	-								
						T. V. T. W. T. W. C.	- 11111111	All controls	
	*						-1-0-1205200		
	-	760)	35			=	
									- 1- 10 - 10 - 10 - 10 - 10 - 10 - 10 -
						•••	·		
	-								ERA
ertificate of Authorization:	Туре		l	J	No.	22,145	Expires	August 2	2 , 19
	Nama -		THE	EDMO DESIG	EN ENGINEERING LT	.u.	Signed /	R'E	
98.03.23			ITE			υ. ————————————————————————————————————	Signed C	Jean c (Represe	olaliya)
	•	0	11.	(M	ianulaciurer)	0	200	(Heprese	nauve)
18-3-23	Name	05	TAJa	4		Commission	39 R.	nel andore	Denuines and No. 1
T007			// (Au	thorized Inspecto	11)		(Nat'l Board (ir	ncl. endorsements) State, F	rovince and No.)

IRVEST TESTING INC.



P.E. No. V-610 Serial No. 1617 Prov. Reg. No. A C.R.N. N8389.21 MFR. THERMO DESIGN Code/Div. Para Code Stamp U Yr. Blt. 1998 Yr. Inst. Size 30'ø x 7'6" Service PWHT Nominal Thickness & Material Repairs Repairs Reason Head: 150# FLG. Mat'l: SA 105 N C.A.: .06251" Reason Head: .345" (8.8mm) SA 516 70N Reason Reason
MFR. THERMO DESIGN Code/Div. Para Code Stamp U Yr. Blt. 1998 Yr. Inst. Size 30'ø x 7'6" Service PWHT Nominal Thickness & Material Head: 150# FLG. Mat'l: SA 105 N C.A.: .06251" Reason
Yr. Blt. 1998 Yr. Inst. Size 30'ø x 7'6" Service PWHT PWHT Nominal Thickness & Material Head: 150# FLG. Mat'l: SA 105 N C.A.: .06251" Reason
Repairs Repairs Regairs Reason Reason Repairs Reason Reason
Head: 150# FLG. Mat'l: SA 105 N C.A.: .06251" Reason
745 (00)
Head:345" (8.8mm) SA 516 70N Regson
Shell:375" (9.5mm)
Shell: PIONEER NATURAL RESOURCES CANADA INC.
Chan Hd: CHINCHAGA GAS PLANT
Chan Sh: LSD C-32-H / 94-H-8
Boot Hd:
Boot Sh:
MAWP Shell Side @ Temp
MAWP Tube Side @ Temp DISCHARGE OIL TRAP / COALESSER
COMMENTS: TECH.: J.O. REV.DATE: DWG DATE: 99/08
FILENAME: PIONEER\C4-L16\L16~057.DWG CAD: WO REVISION: DRAWING: 057

PIONEER NATURAL RESC. RCES CANADA INC. CHINCHAGA GAS PLANT

Short Term Rate (mm/yr) LongTerm Rate (mm/yr)

:

RIVEST TESTING INC.

Item Desc.: C-32-H/94-H-8 / DISCHARGE OIL TRAP / COALESCER V-610 Ser. No.: 1617 Prov. Reg.: N/A Equip. No.: Point No.: 057-05 Pt.Desc.: TRANS.SHELL Good For Continued Service: YES Nominal: 9.500 Mths. Rem. To Min. Nom: Additional Assessment Of Data: YES 1.600 Min. Cal. Wall Thk .: Corr. Allowance: Suggested Max Insp. Interval In Mths.: 12 7.900 Min. Nominal: Survey Dates: 1999-12 10.000 Data Readings 1 2 9.900 3 9.900 4 9.900 5 9.900 6 9.800 Data Evaluation 9.800 Lowest Reading 9.867 Average - Low 3 Thk.Remaining Above Min. 1.900 Indv. Short Term Rate (mm/yr) Short Term Rate (mm/yr) LongTerm Rate (mm/yr) Point No.: 057-10 Pt.Desc.: TOP SHELL Good For Continued Service: YES 9.500 Nominal: Mths. Rem. To Min. Nom: Additional Assessment Of Data: YES Corr. Allowance: 1.600 Min. Cal. Wall Thk .: Min. Nominal: 7.900 Suggested Max Insp. Interval In Mths.: 12 Survey Dates: 1999-12 **Data Readings** 1 10.000 2 9.900 3 9.900 4 10.000 5 10.000 6 9.900 **Data Evaluation** 9.900 Lowest Reading : 9.900 Average - Low 3 Thk.Remaining Above Min. 2.000 Indv. Short Term Rate (mm/yr) :

PIONEER NATURAL RESURCES CANADA INC. CHINCHAGA GAS PLANT


Indv. Short Term Rate (mm/yr)

Short Term Rate (mm/yr) LongTerm Rate (mm/yr) :

:

RIVEST TESTING INC.

C-32-H/94-H-8 / DISCHARGE OIL TRAP / COALESCER Item Desc.: V-610 Ser. No.: 1617 Prov. Reg.: N/A Equip. No.: Point No.: 057-15 Pt.Desc.: BTM.SHELL 9.500 Mths. Rem. To Min. Nom: Good For Continued Service: YES Nominal: Additional Assessment Of Data: YES Corr. Allowance: 1.600 Min. Cal. Wall Thk .: Suggested Max Insp. Interval In Mths.: 12 Min. Nominal: 7.900 1999-12 Survey Dates: **Data Readings** 1 9.800 2 9.800 3 9.700 4 9.800 5 9.700 6 9.700 Data Evaluation Lowest Reading : 9.700 9.700 Average - Low 3 • Thk.Remaining Above Min. 1.800 Indv. Short Term Rate (mm/yr) Short Term Rate (mm/yr) LongTerm Rate (mm/yr) Point No.: 057-20 Pt.Desc.: BTM.HEAD Good For Continued Service: YES 8.800 Nominal: Mths. Rem. To Min. Nom: Corr. Allowance: 1.600 Min. Cal. Wall Thk .: Additional Assessment Of Data: YES Suggested Max Insp. Interval In Mths.: Min. Nominal: 7.200 Survey Dates: 1999-12 **Data Readings** 1 9.800 2 9.700 3 9.600 4 9.700 5 9.700 6 9.600 **Data Evaluation** Lowest Reading : 9.600 Average - Low 3 9.633 : Thk.Remaining Above Min. 2.400





integrity les	sting vices
P.E. No.: <u>N/S</u>	_ Yr. Blt.: <u>1998</u>
OIP# <u>603</u> VS011	
 Serial No.: <u>1617</u>	Size: <u>3048mm x 9144mm</u>
P.R.N. (A) <u>N/S</u>	Service: SWEET
C.R.N.: <u>N838</u> 9.21	PWHT: NO
Code/Div.: ASME VIII DIV. 1	_ RT: <u>2</u>
Para: <u>N/S</u>	_ Insulated: NO
C. Stamp: UW	_ N.B. No: <u>N/S</u>
Manufacturer: THERMO ENG.	
Design & Materials Data	
HEAD Material: SA-105-N/SA-516-7	SHELL
· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·
Nom.: <u>8.8mm</u> C.A.: <u>1.6mm</u>	
BOOT HEAD Material:	
Nom.:	
C.A.:	Nom.: C.A.:
	CHANNEL SHELL
Material:	
Nom.:	
C.A.:	
MAWP Shell Side: 1793 KPA	
MAWP Tube Side:	
	· -
CLIENT	
TAQA 1	NORTH
FACILITY	
CHINCHAGA	CAS PLANT
CHINCHAGA	OAS I DAINI
LSD C-032-F	H/094-H-08

ITEM

DISCHARGE OIL TRAP/COALESCER

BY: M.T. DATE: 2008/04 DWG.# 021



FACILITY: CHINCHAGA GAS PLANT MANUFACTURER: THERMO DESIGN ENGINEER

LSD: C-032-H/094-H-08 DESIGN PRESSURE: 1793 kPa / 260 psi ITEM DESC.: DISCHARGE OIL TRAP/COALESCER 93 C 199 F DESIGN TEMP.:

EQUIP / OIP#: 603VS011 RECOMMENDED NEXT INSP. DATE: 04/2013 PROV. REG. #: N/S RECOMMENDED RETIREMENT DATE: 12/2275 SERIAL #:

REM. LIFE (from last survey 04/2008):

267.70 yrs.

CRN.: TOTAL CAUTION / ACTION TML: N8389.21 0

Item # (021)

TML No.: 2 **TOP HD T-B 150 #**

1617

DATE BUILT: 01/1998 AVERAGE THICKNESS MEASURED: 10.02 mm. MATERIAL: MINIMUM THICKNESS MEASURED: 9.90 mm. SA105-N

Pts.	Nom. Thick.	Corr. Allow.	Min. Thick.	B/L Survey Date mm/yyyy	B/L Survey	Prev. Survey Date mm/yyyy	Prev. Survey	Last Survey Date mm/yyyy	Last Survey	Short Term Rate	Long Term Rate	TML Insp. Due	TML Retire. Date	Action/Caution Required Item
2.01	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	10.10	0.000	0.000	04/2013	12/2974	NO
2.02	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	10.10	0.000	0.000	04/2013	12/2974	NO
2.03	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	10.00	0.000	0.000	04/2013	08/2941	NO
2.04	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	9.90	0.000	0.000	04/2013	04/2908	NO
2.05	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	9.90	0.000	0.000	04/2013	04/2908	NO
2.06	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	10.10	0.000	0.000	04/2013	12/2974	NO

TML No.: 4 **TOP SH T-B 150 #**

DATE BUILT: 01/1998 AVERAGE THICKNESS MEASURED: 10.03 mm. MINIMUM THICKNESS MEASURED: 9.90 mm. MATERIAL: SA516-70

1417 1 1	LICIT IL.	SAS	10-70		WINNIOW THICKNESS WEASOREE							, o mm.		
Pts.	Nom. Thick.	Corr. Allow.	Min. Thick.	B/L Survey Date mm/yyyy	B/L Survey	Prev. Survey Date mm/yyyy	Prev. Survey	Last Survey Date mm/yyyy	Last Survey	Short Term Rate	Long Term Rate	TML Insp. Due	TML Retire. Date	Action/Caution Required Item
4.01	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	10.00	0.000	0.000	04/2013	04/2708	NO
4.02	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	10.00	0.000	0.000	04/2013	04/2708	NO
4.03	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	9.90	0.000	0.000	04/2013	12/2674	NO
4.04	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	10.10	0.000	0.000	04/2013	08/2741	NO
4.05	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	10.10	0.000	0.000	04/2013	08/2741	NO
4.06	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	10.10	0.000	0.000	04/2013	08/2741	NO



FACILITY: CHINCHAGA GAS PLANT MANUFACTURER: THERMO DESIGN ENGINEER

LSD: C-032-H/094-H-08 DESIGN PRESSURE: 1793 kPa / 260 psi ITEM DESC.: DISCHARGE OIL TRAP/COALESCER DESIGN TEMP.: 93 C / 199 F

EQUIP / OIP#: 603VS011

PROV. REG. #: N/S

BESIGN TEME: 73 C / 1991

RECOMMENDED NEXT INSP. DATE: 04/2013

RECOMMENDED RETIREMENT DATE: 12/2275

 SERIAL #:
 1617
 REM. LIFE (from last survey 04/2008):
 267.70 yrs.

 CRN.:
 N8389.21
 TOTAL CAUTION / ACTION TML:
 0

Item # (021)

TML No.: 6 BTM SH T-B 150 #

DATE BUILT: 01/1998 AVERAGE THICKNESS MEASURED: 9.80 mm. MATERIAL: \$A516-70 MINIMUM THICKNESS MEASURED: 9.60 mm.

Pts.	Nom. Thick.	Corr. Allow.	Min. Thick.	B/L Survey Date mm/yyyy	B/L Survey	Prev. Survey Date mm/yyyy	Prev. Survey	Last Survey Date mm/yyyy	Last Survey	Short Term Rate	Long Term Rate	TML Insp. Due	TML Retire. Date	Action/Caution Required Item	
6.01	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	9.60	0.000	0.000	04/2013	12/2574	NO	*
6.02	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	9.70	0.000	0.000	04/2013	04/2608	NO	*
6.03	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	9.90	0.000	0.000	04/2013	12/2674	NO	
6.04	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	9.90	0.000	0.000	04/2013	12/2674	NO	
6.05	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	9.90	0.000	0.000	04/2013	12/2674	NO	
6.06	9.50	1.60	7.90	01/1998	9.50	N/A	N/A	04/2008	9.80	0.000	0.000	04/2013	08/2641	NO	

TML No.: 8 BTM HD T-B 150 #

DATE BUILT: 01/1998 AVERAGE THICKNESS MEASURED: 9.72 mm.
MATERIAL: SA516-70 MINIMUM THICKNESS MEASURED: 9.60 mm.

1417 1 1	DIGIT IL.	SAS	10-70			1411141	1410141 11	IICIN ILD	O IVILII	CILLD.	· · ·			
Pts.	Nom. Thick.	Corr. Allow.	Min. Thick.	B/L Survey Date mm/yyyy	B/L Survey	Prev. Survey Date mm/yyyy	Prev. Survey	Last Survey Date mm/yyyy	Last Survey	Short Term Rate	Long Term Rate	TML Insp. Due	TML Retire. Date	Action/Caution Required Item
8.01	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	9.70	0.000	0.000	04/2013	08/2841	NO
8.02	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	9.70	0.000	0.000	04/2013	08/2841	NO
8.03	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	9.70	0.000	0.000	04/2013	08/2841	NO
8.04	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	9.80	0.000	0.000	04/2013	12/2874	NO
8.05	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	9.80	0.000	0.000	04/2013	12/2874	NO
8.06	8.80	1.60	7.20	01/1998	8.80	N/A	N/A	04/2008	9.60	0.000	0.000	04/2013	04/2808	NO



FACILITY: CHINCHAGA GAS PLANT MANUFACTURER: THERMO DESIGN ENGINEER

LSD: C-032-H/094-H-08 DESIGN PRESSURE: 1793 kPa / 260 psi ITEM DESC.: DISCHARGE OIL TRAP/COALESCER DESIGN TEMP.: 93 C / 199 F

EQUIP / OIP#: 603VS011

PROV. REG. #: N/S

RECOMMENDED NEXT INSP. DATE: 04/2013

RECOMMENDED RETIREMENT DATE: 12/2275

 SERIAL #:
 1617
 REM. LIFE (from last survey 04/2008):
 267.70 yrs.

 CRN.:
 N8389.21
 TOTAL CAUTION / ACTION TML:
 0

Item # (021)

TML No.: 10 4"90L N-E 150 #

DATE BUILT: 01/1998 AVERAGE THICKNESS MEASURED: 6.00 mm. MATERIAL: MINIMUM THICKNESS MEASURED: 5.80 mm.

Pts.	Nom. Thick.	Corr. Allow.	Min. Thick.	B/L Survey Date mm/yyyy	B/L Survey	Prev. Survey Date mm/yyyy	Prev. Survey	Last Survey Date mm/yyyy	Last Survey	Short Term Rate	Long Term Rate	TML Insp. Due	TML Retire. Date	Action/Caution Required Item	
10.01	6.00	0.70	5.30	01/1998	6.00	N/A	N/A	04/2008	6.50	0.000	0.000	04/2013	04/2408	NO	*
10.02	6.00	0.70	5.30	01/1998	6.00	N/A	N/A	04/2008	6.00	0.000	0.000	04/2013	08/2241	NO	*
10.03	6.00	0.70	5.30	01/1998	6.00	N/A	N/A	04/2008	5.80	0.000	0.020	04/2013	11/2032	NO	*
10.04	6.00	0.70	5.30	01/1998	6.00	N/A	N/A	04/2008	6.00	0.000	0.000	04/2013	08/2241	NO	*
10.05	6.00	0.70	5.30	01/1998	6.00	N/A	N/A	04/2008	5.90	0.000	0.010	04/2013	04/2067	NO	*
10.06	6.00	0.70	5.30	01/1998	6.00	N/A	N/A	04/2008	5.80	0.000	0.020	04/2013	11/2032	NO	*



DETAIL VESSEL AND PIPING INSPECTION REPORT

(Imperial)

GENERAL PRESSURE VESSEL INFORMATION

Company:	Pioneer Natural Resources Canada Inc.		LSD: BC C-32-H/94-H	H-8			
Area/Facility:	Chinchaga Gas Plant		Inspection Date 06-Feb-02	Interval: 2 yrs			
Vessel Name:	Discharge Oil Trap Coalescer		A No: BC	MTL No: VSL189			
Internal Coating Type:		Next External: 2/6/2003	Next Internal: Feb, 2004				
Vessel Orientation: Vertical		Internal Coating Lining: 0					
Vessel Type:	Type: Vertical Vessei		Fluid Type:				
Tag No:	V-610		Serial Number: 1617				
Separator Type:			Business Unit:				
Direct Fired Vessel:	N/A Fired T	ube:	Cost Centre:				
Current Status:	In Service	20.00	Flame Arrester Date Required:	Date			
Thermal Insulation:	No	**************************************	Asbestos: No				

PRESSURE VESSEL NAMEPLATE INFORMATION

MTL Number:	VSL189	Volume:	41.000 F3	CRN Nu	mber:	N-838	9-21		Reg	istered:	Yes
Serial Number:	1617			Size:	30.000) in O.I).	х	7 ft	6 in	Seam to Seam
Drawing Number:	9097-0850-204			P&IDN	lumber:						
0	CA 546 70N			Bottom		She	ll Thi	ckness:		0.375	In
Shell Material: SA-516-70N				Тор		She	ll Thi	ckness:		0.375	In
DA 540 70M		Bottom		Hea	d Thi	ckness:		0.345	In		
Head Material:	ad Material: SA-516-70N		Тор		Head Thickness:			0.345	ln		
Tube Material: Tube Size(OD):		**************************************	In	TubeThickness:				In			
Tubesheet Material:		Tubesheet Thickness:			1n						
Channel Material:	Channel Material: Channel Type:			Channel Thickness:			În				
Design Programs	Shell:	Shell: 260 psi Tube: psi		Operating Pressure:			Shell:			psi	
Design Pressure:	Tube:							Tube:			psi
Di T	Shell:	200 F		Operating Temperature:			Shell:			F	
Design Temperature:	Tube:	F		Орегии	y rompo	rataro.		Tube:			F
RT (XRay):	RT (XRay): RT2		Heat Tre	atment:	No						
Code Parameters:		Joint Efficiency:									
Manufacturer:	Thermo Design Engineering		Year Bui	lt:	1998					1000	
Corrosion Allowance:	0.063			Manway:	- 1-0.5	Yes					

By: S.C.(Stephen) Droeske

INSPECTION GROUP INC.

DETAIL VESSEL AND PIPING INSPECTION REPORT

(Imperial)

GENERAL PRESSURE VESSEL INFORMATION

Company:	Pioneer Natural Resources Canada Inc.	LSD: BC	C-32-H/94-	H-8
Area/Facility:	Chinchaga Gas Plant	Inspection Date	06-Feb-02	Interval: 2 yrs
Vessel Name:	Discharge Oil Trap Coalescer	A No: BC		MTL No: VSL189

VESSEL SHELL / HEADS / PIPING

External / Instrumentation Condition

The external surface of this vessel was noted in good condition. The vessel paint was good with no visible signs of external corrosion but there is a minor gasket leak on top manway. All welds were intact and there were no signs of deterioration or cracking. The associated instrumentation appeared to be in good working order.

Internal Condition

No internal access

Nozzle Condition

The nozzles were painted with no leaks on shell nozzles or couplings. No visible evidence of external corrosion was noted during this inspection.

Flange Condition

The flanges are bolted properly and there was no visible evidence of leakage. The associated gaskets and bolting were in place and appeared to be tight.

Internal Piping

External Piping

Not Applicable

The piping was painted with no evidence of corrosion. The associated pressure welds were intact and revealed no signs of deterioration or visible cracking.

Pipe Support Condition

All of the supports are in place, secure and functioning properly.

The associated bolting and gaskets were in place and appeared to be tight. **Bolting Condition**

Firetube Condition

Not Applicable

Demister Pad Condition

Not Applicable

Anode Condition

Not Applicable

Vessel Support

The skid base, skirt, baseplate and 8 bolts were all noted in good condition.

By: S.C.(Stephen) Droeske

Equipment Inspection Report - MTL Inspection Group Inc

Survey By

Test Results

INSPECTION GROUP INC.

MTL Testing Inc.

By: S.C.(Stephen) Droeske

DETAIL VESSEL AND PIPING INSPECTION REPORT

(Imperial)

GENERAL PRESSURE VESSEL INFORMATION

Company:	Pioneer Natural Resources Canada Inc.	LSD: BC C	C-32-H/94-H-8
Area/Facility:	Chinchaga Gas Plant	Inspection Date 06	6-Feb-02 Interval: 2 yrs
Vessel Name:	Discharge Oil Trap Coalescer	A No: BC	MTL No: VSL189

VESSEL COATING INSPECTION Type of Coating Coating Manufactuer and Type Location Coating Condition VESSEL NONDESTRUCTIVE TESTING NDE Type **UT Survey** Location of Test Qualifications Rivest Contractors Name Next UT Date: Feb 3, 2004 Feb 3, 2002 Interval 2 yrs Last UT Survey Date

VESSEL STATUS No Repairs Required? Suitable for Further Service? Yes Repairs Completed? Owners Representative Repairs Completed By Owners Date Repair Date

Recommendations	Consider performing internal inspection next turnaround in 3 years Next PSV servicing in 3 years Repeat UT Survey in 3 years Tighten unions on gauge glass bottle and top access cover
Details of Repairs	

DETAIL VESSEL AND PIPING INSPECTION REPORT

(Imperial)

GENERAL PRESSURE VESSEL INFORMATION

Company:	Pioneer Natural Resources Canada Inc.	LSD: BC	C-32-H/94-H	H-8
Area/Facility:	Chinchaga Gas Plant	Inspection Date	06-Feb-02	Interval: 2 yrs
Vessel Name:	Discharge Oil Trap Coalescer	A No: BC		MTL No: VSL189

	Wall Hat St.		PSV D	ATA		STATE AND	
Side	Set Pressure psi	CRN Number	Manufacturer PSV Number	Model Serial Number	Capacity	Size Inches	Set Date
Shellside	250	W-15675	Farris PNR6102	2850 CE-1699-5-R4	3451 SCFM	1.5 ×	Dec/1999

	CURRENT VESSEL PROCESS CONDITIONS	AND STREET,
Lube Oil		

Name (Printed)	Signature	Date
Visual Inspector Paul Gorman	APISTO Shush or and Gornan	February 06, 2002
QA Supervisor: (Chief Inspector)		
QA Administrator:		
ABSA Inspector:		



INSPECTION REPORT

EQUIPMENT NO: 603V50TT			Page of
FACILITY: Chinchaga Gas Plant		PROV. REG. N0:	
EQUIPMENT NAME: Discharge Oil Trap / Coalescer		TAG NO:	
SIZE: 762mm OD x	L/H 2286mm	MAWP: 1793	kPa @ 93/-29 °C
LSD : C-032-H / 094-H-08		MANWAY 🛛 YES	□ NO
SERVICE:	FLUID: Oil		
☐ SOUR ☑ SWEET ☐ CRYOGENIC			
SCOPE OF INSPECTION TYPE OF INS PRECOMMISSIONING AE MT	SPECTION:	CLEANING: GOOD	ACCESS: □ FULL
		☐ FAIR	☐ PARTIAL
☐ REINSPECTION ☐ LT ☐ PT	⊠ VT	☐ INADEQUATE	
☐ OTHER			
	SKETCHES AS NEE	DED (TURN OVER FOR SKETCH)	
OBSERVATIONS: EXTERNAL			
1. LADDERS, STAIRWAYS, PLATFORMS AND WALKWA	AYS □ N/A		
2. FOUNDATIONS AND SUPPORTS Skirt / Piling			
3. NOZZLES ⊠			
4. GROUNDING CONNECTIONS ☑			
5. PROTECTIVE COATINGS AND INSULATION Epo	оху		
6. EXTERNAL METAL SURFACES ☐ No			
7. FANS AND OTHER ANCILLARY EQUIPMENT ☐ No			
8. PRESSURE RELIEF DEVICES ⊠			
9. NAME PLATE ⊠			
10. ULTRASONIC INSPECTION SURVEY 🛛			
11. INSPECTION REPORT COMPLETED ☑			
12. NON CONFORMANCE COMPLETED ☐ N/A			
13. OIP LABEL APPLIED ☑			
14. PICTURE ON FILE ⊠			
COMMENTS CHECKED BOX INDICATES ACCEPTANCE			
RECOMMENDATIONS:			
NEGOWINENDATIONS.			
SUITABLE FOR	REMEDIAL	ACTION	
FURTHER SERVICE: ☐ YES ☐ NO	PRIORITY:	☐ HIGH ☐ M	EDIUM LOW
INSPECTION PERFORMED BY: Mark Tomko		DATE OF INSPECTION	07 04 2008 (DD MONTH YYYY)
FOLLOW-UP INSPECTION REQ'D:	☐ YES 🏻	NO BY DATE:	(DD MONTH VVVV)

021



\	
7	NY
	<u>"</u>
A	

Drawing File: PIONEER\L16-057.DWG

P&ID. #	 	
REF. #		

5710	5705
	V-610 PROV.R.#
	5720

			VESSEL D	ATA				
Prov. Reg. No		_ C.R.N. N 8389	.21 P.E.	. NoV-610)	Serial	No. <u>1617</u>	
MFR. THERMO DESIGN		Code/Div		Para			Code Stam	<u>U</u>
Yr. Bit. 1998 Yr. Inst	Size .	30'øX7'6"	Vo	ol.:		Service		PWHT
Nominal Thickness								
Head: <u>150# FLG.</u>	_Mat'l:	SA 105 N	_ C.A.: <u>0.0625"</u>	Repairs				
Head: 8.8mm		SA 516-70N	-	COMMENTS				
Shell: 9.5mm	_	SA 516-70N	_ C.A.:	<u></u>				
Shell:	_		_		N. 1946 M. Augusta			
Chan Hd:			_ C.A.:			RESOURCES	S CANADA I	NC.
Chan Sh:			=	CHINCHAGA				
Gas Boot Hd:			_ C.A.:	LSD C-32	-H /	94-H-8		
Gas Boot Sh.:	-		_	=				
Liq. Boot Hd.:			_ C.A.:	P = = =				production of the second
Liq Boot Sh.:								
MAWP Shell Side	260psi	@ Temp	-20/200°F	DISCHARGE	OILT	RAP / COALE	ESSER	
MAWP Tube Side						REV.DATE:		DATE: 02/2002
Table Same Control of Action 19 1				CAD: MKN	/ F	REVISION:	DRAV	VING: 057

Equip No V-610 Serial No 1617 Prov Reg No N/A
Description DISCHARGE OIL TRAP/ COALESSER

057 - 005

TML Description: TRANS. SHEI	T				
T Nominal: 9.5	<i>.</i>				
Corr Allowance: 1.6		Data Readings			
Data Evaluations			Dec-99	ACCUPATION AND SEC	
Data Evatuations		Point 1	10.0	10.0	
Months Remaining to T Min:	999	Point 2	9.9	10.0	
Min Calc'd Wall Thickness:	N/A	Point 3	9.9	10.0	
Thick Remain Above T Min:	2.0	Point 4	9.9	9.9	
Short Term Corr Rate:	N/A	Point 5	9.9	9.9	
Long Term Corr Rate:	N/A	Point 6	9.8	9.9	
Months Remain to LFL:	104	Point 7			
Lowest Value - Last Reading:	9.9	Point 8			
	-	Point 9			
Comment:		Point 10			
		Point 11			
		Point 12			
		Average	9.9	10.0	
		Avg Low 3	9.9	9.9	
		Lowest	9.8	9.9	

057 - 010

					007	UIU
TML Description: TOP SHELL						
An and the street of the second of the secon						
STATE STATE OF THE CONTROL OF THE CO						1
Min Nominal: 7.9						
Corr Allowance: 1.6		Data Readings				
Data Fralentiana			Dec-99	Feb-02		
Data Evaluations		Point 1	10.0	10.1		
Months Remaining to T Min:	999	Point 2	9.9	9.9		
Min Calc'd Wall Thickness:	N/A	Point 3	9.9	9.9		
Thick Remain Above T Min:	2.0 N/A	Point 4	10.0	10.0		
Short Term Corr Rate:		Point 5	10.0	10.0		
Long Term Corr Rate:	N/A	Point 6	9.9	10.0		
Months Remain to LFL:	N/A	Point 7				
Lowest Value - Last Reading:	9.9	Point 8				
		Point 9				
Comment:		Point 10				
		Point 11				
		Point 12				
140		Average	10.0	10.0		
		Avg Low 3	9.9	9.9		
		Lowest	9.9	9.9		

TML Description: BTM. SHELL					
T Nominal: 9.5					
Min Nominal: 7.9					
Corr Allowance: 1.6	i	Data Readings			
	in see	I	Dec-99 I	Feb-02	
Data Evaluations		Point 1	9.8	9.9	
Months Remaining to T Min:	999	Point 2	9.8	9.9	
Min Calc'd Wall Thickness:	N/A	Point 3	9.7	9.8	
Thick Remain Above T Min:	1.9	Point 4	9.8	9.9	
Short Term Corr Rate:	N/A	Point 5	9.7	9.8	
Long Term Corr Rate:	N/A	Point 6	9.7	9.9	
Months Remain to LFL:	78	Point 7			
Lowest Value - Last Reading:	9.8	Point 8			
		Point 9			
Comment:		Point 10			
		Point 11			
		Point 12			
		Average	9.8	9.9	
		Avg Low 3	9.7	9.8	
		Lowest	9.7	9.8	
L		<u> </u>			

057 - 020

TML Description: BTM. HEAD					
T Nominal: 8.8					
Min Nominal: 7.2					
Corr Allowance: 1.6	A.	Data Readings	5		
D. F. I.			Dec-99	Feb-02	
Data Evaluations		Point 1	9.8	9.8	
Months Remaining to T Min:	999	Point 2	9.7	9.8	
Min Calc'd Wall Thickness:	N/A	Point 3	9.6	9.7	
Thick Remain Above T Min:	2.4	Point 4	9.7	9.7	
Short Term Corr Rate:	N/A	Point 5	9.7	9.6	
Long Term Corr Rate:	N/A	Point 6	9.6	9.7	
Months Remain to LFL:	N/A	Point 7			
Lowest Value - Last Reading:	9.6	Point 8			
**************************************		Point 9			
Comment:		Point 10			
		Point 11			
·•		Point 12			
		Average	9.7	9.7	
		Avg Low 3	9.6	9.7	
		Lowest	9.6	9.6	





4253-97 Street, Edmonton AB, T6E 5Y7
Tel.: (780) 417-0340
Fax: (780) 417-0348
www.integrity-testing.com

EQUIPMENT INTERNAL INSPECTION REPORT

Customer:	TAQA North		ITS Job N	S Job No.:		
District:	Northern		Date:		10-Jul-2012	
Facility:	Chinchaga Gas Pla	int	LSD:		C-32-H/94-H-0	8
Equip. Description:	Discharge Oil Trap/Coa	alescer	Serial No	o.: 1617		
Equip./OIP No.:	603VS011		PRN:		Not Stated	
Equip. Type: □Column □Cooler □	Exchanger Furnace Heater Plants	ate Exchanger □Reboile	Other:			
Head (1)	Head (2)	Shell	Boot Shell/Head			
▼ Top □ North □ West	☑ Bottom ☐ South ☐ East	□ Тор □ В	ottom	✓ Not Applicable		
✓ Flat ✓ FLG □ ELL □ ECC	☐ Flat ☐ FLG ☑ ELL ☐ ECC	✓ Good Condition	☐ Good C	Condition		
□ HEMI	☐ HEMI	☐ Internal Corrosio	n	□ Interna	l Corrosion	
☑ Good Condition	✓ Good Condition	☐ Pitting:	(max depth)	☐ Pitting:		(max depth)
☐ Internal Corrosion	☐ Internal Corrosion	☐ Wear/Erosion		□ Wear/E	rosion	
Pitting: (max depth)	Pitting: (max depth)	☐ Cracked		□ Cracke	d	
☐ Wear/Erosion	☐ Wear/Erosion	☐ Blistered		□ Blistere	ed	
□ Cracked	☐ Cracked	□ Scale		□ Scale		
☐ Blistered	☐ Blistered	✓ Coated		□ Coated		
□ Scale	□ Scale	☐ Mechanical Dam	nage	□ Mechai	nical Damage	
		☐ Bulged/ Distorte	d/	☐ Bulged	/ Distorted/	
☐ Mechanical Damage	☐ Mechanical Damage	Deformation		Deformat	ion	
☐ Bulged/ Distorted/ Deformation	☐ Bulged/ Distorted/ Deformation	✓ See Comments	✓ See Comments			
☐ See Comments	☐ See Comments	1				
Channel Head	Internal Welds	Internal Noz	zles		Drum	
✓ Not Applicable	Good Condition Good	✓ Good Condition		□Mud —	Steam	
Good Condition	Poor Quality	☐ Internal Corrosic		✓ Not App		
☐ Internal Corrosion	☐ Internal Corrosion	☐ Pitting:	(max depth)		ondition	
Pitting: (max depth)		☐ Wear/Erosion			Corrosion	
□ Wear/Erosion	☐ Wear/Erosion	☐ Cracked		Pitting:		(max depth)
☐ Cracked	☐ Cracked	□ Scale		□ Wear/E		
□ Blistered	□ Scale	✓ Coated		☐ Cracked		
□ Scale	Coated ■	☐ Plugged		□ Blistere	d	
□ Coated	☐ Mechanical Damage	Poor Welding		□ Scale		
☐ Mechanical Damage	See Comments	Leaking		Coated		
☐ Bulged/ Distorted/		☐ Mechanical Dam	age	□ Mechar	ical Damage	
Deformation ☐ See Comments		See Comments		□ Bulged, Deformati	Distorted/ on	
				See Co	mments	

Report No.: VI-1829-09-EDP



4253-97 Street, Edmonton AB, T6E 5Y7
Tel.: (780) 417-0340
Fax: (780) 417-0348
www.integrity-testing.com

			1		
Internal Protection	Vessel Internals	Heating Coil (A)	Heating Coil (B)		
☑ Not Applicable	✓ Adequate Cleaning	✓ Not Applicable	✓ Not Applicable		
☐ Coating ☐ Lining	□ Vortex	☐ Good Condition	Good Condition		
Good Condition	Breaker(s)/Deflection	☐ Corrosion	☐ Corrosion		
□ Blister(s)	Plate(s) Damage	☐ Pitting: (max depth)	Pitting: (max depth)		
□ Dis-bonded	□ Weir(s)/ Baffle(s)/	☐ Cracked	☐ Cracked		
□ Chipped	Divider(s) Damage	☐ Scaled	☐ Scaled		
☐ Holidays/Cracked	☐ Spray Nozzles Damaged/	□ Worn	□ Worn		
☐ Mechanical Damage	Missing	□ Loose	Loose		
☐ Missing	Down comor Correcion	☐ Poor Installation	Poor Installation		
☐ See Comments	Down-comer Corrosion	☐ See Comments	See Comments		
	☐ See Comments				
	_				
Demister Screen	Refractory	Manway	Trays		
✓ Not Applicable	✓ Not Applicable	□ Not Applicable	✓ Not Applicable		
Good Condition	Good Condition	Good Condition	Good Condition		
□ Dislodged	Cracked (minor)	Coating Damage	□ Collapsed		
□ Broken	☐ Spalling	☐ Internal Corrosion	☐ Distorted		
☐ Missing	☐ Missing	☐ Mechanical Damage	Loose		
☐ Tie-downs Missing	□ Damaged	Seal Face Corrosion	☐ Missing		
☐ Fouling	☐ Cracked (severe)	Pitting: (max depth)	□ Wear		
☐ Corrosion	☐ See Comments	✓ See Comments	☐ Corrosion		
See Comments			□ Poor		
			☐ Valve Caps Missing		
			☐ See Comments		
		715 "			
Tube Sheet	Firetube(s)	Tube Bundle	Tubes		
■ Not Applicable	✓ Not Applicable	✓ Not Applicable	■ Not Applicable		
Good Condition	Good Condition	Good Condition	Good Condition		
□ Corrosion	Corrosion	Corrosion	External Corrrosion		
Pitting: (max depth)	Pitting: (max depth)	Pitting: (max depth)	☐ Internal Corrosion		
☐ Wear/Erosion	☐ Wear/Erosion	☐ Wear/Erosion	Pitting: (max depth)		
☐ Cracked	☐ Cracked	☐ Cracked	☐ Wear/Erosion		
□ Damaged	☐ Scaled	☐ Damaged	□ Cracked		
See Comments	□ Coated	☐ Plugged	☐ Thinning		
	☐ Heat Impinged	□ Scaled	Heat Impinged		
	☐ Burner Misalignment	See Comments	☐ Bulged/Distorted		
	☐ Damaged Supports		Leaking		
	☐ Damaged Guides/ Tracks		☐ See Comments		
	-				
	See Comments				

Report No.: VI-1829-09-EDP

Tel.: (780) 417-0340 Fax: (780) 417-0348 www.integrity-testing.com



Observations:

✓ Vessel in Good Condition

- Based on API 510 Visual Internal Inspection this vessel is fit for service
- The support ring for screen is intact and secure. There are no issues.
- The gasket seal surface on the top head is in good condition. There is no corrosion, erosion or mechanical damage. The tabs on the top head are in good condition.
- The pressure gauge is not within MAWP of vessel. A Found Work sheet was put in place to swap gauges from 603VF009.
- The coating is chipped around the nozzle opening. On the shell wall, there is an approximately $\frac{1}{4}$ " round piece of coating missing alongside the nozzle. There is no corrosion or erosion noted on the shell wall. Bottom head coating has some marks from it being sucked out. There are no issues.
- The filter screen support ring has corrosion as material is missing.

Recommendations:

- Swap the pressure gauge from 603VF008 and both vessels will be within the range of their MAWP.
- Monitor ¼ inch diameter chipping of coating on shell wall and see if it has gotten larger at next outage.
- Replace or repair filter support ring of the filter screen.

Pictures:



Photo 1: Bottom Head and Shell





Photo 3: Top Head



Photo 2: Top Nozzle



Photo 4: Coating Chipped

Report No.: VI-1829-09-EDP



4253-97 Street, Edmonton AB, T6E 5Y7 Tel.: (780) 417-0340 Fax: (780) 417-0348 www.integrity-testing.com

Pictures:



Photo 5: Coating Chipped (2)



Photo 6: Overview



Photo 7: O-Ring Seal and Coating Chipped



Photo 8: Filter Screen



Photo 9: Filter Screen (2)

Additional Comments:

None

Internal Inspection Performed By:

Print Name:

Erwin Pederson

Erwin Pederson Signature:

API 510: 33075 IPV: 000406 PEI Class 2: 154

Report Reviewed:

Certification No.:




RAM# 434016	EQUIP S	STATIC RE	ECORD	JOB#	1-2968
Unique OUP #:	603VS011 Old	OUP #:	LSD:	C-032-H/0	094-H-08
PLANT / FIELD:	Chinchaga Gas Plant	Down Hole I	Location:		RENTAL: No
EQUIPMENT NAME:	Discharge Oil Trap / Coalescer	Unique # of	f Compressor this equipmer	nt is related to:	
VESSEL STATUS: _	Active PRIMARY LO	OCATION:		Vessel Car-Sealed	d Out? No
PHYSICAL LOCATIO	N:			YEAR INSTALLED	D:
SERVICE: Swee	t H ₂ S PR	OCESS FLUID:	Oil Multiphase	CYC	LIC:
MANUFACTURER:	Thermo Design Engineering Ltd.	DWG.#	90970850204 Rev. 1	S N:	1617
PRN	for VESSEL or SHELL		N8389.21	YR. BUIL	T1998
NB:	CODE/DIV.	SME Sec. VIII Div. 1	PARA.	STA	AMPU
SHELL-TANK	RADIOGRAPHY:_	RT2	JOINT EFF. 100%	PW	/HT:
MAWP1793	kPa AT93	°C	MDMT29	°c AT_	kPa
DIA. ID 743.0	mm LENGTH:	mm HE	IGHT: 2286.0 mm	VOLUME:	m ³
SECTION	<u>MATERIAL</u>	ı	NOMINAL THICKNESS	<u>(</u>	C.A.
Shell	SA-516-70N		9.525	mm1	.588 mm
Top Head	SA-105-N			mm	mm
Bottom Head	SA-516-70N		8.763	_ mm 1	.588 mm
				mm	mm
				mm	mm
				mm	mm
Heat Exchangers, Tul Channel, Line Heater			CRN	RADIOGRA	APHY:
MAWP	_ kPa AT °C	MDMT	_{°C} AT	kPa S N:	
CODE/DIV	PARA STA	MP	TUBE/TUBE SHEET	TEMA CI	_ASS
DIA.	mm LENGTH:	mm	TUBE SIZE	mm # of	Tubes
SECTION	MATERIAL		NOMINAL THICKNESS	<u>(</u>	C.A.
				mm	mm
				mm	mm
				mm	mm
TUDING: DDN	CRN	TEMA CLAS	ee TVDE		mm
	a ATc TUBE S				
# of Tubes	MATERIAL		NOMINAL THICKNESS		C.A.
# OF TUDGS	WINTERNAL		NOWINAL THIORIVEOU		mm
COIL: PRN_	CRN	COIL N			
MAWP	kPa AT	∘c TUBE SI	ZE mm	S N:	
# of Tubes	MATERIAL	ı	NOMINAL THICKNESS	<u>(</u>	<u>C.A.</u>
				mm	mm

RAM# 434016	EQUIP S	TATIO	RECOR	JOB# 1-2968			
Unique OUP #:	603VS011 OI	d OUP #:		LSD:	C-032-H/094-H-08		
TANK M/WAY OD FLANGE	DIMENSIONS:	X	mm	OR IF M/WAY IS ROUN	ND, DIA. IS:mm		
TK. HEATED: TYPE C	OF HEAT: T	K. SKIDDI	ED or PORTABI	LE: GAS BLANKET	: DOUBLE WALL:		
TK. CONSTRUCTION:	TANK DYKED:	DYŁ	KE MATERIAL:	Leak Tag#:_			
DYKE LINED: TYPE of	f LINER:	Leak To	est Co.	Leak	k Test Date		
DYKE SHAPE:	mm		Width:	mm	Height:mm		
DYKE VOLUME:	TK. BASE SITTING	ON:		BETWEEN TK. AND BA	ASE:		
TANKS INSIDE DYKE:							
P&ID #:				SHUT DOW	/N:		
OPERATING PRESSURE:	965 _{kPa} OF	ERATING	TEMP	c YEAR PUT	Γ IN SERVICE:		
VESSEL CONNECTIONS:	NPTFLANGE_Yes	LARGES ¹	T CONNECTION	Nm INSPECT	TION PORT: Man Way		
FLANGE ANSI: 150		FLG. FAC	E:	SIZE of INS	PECTION PORT: 406.4 mm		
VESSEL ORIENTATION: _	Vertical TYPE	OF VESS	EL SUPPORT:	Skirt IS B	OTTLE (VB) BLOCKED: No		
TRAY(VT):	# of TRAYS	MAT'L		MFG			
PACKING(VK):	EXT. INSU	ILATED:_			Full or Partially covered?		
			INSULATION	TYPE:	CLADDING:		
TYPE of EXT. INSULATION	: E	XT. INSU	LATION THICK	NESS:mm	CUI Susceptible:		
EXT. COATING:Enamel	Paint INTERN	AL COAT	ING:	INTER. L	INING:		
PRESSURE RELIEF	DATA	1 1					
PSV OUP#	SET PRESSURE	PR	OTECTS - TAN	CODE: SV, SR, ST, S K, SHELL, TUBE (HA or ing coil in line heater), PL	L or ESD HT), HP coil, LP coil, FG coil, L, PP, Channel A or B in HP		
603SVVS011	1793		,	Shell			
		kPa					
		kPa					
		kPa					
		kPa					
		kPa					
		kPa					
		kPa					
		kPa					
		kPa					
		kPa					
		kPa					
		kPa					
ITS PRINT NAME:	Murray Angus MacGregor		ITS SIGNATU	JRE:	leal)		
			DATE: dat	ta collected - yyyy-mmm-dd	2014-Oct-18		







☐ Column ☐ Cooler ☐ Excha	nger 🗆 Furnace 🗀 Heater [Client:, District:, LSD:, Etc.:						
Description:	DISCHARGE OIL TRAP/ C							
P.R.N. No.:	N/S	C.R.N.:	N8389.21			TAQA NORTH		
Equipment No.: OIP	603VS011	N.B. No.:				CHINCHAGA GAS PLANT		
Serial No.:	1617	Other:				C-032-H/094-H-08		
HEAD Material:	SA-105-N/SA-516-70	Nom.:	8.8mm	C.A.:	1.6mm			
HEAD Material:		Nom.:						
SHELL Material:	SA-516-70N	Nom.:	9.5mm	C.A.:	1.6mm			
SHELL Material:		Nom.:				Tech.: A.L.N.	Date: 10/2014	
MAWP Shell Side:	1793 KPA	@Temp.:	93°C/-29°C			ITS Job No.: 1-2968(I)	DWG No.: 021	



FACILITY: CHINCHAGA GAS PLANT MANUFACTURER: THERMO DESIGN ENGINEER

LSD: C-032-H/094-H-08 DESIGN PRESSURE: 1793 kPa / 260 psi ITEM DESC.: DISCHARGE OIL TRAP/COALESCER DESIGN TEMP.: 93 C / 199 F

ITEM DESC.: DISCHARGE OIL TRAP/COALESCER
EQUIP / OIP#: 603VS011

PROV. REG. #: N/S VESSEL CORROSION ALLOWANCE: 1.59 mm

SERIAL #: 1617

CRN.: N8389.21 TOTAL CAUTION / ACTION TML: 2

Item # (021)

COMMENTS:

2014/10 - LIMITED SCANNING DUE TO TEMPERATURE.

TML No.: 2 TOP HD T-B 150 #

DATE E		01/1998 SA105-N				AGE THICK IUM THICK				mm. mm.	
Pts.	Nom. Thick. mm	CA + Steel Mfg.Tol. mm	Nom. -CA -Toll. mm	B/L Survey Thick. mm	Prev. Survey Thick. mm	Last Survey Thick. mm	Short Term CR mm/yr	Long Term CR mm/yr	Rem. Half Life yr	Future UT Reading mm/yy	Action/Caution Required Item
				04/2008		10/2014					
2.01	0.00	0.00	0.00	10.10	N/A	9.80	0.0000	0.0457	100.00	•	NO
2.02	0.00	0.00	0.00	10.10	N/A	9.80	0.0000	0.0457	100.00		NO
2.03	0.00	0.00	0.00	10.00	N/A	9.70	0.0000	0.0457	100.00		NO
2.04	0.00	0.00	0.00	9.90	N/A	9.70	0.0000	0.0305	100.00	•	NO
2.05	0.00	0.00	0.00	9.90	N/A	9.70	0.0000	0.0305	100.00		NO
2.06	0.00	0.00	0.00	10.10	N/A	9.80	0.0000	0.0457	100.00		NO

TML No.: 4	ГОР SH T-B 150 #	ŧ
------------	------------------	---

DATE E		01/1998 SA51670N				AGE THICK UM THICK			,	mm. mm.		
Pts.	Nom. Thick. mm	CA + Steel Mfg.Tol. mm	Nom. -CA -Toll. mm	B/L Survey Thick. mm	Prev. Survey Thick. mm	Last Survey Thick. mm	Short Term CR mm/yr	Long Term CR mm/yr	Rem. Half Life yr	Future UT Reading mm/yy	Action/Caution Required Item	
				01/1998	04/2008	10/2014						
4.01	9.53	1.84	7.69	9.53	10.00	9.90	0.0152	0.0000	72.51		NO	,
4.02	9.53	1.84	7.69	9.53	10.00	9.70	0.0457	0.0000	21.98		NO	*
4.03	9.53	1.84	7.69	9.53	9.90	9.70	0.0305	0.0000	32.97		NO	*
4.04	9.53	1.84	7.69	9.53	10.10	10.10	0.0000	0.0000	100.00		NO	
4.05	9.53	1.84	7.69	9.53	10.10	9.90	0.0305	0.0000	36.26		NO	*
4.06	9.53	1.84	7.69	9.53	10.10	9.80	0.0457	0.0000	23.08		NO	*

If Baseline (B/L) Survey Thickness Measurement was not taken at the time of Manufacture, then Nominal Thickness is used as Baseline Thickness. Minimum Thickness is calculated

 $Design\ Minimum\ Thickness = Nom.\ Thick.\ -\ CA\ -\ Manufacturing\ Steel\ Tolerance.$

Manufacturing Tolerance of pipe and forged fittings is + or -12.5% (May or may not apply dependent upon the Client's Owner-User Integrity Management System).

Manufacturing Tolerance of plate is + or - 0.25mm (0.010") (May or may not apply dependent upon the Client's Owner-User Integrity Management System).

 $^(*) and GREEN \ Represent \ 25\% \ of \ the \ last \ thickness \ readings, \ which \ have \ the \ shortest \ remaining \ half \ life.$



FACILITY: CHINCHAGA GAS PLANT MANUFACTURER: THERMO DESIGN ENGINEER

LSD: C-032-H/094-H-08 DESIGN PRESSURE: 1793 kPa / 260 psi ITEM DESC.: DISCHARGE OIL TRAP/COALESCER DESIGN TEMP.: 93 C / 199 F

EQUIP / OIP#: 603VS011

PROV. REG. #: N/S VESSEL CORROSION ALLOWANCE: 1.59 mm

SERIAL #: 1617

CRN.: N8389.21 TOTAL CAUTION / ACTION TML: 2

Item # (021)

COMMENTS:

2014/10 - LIMITED SCANNING DUE TO TEMPERATURE.

TML No.: 6 BTM SH T-B 150 #

DATE E	BUILT:	01/1998			AVER	AGE THICK	NESS ME	EASURED:	9.78	mm.		
MATER	IAL:	SA51670N			MINIM	IUM THICK	NESS ME	EASURED:	9.70	mm.		
Pts.	Nom. Thick. mm	CA + Steel Mfg.Tol. mm	Nom. -CA -Toll. mm	B/L Survey Thick. mm	Prev. Survey Thick. mm	Last Survey Thick. mm	Short Term CR mm/yr	Long Term CR mm/yr	Rem. Half Life yr	Future UT Reading mm/yy	Action/Cautior Required Item	_
				01/1998	04/2008	10/2014						
6.01	9.53	1.84	7.69	9.53	9.60	9.80	0.0000	0.0000	100.00	•	NO	
6.02	9.53	1.84	7.69	9.53	9.70	9.80	0.0000	0.0000	100.00		NO	
6.03	9.53	1.84	7.69	9.53	9.90	9.70	0.0305	0.0000	32.97		NO	*
6.04	9.53	1.84	7.69	9.53	9.90	9.80	0.0152	0.0000	69.23		NO	
6.05	9.53	1.84	7.69	9.53	9.90	9.80	0.0152	0.0000	69.23		NO	
6.06	9.53	1.84	7.69	9.53	9.80	9.80	0.0000	0.0000	100.00	•	NO	

TMI.	N_0 .	R	RTM HD	T_R 150 #

DATE E		01/1998 SA51670N						EASURED: EASURED:	,	mm. mm.	
Pts.	Nom. Thick. mm	CA + Steel Mfg.Tol. mm	Nom. -CA -Toll. mm	B/L Survey Thick. mm	Prev. Survey Thick. mm	Last Survey Thick. mm	Short Term CR mm/yr	Long Term CR mm/yr	Rem. Half Life yr	Future UT Reading mm/yy	Action/Caution Required Item
				01/1998	04/2008	10/2014					
8.01	8.76	1.84	6.92	8.76	9.70	9.60	0.0152	0.0000	87.93		NO
8.02	8.76	1.84	6.92	8.76	9.70	9.60	0.0152	0.0000	87.93		NO
8.03	8.76	1.84	6.92	8.76	9.70	9.60	0.0152	0.0000	87.93		NO
8.04	8.76	1.84	6.92	8.76	9.80	9.60	0.0305	0.0000	43.97		NO
8.05	8.76	1.84	6.92	8.76	9.80	9.80	0.0000	0.0000	100.00		NO
8.06	8.76	1.84	6.92	8.76	9.60	9.80	0.0000	0.0000	100.00		NO

If Baseline (B/L) Survey Thickness Measurement was not taken at the time of Manufacture, then Nominal Thickness is used as Baseline Thickness. Minimum Thickness is calculated

 $Design\ Minimum\ Thickness = Nom.\ Thick.\ -\ CA\ -\ Manufacturing\ Steel\ Tolerance.$

Manufacturing Tolerance of pipe and forged fittings is + or -12.5% (May or may not apply dependent upon the Client's Owner-User Integrity Management System).

Manufacturing Tolerance of plate is + or - 0.25mm (0.010") (May or may not apply dependent upon the Client's Owner-User Integrity Management System).

 $^{(*) \} and \ GREEN \ Represent \ 25\% \ of \ the \ last \ thickness \ readings, \ which \ have \ the \ shortest \ remaining \ half \ life.$



FACILITY: CHINCHAGA GAS PLANT MANUFACTURER: THERMO DESIGN ENGINEER

LSD: C-032-H/094-H-08 DESIGN PRESSURE: 1793 kPa / 260 psi ITEM DESC.: DISCHARGE OIL TRAP/COALESCER DESIGN TEMP.: 93 C / 199 F

EQUIP / OIP#: 603VS011

PROV. REG. #: N/S VESSEL CORROSION ALLOWANCE: 1.59 mm

SERIAL #: 1617

CRN.: N8389.21 TOTAL CAUTION / ACTION TML: 2

Item # (021)

COMMENTS:

10.06

6.02

2014/10 - LIMITED SCANNING DUE TO TEMPERATURE.

TML No.: 10 4"90L N-E 150 #

0.75

5.27

6.02

5.80

DATE E		01/1998				AGE THICK IUM THICK				mm. mm.		
Pts.	Nom. Thick. mm	CA + Steel Mfg.Tol. mm	Nom. -CA -Toll. mm	B/L Survey Thick. mm	Prev. Survey Thick. mm	Last Survey Thick. mm	Short Term CR mm/yr	Long Term CR mm/yr	Rem. Half Life yr	Future UT Reading mm/yy	Action/Caution Required Item	
				01/1998	04/2008	10/2014						
10.01	6.02	0.75	5.27	6.02	6.50	6.20	0.0457	0.0000	10.17		CAUTION	*
10.02	6.02	0.75	5.27	(02	<i>c</i> 00		0.0000					
10.02	0.02	0.75	3.21	6.02	6.00	6.00	0.0000	0.0000	100.00	•	NO	
10.03	6.02	0.75	5.27	6.02	5.80	5.90	0.0000	0.0000	100.00	•	NO NO	*
										· ·		*

0.0000

0.0000

100.00

6.10

If Baseline (B/L) Survey Thickness Measurement was not taken at the time of Manufacture, then Nominal Thickness is used as Baseline Thickness. Minimum Thickness is calculated

 $Design\ Minimum\ Thickness = Nom.\ Thick.\ -\ CA\ -\ Manufacturing\ Steel\ Tolerance.$


Manufacturing Tolerance of pipe and forged fittings is + or -12.5% (May or may not apply dependent upon the Client's Owner-User Integrity Management System).

Manufacturing Tolerance of plate is + or - 0.25mm (0.010") (May or may not apply dependent upon the Client's Owner-User Integrity Management System).

(*) and GREEN Represent 25% of the last thickness readings, which have the shortest remaining half life.

BLUE (Caution TML Point) - if Corrosion Rate exceed a 0.250mm / 0.009 in. per yr. or Half Life is less than 15 years.

RED (Action TML Point) - If Remaining Half Life is 0 and Last Survey Thickness is below Nominal-CA-Tolerance Thickness.





4253-97 Street, Edmonton AB, T6E 5Y7 Tel.: (780) 417-0340 Fax: (780) 417-0348 www.integrity-testing.com

EQUIPMENT EXTERNAL INSPECTION REPORT

Customer:		TAQA North		ITS Job	No.:	1-2968	
District:		North Area		Date:		18-Oct-2014	
Facility:	Chinchaga Gas Plant LSD:					C-032-H/094-H-	08
Equip. Description:	Discharge Oil Trap / Coalescer Serial No.				o.:	1617	
Equip./OIP No.:		603VS011		PRN:		Not Stated	
Equip. Type: Column Cooler	Exchanger 🗌 Furn	ace Heater Pla	te Exchanger Reboil	er 🕢 Vessel 🔲	Other:		
Remedial Action	Se	rvice	Associated Co	mponents		Shell	
✓ No Action Required	✓ Sweet	☐ Sour	▼ Y □ N: Name P	late Secure	 ✓ G	ood Condition	
☐ Paint/Coating Repairs	Access an	d Coverage	▼ Y □ N: Name P	late Legible	□ E:	xternal Corrosion	
☐ Insulation Repairs	External In	spection	External Groundi	ng	☐ Pi	itting:	(max depth)
☐ PSV Service Required	☐ Part. Exter	nal Inspection	Direct 🗹 Indire	ect 🗆 N	□ S	cale	
☐ Further Assessment	☐ Internal In:	spection (VI)		adders/	□В	listered	
Required	NDE Examina	ition	tion Walkway/ G			lechanical Damage	
☐ Condition Damage	 ✓ UT		in safe condition	?	□ D	eformation/Distorti	on
☐ Does not comply with	□мт		☐ See Attached	Pictures	□с	ondensation/Sweat	ing
applicable code/safe operating requirement.	□ PT		☐ Excessive Vibr	ration		o Access	
Repairs Required	□ RT		□ ∨ □ N □ NA. □	Proceuro	□ N	o Access Insulated	
☐ See Comments	□ BH		☑ Y □ N □ NA: Pressure Gauge within MAWP			o Access Ice Build	
Status	Other			Tomn	_	/eld(s) in Good Con	
✓ Operational; ☐ Idle;	See Comm	ents	□ Y ☑ N □ NA: Temp. Gauge within MDMT			/eld(s) Corroded	arcion.
Shut In;	_ 500 001111		✓ Y □ N Attache	ed Pipina		/eld(s) Poor Quality	
☐ Surplus/Boneyard;			and Instrumentation in Good Condition See Comments			/eld(s) Cracked	
Other:						ee Comments	
other.			_ See Comment	.5	U 30	ee Comments	
Head (1)			Head (2)			Nozzles	
✓ Top □ North	☐ West	✓ Bottom	☐ South	☐ East	 RF	RTJ V NPT	
☐ Flat ☑ FLG ☐ ELL ☐ EG	СС П НЕМІ	☐ Flat ☐ FLG	✓ ELL □ ECC	□ НЕМІ	 Go	od Condition	
Quick Actuating Closure		☐ Quick Actua	ting Closure		√ Fas	steners Engaged	
✓ Good Condition		☐ Good Condi	tion			pad Weep Holes Cl	ear
☐ External Corrosion		✓ External Cor	rosion		□ No:	zzles are Gusseted	
☐ Pitting:	(max depth)	☐ Pitting:		(max depth)	☐ Ext	ternal Corrosion	
☐ Scale		☐ Scale			☐ Lea	aking/Weeping	
☐ Blistered		□ Blistered			☐ Da	maged/Cracked	
☐ Mechanical Damage		☐ Mechanical	Damage		☐ Bol	lts Missing/Loose	
☐ Deformation/Distortion	☐ Deformation	n/Distortion	☐ De	flection/Distortion			
☐ Condensation/Sweating	☐ Condensation/Sweating				☐ Partial Internal Inspection		
☐ No Access		☐ No Access			□ No	Access Insulated	
■ No Access Insulated		☐ No Access Ir	nsulated		 ₩e	eld(s) in Good Cond	ition
☐ No Access Ice Build Up		☐ No Access Id	ce Build Up		☐ Weld(s) Corroded		
☐ External Protection Only			tection Only		☐ Weld(s) Poor Quality		
See Comments		✓ See Comme	<u> </u>			eld(s) Cracked	
					☐ See	e Comments	





4253-97 Street, Edmonton AB, T6E 5Y7 Tel.: (780) 417-0340 Fax: (780) 417-0348 www.integrity-testing.com

External Surface	Supports	Associated Piping	PRD 1	PRD 2	
✓ Good Condition	✓ Good Condition	✓ Good Condition	Location: inlet piping	Location: Not Applicable	
Painted Full Part.		☐ Corrosion	PSV Tag No.: 603SVVS011	PSV Tag No.: Not Applicable	
☐ Coated ☐ Full ☐ Part.	Secure	Pitting: (max depth)	✓ Service Date within	☐ Service Date within	
☐ Insulated ☐ Full ☐ Part.	☐ Welded to Skid	☐ Bolts Missing/	Interval	Interval	
☐ Insulation Damaged☐ Penetration Seals	Supported by Nozzle(s)	Loose/ Damaged Short Threaded	✓ Set Pressure within MAWP	☐ Set Pressure within MAWP	
Broken	☐ Piping Supported	☐ Valves leaking	✓ Safety Seal Intact	☐ Safety Seal Intact	
☐ Corrosion Under	☐ Expansion Slots		Service Seal Intact	☐ Service Seal Intact	
Insulation (CUI)		☐ Connections		☐ Current Service Tag	
,	☐ Bolts Missing/ Loose/ Damaged	Leaking	Attached	Attached	
☐ Visible Moisture Contamination	☐ Short Threaded	✓ Piping and Valves Supported	☐ PSV inlet Gusseted	☐ PSV inlet Gusseted	
☐ Paint Deterioration	☐ Deflected/Distorted	Supported	☐ Inlet Block Valve	☐ Inlet Block Valve	
☐ Coating		☐ Piping Deflected/	Locked Open 🗆 Y 🗆 N	Locked Open 🔲 Y 🔲 N	
Deterioration	☐ Poor Insulation	Distorted	Sealed Open	Sealed Open	
☐ Fireproofing	☐ Fire Proofing	☐ No Access	☐ Outlet Block Valve	☐ Outlet Block Valve	
Cracked	Cracked	Insulated	Locked Open 🔲 Y 🗆 N	Locked Open 🔲 Y 🔲 N	
☐ External Protection	✓ Vessel is level	☐ See Comments	Sealed Open Y N	Sealed Open Y N	
Only	☐ See Comments		✓ See Comments	☐ See Comments	
☐ See Comments					
Good: No concerns found (may Fair: Minor issues found that deequipment, (paint deterioration, measurable metal loss, not mou Poor: Equipment had moderate damaged, severe external corrol No access to PSV due to Paint deterioration on Recommendations	not impair the "fitness for servi, general external surface corros unted to skid, etc.) to major concerns found (equipusion noted, cracked or broken companies to height. PSV information bottom head has resulted.	ce" of the ion - no (this pi		ervice	
	Conditions and Corre d all Non-Conformance Re		orrective Action Report (C	AR) numbers.	
None					
Recommended Ins	pection Intervals:				
Recommended Maximum Inspection Interval:		PRD 1 commended 60 vice Interval:	Months Recommender Service Interva	Not Applicable Months	



VE-1-2968-21-MAM

4253-97 Street, Edmonton AB, T6E 5Y7 Tel.: (780) 417-0340 Fax: (780) 417-0348 www.integrity-testing.com



External Inspection	on Performed By:		ABSA IPV PESL: 000622 API 510: 40801 API 653: 48515		
Print Name:	Murray Angus MacGregor	Certification No.:	PEI Class 2: 158 CWB Level 2: 8501		
Signature:	<u>Idell)</u>		Report Reviewed:		
Chief Inspector / Client Representative:	Name (Print)	Signature	Date:		