



VESSEL (A): 0661731
 DATE OF INSPECTION: 2023 Mar 15
 DATE OF ISSUANCE: 2023 Apr 13



Certificate of Inspection Permit

Pressure Equipment Safety Regulation Section 33

TARA ENERGY SERVICES INC

9526 81 AVENUE

CLAIRMONT, AB
 T8X 0M2

COMPANY CODE: ST-05

DESCRIPTION: HORIZONTAL SEPARATOR

LOCATION: PORTABLE, CLAIRMONT

MANUFACTURER: CORAL OILFIELD SERVICES INC

Next Inspection Due Date: 2027 Mar 15

Max. Inspection Interval: 4.00Yrs

Year Built: 2016

CRN: V9366.2

Serial #: 4299-01

Volume: 60.088 M3

Heating Surface:

Surface Area:

Pressure Relief Valves

PART	MAX. ALLOWABLE PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
COIL	1034 KPA	177 C	-46 C	SV2			TO BE INSTALLED
VESSEL	862 KPA	149 C	-46 C	SV1	862 KPA	125 M3/MIN	VESSEL

At the time of inspection the item described on the Certificate of Inspection Permit was found to comply with the requirements set forth in the Pressure Equipment Safety Regulation and appeared suitable for operation.

Terms and Conditions:

Owner must ensure this vessel/boiler, its overpressure protection devices, pressure gauges and regulating or controlling devices are maintained in good working order and operated safely.

Pressure relief device is to be serviced by an authorized servicing company every four years.

Safety relief valve has been serviced.

HEATING COIL SHALL HAVE THE OUTLET DISCHARGE AT SAFE LOCATION OPEN TO ATMOSPHERE.

An owner or vendor must notify the Administrator in writing when the pressure equipment identified on this certificate is sold or otherwise disposed of.

The owner or person in charge shall report all unsafe conditions, accidents and fires involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.

Permit issued by: LUNCA, RADU



Signature: *Radu Lunca*

Pursuant to Section 44 of the Safety Codes Act, the item described in this Certificate of Inspection Permit is authorized to operate in the Province of Alberta, within the operating limits established herein, provided all terms and conditions detailed in this Permit have been satisfied.