

2 x 4160VAC CAT 3516 GENERATORS



Generator 1 on the truck

OPERATING LIMITS AT RATED SPEED AND LOAD	
JACKET WATER TEMPERATURE	210 °F
AIR CLEANER RESTRICTION	3.0 IN. H ₂ O MAX
FUEL FILTER PRESSURE DIFFERENTIAL	PSI MAX
OIL FILTER PRESSURE DIFFERENTIAL	PSI MAX
EXHAUST STACK TEMP	375 °F MAX
MANIFOLD AIR TEMPERATURE	230 °F MAX
ENGINE OIL TEMPERATURE	130 °C MAX
ENGINE OIL PRESSURE	40 PSI MIN 275 PSI MAX
FUEL PRESSURE	PSI
TRANSMISSION OIL TEMPERATURE	
TRANSMISSION OIL PRESSURE	
ENGINE SERIAL NUMBER	4EK00073

Generator 1 (Engine #2) – 4EK00073



Hours 13,112



Last maintenance done @ 12,135hrs



Control panel Generator #1



Finning technician inspecting Generator #1

2 x 4160VAC CAT 3516 GENERATORS



Generator #2 being lifted into place





Generator #2 (Engine 4) – E4K00076



Hours 12,982



Last maintenance @ 11,959hrs



Tappet assembly under valve cover