



1- ONE (1) VESSEL REQ'D.
2- ASME STAMP & NAT'L BD. NO. REQ'D.
3- WELD PROCEDURES A611, A661, F141, F611 & F621 APPLY.
4- INTERIOR: NO BLAST, NO PAINT
5- EXTERIOR: NO BLAST, NO PAINT
6- ALL INTERIOR NOZZLE EDGES TO HAVE
1/8" MIN RADIUS OR CHAMFER
7- EST. CAP: 16,304 GAL.
8- EST. WT: 35,834# EMPTY.
171,646# FULL OF WATER.
9- C.R.N. #

APPROVED
For Production
Order No. _____
Date _____
By _____

7					ARROW TANK & ENGINEERING CO.
6					MINNEAPOLIS-CAMBRIDGE MINNESOTA
5					16,250 GALLON
4					CO2 STORAGE VESSEL
3					DRAWN BY SMJ CUSTOMER
	6/28/06	ITEM 38 MOD. DELETED ITEMS 44 & 48	SMJ	CHECKED	ENG. WESTMOR IND.
	6/12/06	PER CUSTOMER COMMENTS	SMJ	SCALE 3/8"=1'-0"	SHEET
NO.	DATE	REVISION	BY	DATE	DRAWING NO.
				4-7-05	1 of 2 D 15902-08