

Doc Number: SELKXL-TXF-0203-FXVLY

Release

Issued by: Susie Almaguer

TRANSFORMER DATA SHEET

SHT 1 OF 3

CLIENT: TransCanada Keystone Pipeline Limited Partnership
PROJECT: Keystone XL Oil Pipeline Project
FABR. SPEC: 25472-100-3PS-ET00-W0001
TAG NO.: 126-FXVLY-BO-T-01
SERVICE: Power Transformer
SITE: Canadian Pump Stations

APPLICABLE TO: ☐ QUOTATION ☐ PURCHASE ☐ AS-BUILT
MANUFACTURER: SIEMENS TRANSFORMADORES S.A. de C.V.
SERIAL NO.: TOHON.001092.01
MODEL:
NO. REQUIRED: 2

SITE CONDITIONS
ALT (m): Less than 1000 m
RELATIVE HUMIDITY:
OUTDOOR TEMPERATURE: MIN (°C) -40 MAX (°C) 40
INDOOR TEMPERATURE: MIN (°C) MAX (°C)
SEISMIC DATA: Per separately provided climate data
LOCATION:
☐ INDOOR ☒ OUTDOOR
☐ TROPICAL ☐ DUST
☐ CORROSIVE GASES
☒ OTHER: Blowing Snow and Dust

CURRENT TRANSFORMER

ITEM	PRIMARY	SECONDARY
MANUFACTURER	Meramec	Meramec
TYPE	Bushing	Bushing
VOLTAGE CLASS	1.1 kV	1.1 kV
QUANTITY	6	3
MOUNTING LOCATION	Bushing	Bushing
RATIO	200/5	4000/5A
ACCURACY	C200	C200
THERMAL RF RATING	2.0	2.0

POWER SYSTEM
UTILITY COMPAN: SaskPower
PHONE No.:
FAULT LEVEL:
MVA BASE: ☐ MVA ☒ MVA
PRI. Note 11 MVA, Note 11 X/R RATIO, R pu Note 11 X pu Note 11
SEC. Note 11 MVA, Note 11 X/R RATIO, R pu Note 11 X pu Note 11

BUSHING DATA

ITEM	PRIMARY (Note 10)	SECONDARY (Note 5)
MANUFACTURER	ABB	ABB
TYPE	Oil Filled	Porcelain
VOLTAGE RATING (V)	230	15
CURRENT RATING (A)	800	4000
INSULATION	Oil	Porcelain
CREEPAGE(HIGH CREEP/HIGH STRENGTH)	7722 mm	351 mm
BIL (KV)	1050	110
LOW FREQ. FLASHOVER-WET/DRY (KV)	Note 1	Note 1

TRANSFORMER DESIGN
DISTRIBUTION TRANSFORMER: ☐ CSA C2
PAD MOUNTED TRANSFORMER: ☐ CSA C227.5 ☐ CSA C227.4 (Dead Front)
POWER TRANSFORMER: ☒ CSA, ANSI, IEEE, ASTM ☐ ANSI, IEEE, ASTM
RATING (3 PHASE, 60 HZ): 20/22.4/26.66/29.86/33.33/37.33 MVA
TEMP. RISE: ☒ 65°C ☐ 55°C
IMPEDANCE: ☐ STD 7.1 %
POSITIVE SEQ. IMP: 7.1 %
ZERO SEQ. IMP: 5.35 %
X/R RATIO: 19
COOLING TYPE: ☐ ONAN ☒ ONAN/ONAF/ONAF (Note 2)

SURGE ARRESTER (Note 6)
☒ REQUIRED ☐ NON REQUIRED
LOCATION: ☒ HIGH VOLTAGE ☐ LOW VOLTAGE

25472-101-VIA-MPC0-W0126
002
Supplier Document Status
Code 1
Code 1 = Work may proceed.
Code 2 = Revise and resubmit. Work may proceed subject to resolution of indicated comments.
Code 3 = Revise and resubmit. Work may not proceed.
Code 4 = Review not required. Work may proceed.
Permission to proceed does not constitute acceptance or approval of design details, calculations, analyses, test methods, or materials developed or selected by the Supplier and does not relieve the Supplier from full compliance with contractual obligations.
Responsible Engineer: Kothari, Manish
Date Signed: 06/14/2011
VPTL - VPTL-02492
Equipment No: NA

WINDING CONNECTION
☒ DELTA / WYE ☐ OTHER
☒ VECTOR GROUP Dyn1
PRIMARY: 230,000 V ☐ Std BIL ☒ 825 kV
SECONDARY: 6,900 V ☐ Std BIL ☒ 110 kV
WINDING MATERIAL
PRIMARY: ☒ COPPER ☐ ALUMINUM
SECONDARY: ☒ COPPER ☐ ALUMINUM

FANS AND PUMPS
AUX. POWER SUPPLY: ☒ 208VAC, 3PH, 60 HZ ☐ OTHER Note 7
MOTOR ENCLOSURE: ☒ TEFC ☐ OTHER
INSUL. TEMP. RISE: ☒ CLASS F, CLASS B RISE ☐ OTHER
AUTOMATIC CONTROL FOR FANS: ☒ REQUIRED ☐ NON-REQUIRED

SYSTEM CONNECTIONS & FEATURES

PRIMARY	SECONDARY	ITEM
<input checked="" type="checkbox"/>	<input type="checkbox"/>	TOP MOUNTED BUSHINGS (SEGMENT 3 - Note 3)
<input type="checkbox"/>	<input checked="" type="checkbox"/>	SIDE MOUNTED BUSHINGS (SEGMENT 1 - Note 3)
<input checked="" type="checkbox"/>	<input type="checkbox"/>	EXPOSED BUSHINGS
<input type="checkbox"/>	<input checked="" type="checkbox"/>	ENCLOSED BUSHINGS (terminal box)
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NEUTRAL GROUNDING
		<input type="checkbox"/> SOLID <input checked="" type="checkbox"/> RESISTANCE NGR 25 A, 10 Sec (Note 4)
		TERMINAL BOX / THROAT
<input type="checkbox"/>	<input type="checkbox"/>	TOP ENTRY
<input type="checkbox"/>	<input checked="" type="checkbox"/>	BOTTOM ENTRY
<input type="checkbox"/>	<input type="checkbox"/>	BUS DUCT ENTRY
<input type="checkbox"/>	<input checked="" type="checkbox"/>	SPACE FOR STRESS CONES
<input type="checkbox"/>	<input type="checkbox"/>	POT HEADS
	<input type="checkbox"/>	POT HEADS
		CABLES
<input checked="" type="checkbox"/>		TYPE AAC SIZE 477 MCM NO./PH 1
	<input checked="" type="checkbox"/>	TYPE TECK SIZE 750 MCM NO./PH 4

TAP CHANGERS
☒ NLTC LOCATION: ☐ LOW VOLTAGE ☒ HIGH VOLTAGE
STEPS: ☒ 4 STEPS OF 2.5% (+5% to -5%) - Full capacity at all taps ☐ OTHER
☒ LTC LOCATION: ☒ LOW VOLTAGE ☐ HIGH VOLTAGE
☒ 32 STEPS OF 5/8% (+10% to -10%) - Full capacity at all taps ☐ OTHER
☒ AUTOMATIC (LTC only) ☐ NON AUTOMATIC

TRANSFORMER CONTROL CABINET
ENCLOSURE: ☒ NEMA 4X ☐ OTHER
☒ HINGED DOOR ☐ OTHER
☒ LOCKABLE
SPACE HEATER WITH THERMOSTAT: ☒ REQUIRED ☐ NON REQUIRED

- NOTES:**
- Vendor to fill in data
 - Two stage fan cooling
 - As per ANSI C57.12.10-1997
 - Supplied and installed on a concrete pad by TCPL
 - 6.9 kV Bushings to be tested as per TCPL/Siemens/WP agreement for ensuring suitability for application (11/06/09)
 - Vendor to fill in on surge arrester Data Sheet 25472-100-EGD-EGLO-W0004
 - Fans are to have individual Circuit Breakers/Fan
 - Insulating Oil must meet or exceed the requirements of C57.106. Note the 'Required' column indicates the limits of new mineral oil as received from the supplier. Other limits apply prior to energisation as noted in C57.106.
 - Transformer tags per separate list, see page 3 of 3.
 - High Voltage Bushings construction shall be in accordance with IEEE C57.19.01
 - Utility supplied data. Data will be added when received.



JOB NO. 08E4490
DATA SHEET NO. 25472-100-ETD-ET00-W0004

REV	ISSUED FOR	DATE	BY	CHKD	APPR
00	Design	14 April 10	FM	GI	KM

Doc Number: SELKXL-TXF-0203-FXVLY

Release

Issued by: Susie Almaguer

TRANSFORMER DATA SHEET

SHT 2 OF 3

CLIENT: TransCanada Keystone Pipeline Limited Partnership

TAG NO. 12G-FXVLY-B0-T-01

PROJECT: Keystone XL Oil Pipeline Project

SERVICE: Power Transformer

FABR. SPEC: 25472-100-3PS-ET00-W0001

SITE: Canadian Pump Stations

APPLICABLE TO: ☐ QUOTATION ☐ PURCHASE ☐ AS-BUILT
MANUFACTURER: SIEMENS TRANSFORMEROS 3A DE C.U.
SERIAL NO.: T.040N.001092.01

MODEL: Note 1
NO. REQUIRED: 2

OPTIONAL ACCESSORIES

- ☒ LIQUID LEVEL INDICATOR W / ALARM CONTACTS
☒ LIQUID TEMP. INDICATOR W / TRIP / ALARM / FAN CONTACTS
☒ WINDING TEMP. INDICATOR W / TRIP / ALARM CONTACTS
☒ VACUUM PRESSURE GAUGE W / ALARM CONTACTS
☒ VACUUM PRESSURE BLEEDER DEVICE
☐ GAS DETECTOR RELAY WITH INDICATOR
☒ SUDDEN PRESSURE RELAY/W TRIP/ALARM CONTACTS
☒ EMERGENCY PRESSURE RELIEF DEVICE W/ALARM CONTACTS
☒ LIQUID DRAIN VALVE WITH THREADED PLUG
☒ LIQUID SAMPLING VALVE WITH THREADED PLUG
☒ RADIATOR VALVES
☒ RADIATOR DRAIN PLUGS AND VENT PLUGS
☒ LIFTING EYES
☒ JACKING FACILITIES
☒ NAMEPLATE FOR BUYER'S EQUIPMENT NUMBER
☒ SPARE PARTS: 1 SPARE SET OF GASKETS
☐ SPECIAL TOOLS

INSULATING OIL ELECTRICAL DATA (Note 8)

GENERAL	UNITS	REQUIRED	VENDOR CONFIRMATION
MANUFACTURER		PETRO CANADA	
TRADE NAME		LUMINOL	
VENDOR'S CATALOG NUMBER		35	
DIELECTRIC			
DIELECTRIC BREAKDOWN VOLT. 60 Hz, ASTM D877	KV / MIN.	30	55
DIELECTRIC BREAKDOWN VOLT. IMPULSE COND. ASTM D3300	KV / MIN.	Note 1	> 300
TEST DATA			
NEUTRALIZATION NUMBER ASTM D 974	mgKOH/g	0.03 Max.	< 0.01
WATER CONTENT ASTM D1533	ppm	Note 1	< 25
INTERFACIAL TENSION @ 25°C, ASTM D971	dynes/cm	40	48
SPECIFIC GRAVITY @ 15°C, ASTM D1298		0.85	0.835
GASSING TENDENCY, ASTM D2300	µL/min	Note 1	-10
CORROSIVE SULPHUR, ASTM D1275B	Y/N	Note 1	NON CORROSIVE
PCB CONTENT, ASTM D4059	ppm	Nil	NIL

MISCELLANEOUS

- PAINT
☐ STD
☒ ASA 70 / II Enamel over epoxy (LIGHT GRAY ANSI 70)
☐
- WEIGHTS
☒ CORE & COILS: 48498 kg
☒ TANK & FITTINGS: 19,114 kg
☒ COOLING LIQUID: 1,303 kg
☒ VOLUME TOTAL: 28,239 litre
- ☒ TOTAL INSTALLED WT.: 99,019 kg
- TRANSFORMER LOSSES @ RATED VOLTAGE
☒ NO LOAD: 75.8 kW
☒ FULL LOAD: 239.3 kW
- EFFICIENCY @
☒ 50% FULL LOAD: 99.51 %
☒ 75% FULL LOAD: 99.40 %
☒ 100% FULL LOAD: 99.26 %
☒ 125% FULL LOAD: 99.1 %
- TESTING
☒ As per Specifications
- SOUND LEVEL
☒ ANSI C57.12.00 ☐ CSA-C88 M90
☒ MAXIMUM AUDIBLE SOUND LEVEL ONAN: 74 dBA
☒ MAXIMUM AUDIBLE SOUND LEVEL ONAF: 76 / 77 dBA
- GROUNDING PADS
☒ TWO (2) GROUNDING PADS WITH LUGS
☐ OTHER
☒ REQUIRED FOR # 2/0 AWG to 4/0 AWG CU
☐ OTHER

VISUAL			
COLOR, ASTM D1500		Clear/pale amber	< 0.5
CONDITION, ASTM D1524		Clear	Clear
TEMPERATURE POINTS			
FLASH POINT, ASTM D92	°C	133 Min.	170
POUR POINT, ASTM D5950 / D97	°C	-58 MIN.	-60
ANILINE POINT, ASTM D611	°C	Note 1	NA
OXIDATION STABILITY FOR INHIBITED OIL, ASTM D2440 / D2112			
WT.% Sludge, @ 72 hrs	%	Note 1	NA
NEUTRALIZATION NUMBER @ 72 hrs	mgKOH/g		NA
WT.% Sludge, @ 164 hrs	%	Note 1	< 0.01
NEUTRALIZATION NUMBER @ 164 hrs	mgKOH/g	Note 1	< 0.01
OXIDATION STABILITY FOR INHIBITED OIL, IEC 61125 Method C			
WT.% Sludge	%	Note 1	< 0.02
NEUTRALIZATION NUMBER	mgKOH/g	Note 1	< 0.02
POWER FACTOR AT 90°C		Note 1	< 0.001
KINEMATIC VISCOSITY, ASTM D445			
VISCOSITY AT 0 °C	Sybolt sec.	Note 1	53
VISCOSITY AT 40 °C	Sybolt sec.	Note 1	9.2
VISCOSITY AT 100 °C	Sybolt sec.	Note 1	2.8
VISCOSITY AT -40 °C	Sybolt sec.	Note 1	1230
POWER FACTOR, ASTM D924			
POWER FACTOR AT 25°C	% MAX	0.05	< 0.0001
POWER FACTOR AT 100°C	% MAX	0.3	0.001
INHIBITOR CONTENT, TYPE II OIL, ASTM D2668	%	> 0.08 - 0.3	0.20

NOTES:

- Vendor to fill in data
- Two stage fan cooling
- As per ANSI C57.12.10-1997
- Supplied and installed on a concrete pad by TCPL
- 6.9 kV Bushings to be tested as per TCPL/Siemens/WP agreement for ensuring suitability for application (11/06/09)
- Vendor to fill in on surge arrester Data Sheet 25472-100-EGD-EGLO-W0004
- Fans are to have individual Circuit Breakers/Fan
- Insulating Oil must meet or exceed the requirements of C57.106. Note the 'Required' column indicates the limits of new mineral oil as received from the supplier. Other limits apply prior to energisation as noted in C57.106.
- Transformer tags per separate list, see page 3 of 3.
- High Voltage Bushings construction shall be in accordance with IEEE C57.19.01
- Utility supplied data. Data will be added when received.

REV	ISSUED FOR	DATE	BY	CHKD	APPR
00	Design	14 April 10	FM	IGI	KM



JOB NO. 08E4490
DATA SHEET NO. 25472-100-ETD-ET00-W0004

Doc Number SEKKXL-TXF-0203-FXVLY

Release 1

Issued by Susie Almoguer

TRANSFORMER DATA SHEET

SHT 3 OF 3

CLIENT TransCanada Keystone Pipeline Limited Partnership TAG. 126-FXVLY-B0-T-01
PROJECT Keystone XL Oil Pipeline Project SERVICE Power Transformer
FABR. SPEC 25472-100-3PS-ET00-W0001 SITE Canadian Pump Stations

APPLICABLE TO ☐ QUOTATION ☐ PURCHASE ☐ AS-BUILT
MANUFACTURER SIEMENS TRANSFORMADORES S.A. DE C.V. MODEL Note 1
SERIAL NO. T.040N.001092.01 NO. REQUIRED 2

TRANSFORMER TAGGING DATA

PUMP STATION	PROVINCE	TAG No.
FOX VALLET PS-6	SASKATCHEWAN	126-FXVLY-B0-T-01
PIAPOT PS-7	SASKATCHEWAN	127-PIAPT-B0-T-01

NOTES:

- Vendor to fill in data
- Two stage fan cooling
- As per ANSI C57.12.10-1997
- Supplied and installed on a concrete pad by TCPL.
- 6.9 kV Bushings to be tested as per TCPL/Siemens/WP agreement for ensuring suitability for application (11/06/09)
- Vendor to fill in on surge arrester Data Sheet 25472-100-EGD-EGL0-W0004
- Fans are to have individual Circuit Breakers/Fan
- Insulating Oil must meet or exceed the requirements of C57.106. Note the 'Required' column indicates the limits of new mineral oil as received from the supplier. Other limits apply prior to energisation as noted in C57.106.
- Transformer tags per separate list, see page 3 of 3.
- High Voltage Bushings construction shall be in accordance with IEEE C57.19.01
- Utility supplied data. Data will be added when received.



WorleyParsons
resources & energy

JOB NO. 08E4490
DATA SHEET NO. 25472-100-ETD-ET00-W0004

REV	ISSUED FOR	DATE	BY	CHKD	APPR
00	Design	14 April 10	FM	GI	KM-AY