



NOTE:
 1. DRAIN LINES STRAPPED TO FUEL GAS LINES VIA U-BOLT. LINES ARE GLYCOL TRACED AND INSULATED TOGETHER.
 2. 100mm(4") A333 PIPE DERATED TO 32,915 kPag (4774 psig) TO ALLOW FOR FULL 1.5mm CORROSION ALLOWANCE.

REV	DATE	DESCRIPTION	ENG	LD	BY	CHK
2	2021-06-29	AS-BUILT	BDD	FLJ	SDZ	
1	2019-01-21	ISSUED FOR CONSTRUCTION	BDD	NL	NL	
0	2019-01-09	ISSUED FOR CONSTRUCTION	BDD	NL	VH	
B	2018-12-18	ISSUED FOR APPROVAL	BDD	NL	NL	
A	2018-11-29	ISSUED FOR APPROVAL	BDD	NL	NL	

STAMPS	

CLIENT

McINTOSH PERRY
 2711 - 39 Avenue N.E.
 Calgary, AB T1Y 4T8
 Tel: 403-261-4991 Fax: 403-266-2361
 www.mcintoshperry.com

PROJECT DESC.
 BRAZEAU RIVER
 100/14-09 & 102/14-09-43-13 W5M
 PAD SITE EQUIP.

DRAWING DESC.
 LINE HEATER U-5200
 PROCESS & INSTRUMENTATION DIAGRAM

LSID:
 01-09-43-13 W5M

DRAWING No.
 10723-1012

PROJ. No.
 11249

REV
 2