

☐ Other

Document #: AI FR 015

Page: 1 of 4

Inspection Report – Pressure Vessel Visual Internal

□Installation				nal 🗵 Reg	ulatory	☐ Periodic	⊠ Sv	veet	□ Sour	
Date: 5/12/2021			Description: ⊠Vessel □Exchanger □Boiler				Etag: E32443			
Inspector: Chamith Wickramasinghe			Equipment Name: Separator				CRN#: F8484.2			
Agent Co: Enerplus			Jurisdiction #: A0482583				Serial #: 02.006HS			
Owner: Enerplus			Manufacturer: Orban Industries				Year Built: 2002			
District: North Central Plains			Field: Joarcam				LSD: 11-07-050-21W4M			
· · · · · · · · · · · · · · · · · · ·										
Access			☐ Inspection nozzle							
Opening	Gasket surfaces		Good Condition? ⊠ Yes □ N			Comment: Acceptable				
	Nozzle tube		Good Condition? ⊠ Yes □ No			Comment: Acceptable				
· · · · · · · · · · · · · · · · · · ·										
Internal Coating										
Coating	□ Yes	0 🗆	Full □ Part	Comment: N/A						
Coating Co	ting Condition			epairs Requir	Repairs Completed?		Comments: N/A			
Acceptable				Yes ⊠ No	☐ Yes ⊠ No					
· · · · · · · · · · · · · · · · · · ·										
Shell and Head Surfaces	General Corre	osion	☐ Yes ⊠ No			Comment: Acceptable				
	Pitting Corrosion		☐ Yes ⊠ No			Comment: Acceptable				
	Erosion		☐ Yes ⊠ No			Comment: Acceptable				
	Mechanical Damage		e □ Yes ⊠ No			Comment: Acceptable				
Welds	General Corro	sion	☐ Yes	s ⊠ No		Comment: Acceptable				
	Pitting Corrosion		☐ Yes ⊠ No			Comment: Acceptable				
	Welding defects		☐ Yes ⊠ No			Comment: Acceptable				
<u> </u>										
Internal Piping	General Corrosion		☐ Yes ⊠ No			Comment: Acceptable				
	Pitting Corrosion		☐ Yes ⊠ No			Comment: Acceptable				
	Welding Defects		☐ Yes ⊠ No			Comment: Acceptable				
	Supports Secured?					Comment: Acceptable				
	Short Bolting		☐ Yes ⊠ No			Comment: Acceptable				
<u> </u>										
Nozzles	Obstructions		s 🗵 No Comment: Acceptable							
	Corrosion	Corrosion		Comment:						
			es 🗵 No Comment: Accepta							
Ziosion Zino Zino Commenti recoptable										
Attachments	☐ Vortex breaker		Secure? ☐ Yes ☐ No Good		Good C	Condition? ☐ Yes ☐ No		Comment: N	/A	
						Condition? ⊠ Yes □ N		Comment: A		
	⊠ Downcomer		Secure? ⊠ Yes □ No			sood Condition? ⊠ Yes □		Comment: A	· ·	
	☐ Demister					Condition? ☐ Yes ☐ No		Comment: N/A		
	☐ Heating coil		Secure? ☐ Yes ☐ No Good			Condition? ☐ Yes ☐ No		Comment: N/A		
	☐ Fire tube		Secure? ☐ Yes ☐ No Good			Condition? ☐ Yes ☐ No		Comment: N/A		

Secure? ☐ Yes ☐ No Good Condition? ☐ Yes ☐ No Comment: N/A



Document #: AI FR 015

Page: 2 of 4

Inspection Report - Pressure Vessel Visual Internal


Inspection Summary: Vessel is in acceptable condition. Corrective Action Item(s): None NCR: None **Integrity Status:** Suitable for continued Service? \boxtimes Yes \square No Immediate repairs required? ☐ Yes ☐ No **Inventory Status:** ☐ Out of service **Inspector Sign Off** Recommended Internal Inspection Interval (months): 60 Months Chamith Wickramasinghe Signature: Jurisdictional Inspector #: API510 No. 61383, ABSA ISI No. 001310 **Enerplus In-service Inspector Sign Off** Internal Inspection Interval changes to (months): 60 Months - VE,UT,VI Signature: Chamith Wickramasinghs Jurisdictional Inspector #: API 510 No. 61383, ABSA ISI No. 001310



Inspection Report - Pressure Vessel Visual Internal

Document #: AI FR 015

Page: 3 of 4





Document #: AI FR 015

Inspection Report – Pressure Vessel Visual Internal

