

VISUAL INSPECTION REPORT-PRESSURE VESSEL

Inspection Type 🔽 External 🔽 Internal																
Date: February 7, 201			8			Description:		5	Vessel 🗖 E	Exchange	r 🗖	Furn	ace [Boiler		
Inspector: Ryan Hogg						U	Unit #:				Equip #:		848	875		
Agent Co: 101292687 \$			687 Sask	skatchewan LTD			E	Equip. Name:			Filter					
Location/LSD	BAT/09	BAT/09-32-001-28W1					CRN #: T460			605.4)5.4					
Province:	Manitob	Manitoba					Manufacturer: ESS Co			SS Corp.	rp.					
Area:		Run 00	Run 009 – Ingoldsby/Pierson					Year Built: 201		14	S/N: 45		551-A			
Subarea:		Battery 09-32-001-28W1				J	Jurisdiction #:			PWHT			-			
Service	Swee	Sweet Sour Other:				PSV Location			Ch	Choose an item.			MDMT -20F			
Vessel MAWP		150 PSI					I	Vessel MAWT		100 F		r	RT		r	
PSV Data	Set P	CPE#	Manufac	turer	S/N	In Sz		Out. Sz.	Serv.	. Co.	Serv. Date	IV		CS	С	Capacity
Shell Side												Y/N	I	Y/N		
Tube Side												Y/N	1	Y/N		
Other												Y/N	I	Y/I	٧	
ø		Ma	aterial	Nor	ninal t	CA		Retire t	Lowes	st t	t OK?	Calc. t-min			C	omment
	Shell										□ Y □ N					
nent	Head								0.297"		ΩyΩn					
Components	Channe	el									□ y □ N					
ပိ	Tube										□ Y □ N					
Other											ΩyΩn		Specify:		ecify:	
External Visual Inspection																
Orientation Hor. Ver.				Foundation Concrete Gravel C			🗖 Timi				Condition Welded to building loor					
		C Saddle	;	Seal-welded			F ree	e to Move Condition								
_		C Skirt		Free of debris Comment:				ient:	Condition							
Support		🗖 Hange	rs	Secure Comment:				Condition			n					
		Other Specify: Steel Legs t					o floor Condit			Condition	on Secure					
				± Externally painted inside building, minor rks				r	Electrical grounding:							
Ext. Surface	xt. Surface Painted Insulated Fire-proof Condition Minor marks					roofed	Γ	Cladded	Othe	r :						
Ext. Fixtures				Platform(s) 🗖 Other:				Condition								
Nozzles		Manway Port Size: Remov					ab	le top	Reinforcement Pads Used Weep Holes Present				Present			
		Comment:														
Davit Arm			nt	Greased					Double Nut Cor			Conditi	Condition			

Rev. 3 November 2017



VISUAL INSPECTION REPORT-PRESSURE VESSEL

	PSV	Supported Joined per code	Drains Proper	ly Comment				
Piping	Inlet	Supported Joined per code	Free from leak	^{(S} Comment				
	Outlet	Supported Joined per code	Free from leak	s Comment				
	Drain	Supported Joined per code	Free from leak	Comment				
	Instrumentation	Supported	Free from leaks/kinks	Comment				
	Process Fluid Iden	lified	Flow direction marked	Comment				
	Manual Isolation Value	alve	Free from leaks	s Comment				
Valves	Automated Control	Valve	E Free from leaks	s Comment				
	Vents and Drain pl	ugged	E Free from leaks	s Comment				
Gauges	Pressure	Reading: 0 PSI	Condition Clean and readable					
	Temperature	Reading:	Condition	Condition				
Sight Glass	Fluid Level	Reading:	Condition	Condition				
External Inspection Notes: No damages externally								
Internal Visual Inspection								
Date:	February 7, 2018 Inspector Ryan Hogg							
Scope:	A visual internal (VI) inspection was performed on all accessible shell and head surfaces, nozzles, welds, etc.							
Access:	Manway Hand-hole Inspection Nozzle Diameter: Top head removed							
Opening	Gasket Surfaces:	Compliant with code	Comment	Comment				
	Nozzle Tube:	No pitting, erosion, etc.	Comment	comment				
	Uniform Corrosion:	Insignificant amount	Comment					
Shell and Head	Pitting Corrosion:	None noted	Comment Pitting throughout bottom head					
Surfaces	Erosion:	None noted	Comment	Comment				
	Mechanical Damage:	None noted	Comment	Comment				
	Uniform Corrosion:	Insignificant amount	Comment					
Welds	Pitting Corrosion:	None noted	Comment Pitting thro	bughout filter plate to shell weld				
Welds	Pitting Corrosion: Welding Defects:	None noted	Comment Pitting thro Comment					
Welds	Pitting Corrosion:	None noted	Comment Pitting thro					
Welds	Pitting Corrosion: Welding Defects:	None noted	Comment Pitting thro Comment					
	Pitting Corrosion: Welding Defects: NDT was performed NDE Type: UT N Results: UT on bottom	None noted None noted by: Ryan Hogg DE Type:	Comment Pitting thro Comment Extent: Bottom head					



Crescent Point

VISUAL INSPECTION REPORT-PRESSURE VESSEL

	Corrosion:	None noted	Comment Comment				
	Erosion:	None noted					
	Uortex breaker	Secure 🔲 Good Condition	Comment				
	Impingement plate	Secure 🔲 Good Condition	Comment				
Attachments	Suction tube	Secure Good Condition	Comment				
	Demister	Secure 🔲 Good Condition	Comment				
	Other: Filter plate	Secure 🔽 Good Condition	Comment Minor surface corrosion throughout				
Detailed Inspection Summary	Inspection Practices: 2.0 Non-Fired Pressure Vessels Filter is showing internal pitting and corrosion at the time of inspection. Bottom head was UT'd reading throughout were 0.425" in pitts along head curvature, the center areas between the nozzles in the bottom head in an 8" circular area was down to readings of 0.340" to 0.297" remaining – limited access to the area due to the internal filter holding plate. The weld on the top of the filter holder has corroded with the corrosion reaching the rubber ring area. The area around the gasket if continuing to corrode will create a leak at the top head to shell seal. Vessel is to be cleaned out at each filter change interval – filter is at the end of life – prepare for a future replacement.						
Recommended Actions	Due to the design of the filters the bottom head is pitting throughout, there is no access for repairing. The top plate to hold the filters is corroding along the weld to the shell – the corrosion has reached the o-ring area on the North corner. The filter is at the end of life – prepare for a future replacement.						
Integrity Status	Suitable for Continued Service 🗹 Yes 🗖 No 🔄 Future Repairs Required						
Inventory Status	C Active Out of Service Surplus Rental Scrap						

Visual External Inspection Interval: <u>1</u> yrs OR Visual Internal Inspection Interval: <u>1</u> yrs OR	• <u> </u>	
Ultrasonic Inspection Interval: <u>6 month</u> OR	Changed to:	yrs.
PSV Interval: yrs OR Changed to:	yrs.	
Class 1 Class 2 PEI Certificate #:	<u>128</u>	\sim
IPV/IBPV Certificate #:		14
Inspectors Name: <u>Ryan Hogg</u>	Signature:	hyan 1099
		/

Chief Inspector: I certify that the information on this report is true and all inspections as required by our Owner/User Quality Assurance Program # <u>QMS-0036</u> which expires <u>September 6, 2018</u> have been done.

Recommendations:

Internally inspect at next filter change.

UT after 6 month of service due to corrosion issues in the adjacent filters.

Filters should be cleaned out on a regular basis when switching to opposite bank of filters.

Filter is at end of life – prepare for future replacement.







VISUAL INSPECTION REPORT-PRESSURE VESSEL

