

Certificate of Inspection

GUNNING INVESTMENT RECOVERY SERVICES INC
213 DALCASTLE CLOSE N.W.

CALGARY, AB
T3A 1Z4

PREFERRED RE-INSPI. INTERVAL: Yr.

YEAR BUILT: 1994

CRN: M6180.2

SERIAL #: 49851-1

VOLUME: 0.287 M3

HEATING SURFACE:

SURFACE AREA:

COMPANY CODE:

DESCRIPTION: VERTICAL FILTER SEPARATOR

LOCATION: STOCK, CALGARY

MANUFACTURER: PERRY EQUIPMENT CORPORATION

Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	9763 KPA	65 C	-29 C	SV1	9756 KPA	105 M3/MIN	VESSEL

OWNER INSTRUCTIONS/REMARKS:

NOT SUBJECT TO ANNUAL FEES AS PER INFORMATION BULLETIN IB03-003 (i)
VESSELS HAVING A VOLUME NOT EXCEEDING 0.5 M3 (500 LITRES) THAT ARE LOCATED IN WELL HEAD PLANTS OR
BATTERIES;

Safety Codes Officer: REINHART, JASON

Signature:



NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

The owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.