

Job Number: 03-248-521
Calculation Package Revision Level: 1

DESIGN CALCULATIONS INDEX

Calculation Description	Applicable		Pages	Rev. Level
	Yes	No		
Primary Membrane Stress Calcs. (Computer Design Pgm.)	✓		1-14	1
Lifting Lug Calculations		✓		
Horizontal Vessel Saddle Calculations		✓		
Vertical Vessel Skirt Calculations		✓		
Other UG-22 Specified Loadings		✓		
Vessel Impact Testing Exemption Summary	✓		1-14	1

DESIGN CALCULATIONS REVISION CONTROL AND APPROVAL

¹ Drawing No. & Rev. Level	Calc. Package Rev. Level	Revised Calcs. Required	Approval	Date

New design

¹ Whenever new drawings are issued that pertain to the calculation package, or whenever drawings are revised, the current calculations shall be verified and approved as applicable or revised as necessary and approved.

Date Printed: 5/6/2004

VESSEL DESCRIPTION

18" O.D. x 66" S/S

Vessel designed per the ASME Boiler & Pressure Vessel Code,
Section VIII Division 1, 2001 Edition, 2003 Addenda
with Advanced Pressure Vessel, Version: 8.2.1
Vessel is ASME Code Stamped

Job No: 03-248

Vessel Number: 03-248-521

NAMEPLATE INFORMATION

MAWP: 655.00 PSI
MDMT: -20 °F at 655.00 PSI
Serial Number(s): 03-248-521
Year Built: 2004
Radiography: RT 1
Postweld Heat Treated: HT
Construction Types: W

Notes

All applicable UG-22 loadings have been considered in this design

Signatures

Engineering:  Date:  / /

Mike Fudge

MAY 06 2004

Revision No.:  Date: / /

Table of Contents

Shell 1	1
Head 1	2
Nozzle 1	3
Nozzle 2	8
MDMT Summary	12
MAWP Summary	13
Summary Information	14

Bidell Equipment, Inc.

Shell 1

Job No: 03-248
Number: 1

Vessel Number: 03-248-521
Mark Number: S1

Date Printed: 5/6/2004

Cylindrical Shell Design Information

Design Pressure:	655.00	PSI	Design Temperature:	300	°F
Static Head:	0.00	PSI	Joint Efficiency:	100	%
Shell Material:	SA-106	Gr B	Factor B Chart:	CS-2	
Shell Length:	66.0000	in.	Material Stress (hot):	17100	PSI
Corrosion Allowance:	0.1250	in.	Material Stress (cold):	17100	PSI
External Corrosion Allowance:	0.0000	in.	Actual Circumferential Stress:	15814	PSI
Outside Diameter (new):	18.0000	in.	Actual Longitudinal Stress:	7517	PSI
Outside Diameter (corroded):	18.0000	in.	Specific Gravity:	1.00	
Shell Surface Area:	25.92	Sq. Ft.	Weight of Fluid:	533.96	lb.
Shell Estimated Volume:	63.92	Gal.	Total Flooded Shell Weight:	1109.02	lb.
			Shell Weight:	575.06	lb.

Minimum Design Metal Temperature Data

Minimum Design Metal Temperature: -20 °F
Material is exempt from impact testing per UG-20(f), 1 through 5

Design Thickness Calculations

Longitudinal Stress Calculations per Paragraph UG-27(c)(2)

$$t = \frac{PR}{2SE + 0.4P} = \frac{655.00 * 8.5630}{2 * 17100 * 1.00 + 0.4 * 655.00} = 0.1628 + 0.1250 \text{ (corrosion)} + 0.0000 \text{ (ext. corrosion)} + 0.0411 \text{ (12 1/2\% for pipe)}$$

= minimum of **0.3289** in.

Circumferential Stress Calculations per Appendix 1-1(a)(1)

$$t = \frac{PR_o}{SE + 0.4P} = \frac{655.00 * 9.0000}{17100 * 1.00 + 0.4 * 655.00} = 0.3396 + 0.1250 \text{ (corrosion)} + 0.0000 \text{ (ext. corrosion)} + 0.0664 \text{ (12 1/2\% for pipe)}$$

= minimum of **0.5310** in.

MAWP for this Shell Section Only

$$P = \frac{SEt}{R_o - 0.4t} = \frac{17100 * 1.00 * 0.3667}{9.0000 - 0.4 * 0.3667}$$

= maximum design pressure of **708.27** PSI

External loads do not control design.

Pipe Selected: Size = **18 in.**, Schedule = **40**, Diameter = **18.0000** in., Wall = **0.5620** in.

Bidell Equipment, Inc.
Head 1

Job No: 03-248
Number: 1

Vessel Number: 03-248-521
Mark Number: H1

Date Printed: 5/6/2004

Ellipsoidal Head Design Information

Design Pressure:	655.00 PSI	Design Temperature:	300 °F
Static Head:	0.00 PSI	Joint Efficiency:	100 %
Head Material:	SA-516 Gr 70	Factor B Chart:	CS-2
Material Condition:	Normalized	Material Stress (hot):	20000 PSI
Corrosion Allowance:	0.1250 in.	Material Stress (cold):	20000 PSI
External Corrosion Allowance:	0.0000 in.	Actual Head Stress:	18275 PSI
Head Location:	Right	Straight Flange :	2.0000 in.
Outside Diameter :	18.0000 in.	Head Depth (ho) :	4.7500 in.
Thin Out :	0.0625 in.		
K = $\frac{1}{2} [2 + (D/2h)^2]$:	1.00		
Head Surface Area:	3.08 Sq. Ft.	Specific Gravity:	1.00
Head Estimated Volume:	4.75 Gal.	Weight of Fluid:	39.61 lb.
Head Weight:	62.79 lb.	Total Flooded Head Weight:	102.41 lb.

Minimum Design Metal Temperature Data

Minimum Design Metal Temperature: -20 °F
Material is exempt from impact testing per UG-20(f), 1 through 5

Design Thickness Calculations

Design Thickness Calculations per Appendix 1-4(c)

$$\frac{PD_o K}{2SE + 2P(K - 0.1)} = \frac{655.00 * 18.0000 * 1.00}{2 * 20000 * 1.00 + 2 * 655.00 * (1.00 - 0.1)} = 0.2864 + 0.1250_{\text{(corrosion)}} + 0.0000_{\text{(ext. corrosion)}} + 0.0625_{\text{(thin out)}}$$

= minimum of **0.4739** in.

Extreme Fiber Elongation Calculation per Paragraph UCS-79

$$\text{elongation} = \frac{75t}{R_f} = \frac{75 * 0.5000}{2.9750} = \text{elongation of } 12.60 \%$$

MAWP per UG-32 for this Head Only

$$P = \frac{2SEt}{KD_o - 2t(K - 0.1)} = \frac{2 * 20000 * 1.00 * 0.3125}{1.00 * 18.0000 - 2 * 0.3125 * (1.00 - 0.1)} = 716.85 \text{ PSI}$$

External loads do not control design.

Nominal Head Thickness Selected = **0.5000** in.
Minimum Thickness after forming = **0.4375** in.

Job No: 03-248
Number: 1
ID Number: 1

Date Printed: 5/6/2004

Nozzle Design Information

Design Pressure:	655.00 PSI	Design Temperature:	300 °F
Static Head:	0.00 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S _n):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.1250 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Passes through a Category A Joint:	No
Nozzle Pipe Size:	10	Nozzle Pipe Schedule:	160
Nozzle ID (new):	8.5000 in.	Nozzle Wall Thickness(new):	1.1250 in.
Nozzle ID (corroded):	8.7500 in.	Nozzle Wall Thickness(corroded):	1.0000 in.
Outer "h" Limit:	0.9168 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal "h" Limit:	0.9168 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
OD, Limit of Reinforcement:	17.5000 in.	Appendix 1-7 OD, Limit of Reinforcement(d _{LDR}):	13.1250 in.
Outside Groove Weld Depth:	0.5620 in.		

Minimum Design Metal Temperature

Minimum Design Metal Temperature: -20 °F
Material is exempt from impact testing per UG-20(f), 1 through 5

Reinforcing Pad Information

Reinforcing Material:	SA-106 Gr B	Allowable Stress at Design Temperature(S _p):	17100 PSI
		Allowable Stress at Ambient Temperature:	17100 PSI
Reinforcing Plate Thickness(t _e):	0.3750 in.	Repad to Vessel Weld Leg Size(Weld 42):	0.3125 in.
OD, Reinforcing Plate(D _p):	14.8750 in.	Repad to Nozzle Groove Weld Depth:	0.3750 in.

Host Component: Shell 1 - Shell 1

Material:	SA-106 Gr B	Shell wall thickness(new):	0.5620 in.
Material Stress(S _v):	17100 PSI	Shell wall thickness - 12½% for pipe (corroded):	0.3668 in.

Nozzle Detail Information




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal Weld Leg Size(Weld 43):	0.0000 in.
Nozzle Wall Thickness(t _n):	1.1250 in.
Outside Groove Weld Depth:	0.5620 in.
Repad to Vessel Weld Leg Size(Weld 42):	0.3125 in.
Repad Thickness(t _e):	0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.
Pipe Size: 10 Schedule: 160
Nozzle is adequate for UG-45 requirements.
Opening is adequately reinforced for Internal Pressure.
Large opening meets Appendix 1-7 stress calculation requirements
Weld Strength Paths are adequate.

Job No: 03-248 Number: 1 ID Number: 1 Bidell Equipment, Inc. Nozzle 1 Vessel Number: 03-248-521 Mark Number: N1 Date Printed: 5/6/2004		
Required Shell Thickness per Paragraph UG-37(a)		
$tr = \frac{PR_o}{SE + 0.4P} = \frac{655.00 * 9.0000}{17100 * 1 + 0.4 * 655.00}$		= 0.3395 in.
Nozzle Required Thickness Calculations		
Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)		
$trn = \frac{PR_n}{SE - 0.6P} = \frac{655.00 * 4.3750}{17100 * 1 - 0.6 * 655.00}$		= 0.1715 in.
Strength Reduction Factors		
$fr1 = \frac{S_n}{S_v} = \frac{17100}{17100} = 1.0000$		$fr2 = \frac{S_n}{S_v} = \frac{17100}{17100} = 1.0000$
$fr3 = \frac{S_n}{S_v} = \frac{17100}{17100} = 1.0000$		$fr4 = \frac{S_p}{S_v} = \frac{17100}{17100} = 1.0000$
UG-45 Thickness Calculations		
Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)		
$t = \frac{PR_n}{SE - 0.6P} + Ca + ext. Ca = \frac{655.00 * 4.3750}{17100 * 1.00 - 0.6 * 655.00} + 0.1250 + 0.0000$		= 0.2965 in.
Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)		
$t = \frac{PR_o}{SE + 0.4P} + Ca + ext. Ca = \frac{655.00 * 9.0000}{17100 * 1 + 0.4 * 655.00} + 0.1250 + 0.0000$		= 0.4645 in.
Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)		
$t = \text{minimum thickness of standard wall pipe} + Ca + ext. Ca$		= 0.4444 in.
Nozzle Minimum Thickness per Paragraph UG-45(b)		
$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)}$		= 0.4444 in.

Nozzle Reinforcement Calculations

Area Required for Internal Pressure

$A = d \text{ tr } F + 2 \text{ tn tr } F (1 - fr1) = (8.7500 * 0.3395 * 1.00) + (2 * 1.0000 * 0.3395 * 1.00 * (1 - 1.0000)) = 2.9706 \text{ sq. in.}$

Area Available - Internal Pressure

$A1 \text{ Formula 1} = d(E1 \text{ t} - F \text{ tr}) - 2\text{tn}(E1 \text{ t} - F \text{ tr})(1 - fr1) = 8.7500 * (1.00 * 0.3667 - 1.00 * 0.3395) - 2 * 1.0000 * (1.00 * 0.3667 - 1.00 * 0.3395) * (1 - 1.0000) = 0.2380 \text{ sq. in.}$

$A1 \text{ Formula 2} = 2(t + \text{tn})(E1 \text{ t} - F \text{ tr}) - 2\text{tn}(E1 \text{ t} - F \text{ tr})(1 - fr1) = 2 * (0.3667 + 1.0000)(1.00 * 0.3667 - 1.00 * 0.3395) - 2 * 1.0000 * (1.00 * 0.3667 - 1.00 * 0.3395) * (1 - 1.0000) = 0.0743 \text{ sq. in.}$

$A1 = \text{Larger value of } A1 \text{ Formula 1 and } A1 \text{ Formula 2} = 0.2380 \text{ sq. in.}$

$A2 \text{ Formula 1} = 5(\text{tn} - \text{trn}) \text{ fr2 t} = 5(1.0000 - 0.1715) * 1.0000 * 0.3667 = 1.5191 \text{ sq. in.}$

$A2 \text{ Formula 2} = 2(\text{tn} - \text{trn}) \text{ fr2} (2.5 \text{ tn} + \text{te}) = 2(1.0000 - 0.1715) * 1.0000 * (2.5 * 1.0000 + 0.3750) = 4.7639 \text{ sq. in.}$

$A2 = \text{Smaller value of } A2 \text{ Formula 1 and } A2 \text{ Formula 2} = 1.5191 \text{ sq. in.}$

A3 = Smaller value of the following :

$5 * t * t_l * f_{r2} = 5 * 0.3667 * 0.8750 * 1.0000 = 1.6043 \text{ sq. in.}$

$5 * t_l * t_l * f_{r2} = 5 * 0.8750 * 0.8750 * 1.0000 = 3.8281 \text{ sq. in.}$

$2 * h * t_l * f_{r2} = 2 * 0.0000 * 0.8750 * 1.0000 = 0.0000 \text{ sq. in.}$

$= 0.0000 \text{ sq. in.}$

$A41 = (\text{leg})^2 * \text{fr3} = (0.3750)^2 * 1.0000$

$= 0.1406 \text{ sq. in.}$

$A42 = (\text{leg})^2 * \text{fr4} = (0.3125)^2 * 1.0000$

$= 0.0977 \text{ sq. in.}$

$A43 = (\text{leg})^2 * \text{fr2} = 0 * 1.0000$

$= 0.0000 \text{ sq. in.}$

$A5 = (Dp - d - 2\text{tn}) \text{ te fr4} = (14.8750 - 8.7500 - 2 * 1.0000) * 0.3750 * 1.0000$

$= 1.5469 \text{ sq. in.}$

$\text{Area Available (Internal Pressure)} = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 3.5423 \text{ sq. in.}, \text{ which is greater than } A (2.9706)$

Appendix 1-7(a) (Large Opening in Shell) Calculations	
Area Required for Internal Pressure A = 2/3 * (d tr F + 2 tn tr F (1 - fr1)) = 2/3 * ((8.7500 * 0.3395 * 1.00) + (2 * 1.0000 * 0.3395 * 1.00 * (1 - 1.0000)))	= 1.9804 sq. in.
Area Available - Internal Pressure A1 = (dLDR - d)(E1 t - F tr) - 2tn(E1 t - F tr)(1 - fr1) = (13.1250 - 8.7500) * (1.00 * 0.3667 - 1.00 * 0.3395) - 2 * 1.0000 * (1.00 * 0.3667 - 1.00 * 0.3395) * (1 - 1.0000)	= 0.1190 sq. in.
A2 Formula 1 = 5(tn - trn) fr2 t = 5(1.0000 - 0.1715) * 1.0000 * 0.3667 = 1.5191 sq. in. A2 Formula 2 = 2(tn - trn) fr2 (2.5 tn + te) = 2(1.0000 - 0.1715) * 1.0000 * (2.5 * 1.0000 + 0.3750) = 4.7639 sq. in. A2 = Smaller value of A2 Formula 1 and A2 Formula 2	= 1.5191 sq. in.
A3 = Smaller value of the following : 5 * t * ti * fr2 = 5 * 0.3667 * 0.8750 * 1.0000 = 1.6043 sq. in. 5 * ti * ti * fr2 = 5 * 0.8750 * 0.8750 * 1.0000 = 3.8281 sq. in. 2 * h * ti * fr2 = 2 * 0.0000 * 0.8750 * 1.0000= 0.0000 sq. in.	= 0.0000 sq. in.
A41 = (leg)² * fr3 = (0.3750)² * 1.0000	= 0.1406 sq. in.
A42 = Allowable Weld 42 area * fr4 = 0.0000 * 1.0000	= 0.0000 sq. in.
A43 = (leg)² * fr2 = 0 * 1.0000	= 0.0000 sq. in.
A5 = (Dp - d - 2tn) te fr4 = (13.1250 - 8.7500 - 2 * 1.0000) * 0.3750 * 1.0000	= 0.8906 sq. in.
Area Available (Internal Pressure) = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 2.6693 sq. in., which is greater than A (1.9804)	

Bidell Equipment, Inc.

Nozzle 1

Job No: 03-248

Number: 1

ID Number: 1

Vessel Number: 03-248-521

Mark Number: N1

Date Printed: 5/6/2004

Nozzle Weld Strength Calculations

Attachment Weld Strength per Paragraph UW-16

Weld 41 tmin = smaller of 0.75, te, or tn = smaller of 0.75, 0.3750, or 1.0000 = 0.3750 in.

Weld 41 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + \text{ext. CA}}{0.7} = \frac{0.2500}{0.7} = 0.3571 \text{ in.}$

Weld 41, actual weld leg = 0.3750 in.

Weld 42 tmin = smaller of 0.75, t, or te = smaller of 0.75, 0.3667, or 0.3750 = 0.3667 in.

Weld 42 Leg min. = $\frac{0.5 * t_{\min} + \text{ext. CA}}{0.7} = \frac{0.5 * 0.3667 + 0.0000}{0.7} = 0.2619 \text{ in.}$

Weld 42, actual weld leg = 0.3125 in.

Unit Stresses per Paragraphs UG-45(c) and UW-15

Nozzle wall in shear = 0.70 * Sn = 0.70 * 17100 = 11970 PSI

Upper fillet, Weld 41, in shear = 0.49 * Material Stress = 0.49 * 17100 = 8379 PSI

Vessel groove weld, in tension = 0.74 * Material Stress = 0.74 * 17100 = 12654 PSI

Outer fillet, Weld 42, in shear = 0.49 * Material Stress = 0.49 * 17100 = 8379 PSI

Repad groove weld, in tension = 0.74 * Material Stress = 0.74 * 17100 = 12654 PSI

Strength of Connection Elements

Nozzle wall in shear = $\frac{1}{2} * \pi * \text{mean nozzle diameter} * t_n * \text{Nozzle wall in shear unit stress} = \frac{1}{2} * \pi * 9.7500 * 1.0000 * 11970 = 183200 \text{ lb.}$

Upper fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{upper fillet in shear unit stress} = \frac{1}{2} * \pi * 10.7500 * 0.3750 * 8379 = 53000 \text{ lb.}$

Groove Weld in Tension = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{groove depth} * \text{groove weld tension unit stress} = \frac{1}{2} * \pi * 10.7500 * 0.3667 * 12654 = 78300 \text{ lb.}$

Outer fillet in shear = $\frac{1}{2} * \pi * \text{Plate OD} * \text{weld leg} * \text{outer fillet in shear unit stress} = \frac{1}{2} * \pi * 14.8750 * 0.3125 * 8379 = 61200 \text{ lb.}$

Repad groove weld = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{Groove Depth} * \text{repad groove weld in tension unit stress} = \frac{1}{2} * \pi * 10.7500 * 0.3750 * 12654 = 80100 \text{ lb.}$

Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)

W = [A - A1 + 2 tn fr1(E1t - Ftr)] Sv = [2.9706 - 0.2380 + 2 * 1.0000 * 1.0000 * (1.00 * 0.3667 - 1.0000 * 0.3395)] * 17100 = 47700 lb.

W1-1 = (A2 + A5 + A41 + A42) * Sv = (1.5191 + 1.5469 + 0.1406 + 0.0977) * 17100 = 56500 lb.

W2-2 = (A2 + A3 + A41 + A43 + 2 tn t fr1) Sv = (1.5191 + 0.0000 + 0.1406 + 0.0000 + 2 * 1.0000 * 0.3667 * 1.0000) * 17100 = 40900 lb.

W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2 tn t fr1) * Sv = (1.5191 + 0.0000 + 1.5469 + 0.1406 + 0.0977 + 0.0000 + 2 * 1.0000 * 0.3667 * 1.0000) * 17100 = 69000 lb.

Check Strength Paths

Path 1-1 = Outer fillet in shear + Nozzle wall in shear = 61200 + 183200 = 244400 lb.

Path 2-2 = Upper fillet in shear + Repad groove weld + Groove weld in tension + Inner fillet in shear = 53000 + 80100 + 78300 + 0 = 211400 lb.

Path 3-3 = Outer fillet in shear + Inner fillet in shear + Groove weld in tension = 61200 + 0 + 78300 = 139500 lb.

Plate Strength = A5 * Sp = 1.5469 * 17100 = 26452 lb.

Outer fillet weld strength(61200) is greater than plate strength(26452).

Bidell Equipment, Inc.
Nozzle 2

Vessel Number: 03-248-521
Mark Number: N2

Job No: 03-248
Number: 2
D Number: 2

Date Printed: 5/6/2004

Nozzle Design Information

Design Pressure:	655.00 PSI	Design Temperature:	300 °F
Static Head:	0.00 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	6.0000 in.	Allowable Stress at Design Temperature (S _n):	17100 PSI
Internal Projection:	0.5000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.1250 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Passes through a Category A Joint:	No
Nozzle Pipe Size:	6	Nozzle Pipe Schedule:	160
Nozzle ID (new):	5.1890 in.	Nozzle Wall Thickness(new):	0.7180 in.
Nozzle ID (corroded):	5.4390 in.	Nozzle Wall Thickness(corroded):	0.5930 in.
Outer "h" Limit:	0.7813 in.	Upper Weld Leg Size(Weld 41):	0.5000 in.
Internal "h" Limit:	0.7813 in.	Internal Weld Leg Size(Weld 43):	0.5000 in.
OD, Limit of Reinforcement:	10.8780 in.	Outside Groove Weld Depth:	0.5000 in.


Minimum Design Metal Temperature

Minimum Design Metal Temperature: -20 °F
Material is exempt from impact testing per UG-20(f), 1 through 5

Host Component: Head 1 - Head 1

Material:	SA-516 Gr 70	Head wall thickness(new):	0.5000 in.
Material Stress(S _y):	20000 PSI	Head wall thickness - thin out (corroded):	0.3125 in.

Nozzle Detail Information



Upper Weld Leg Size(Weld 41): 0.5000 in.

Internal Weld Leg Size(Weld 43): 0.5000 in.

Nozzle Wall Thickness(t_n): 0.7180 in.

Outside Groove Weld Depth: 0.5000 in.

Fig. UW-16.1 (c)

Nozzle passes through the vessel, attached by a groove weld.
Pipe Size: 6 Schedule: 160
Nozzle is adequate for UG-45 requirements.
Opening is adequately reinforced for Internal Pressure.
Weld Strength Paths are adequate.

Bidell Equipment, Inc.		
Nozzle 2		
Job No: 03-248	Vessel Number: 03-248-521	
Number: 2	Mark Number: N2	
ID Number: 2		
Date Printed: 5/6/2004		

Required Head Thickness per Paragraph UG-37(a)

$$tr = \frac{P K1 Do}{(2SE + 0.8P)} = \frac{655.00 * 0.9000 * 18.0000}{(2 * 20000 * 1 + 0.8 * 655.00)} = 0.2618 \text{ in.}$$

Nozzle Required Thickness Calculations

Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)

$$trn = \frac{PRn}{SE - 0.6P} = \frac{655.00 * 2.7195}{17100 * 1 - 0.6 * 655.00} = 0.1066 \text{ in.}$$

Strength Reduction Factors

$$fr1 = \frac{Sn}{Sv} = \frac{17100}{20000} = 0.8550$$
$$fr2 = \frac{Sn}{Sv} = \frac{17100}{20000} = 0.8550$$
$$fr3 = \frac{Sn}{Sv} = \frac{17100}{20000} = 0.8550$$

UG-45 Thickness Calculations

Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)

$$t = \frac{PRn}{SE - 0.6P} + Ca + \text{ext. Ca} = \frac{655.00 * 2.7195}{17100 * 1.00 - 0.6 * 655.00} + 0.1250 + 0.0000 = 0.2316 \text{ in.}$$

Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)

$$t = \frac{P K Do}{(2SE + 2P(K - 0.1))} + Ca + \text{ext. Ca} = \frac{655.00 * 1.0000 * 18.0000}{(2 * 20000 * 1 + 2 * 655.00 * (1.0000 - 0.1))} + 0.1250 + 0.0000 = 0.4113 \text{ in.}$$

Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)

$$t = \text{minimum thickness of standard wall pipe} + Ca + \text{ext. Ca} = 0.3700 \text{ in.}$$

Nozzle Minimum Thickness per Paragraph UG-45(b)

$$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)} = 0.3700 \text{ in.}$$

Bidell Equipment, Inc.
Nozzle 2

Job No: 03-248
Number: 2
D Number: 2

Vessel Number: 03-248-521
Mark Number: N2

Date Printed: 5/6/2004

Nozzle Reinforcement Calculations

Area Required for Internal Pressure

$A = d \text{ tr } F + 2 \text{ tn tr } F (1 - fr1) = (5.4390 * 0.2618 * 1.00) + (2 * 0.5930 * 0.2618 * 1.00 * (1 - 0.8550)) = 1.4690 \text{ sq. in.}$

Area Available - Internal Pressure

$A1 \text{ Formula 1} = d(E1 \text{ t} - F \text{ tr}) - 2 \text{ tn}(E1 \text{ t} - F \text{ tr})(1 - fr1) = 5.4390 * (1.00 * 0.3125 - 1.00 * 0.2618) - 2 * 0.5930 * (1.00 * 0.3125 - 1.00 * 0.2618) * (1 - 0.8550) = 0.2670 \text{ sq. in.}$

$A1 \text{ Formula 2} = 2(t + \text{tn})(E1 \text{ t} - F \text{ tr}) - 2 \text{ tn}(E1 \text{ t} - F \text{ tr})(1 - fr1) = 2 * (0.3125 + 0.5930)(1.00 * 0.3125 - 1.00 * 0.2618) - 2 * 0.5930 * (1.00 * 0.3125 - 1.00 * 0.2618) * (1 - 0.8550) = 0.0831 \text{ sq. in.}$

$A1 = \text{Larger value of } A1 \text{ Formula 1 and } A1 \text{ Formula 2} = 0.2670 \text{ sq. in.}$

$A2 \text{ Formula 1} = 5(\text{tn} - \text{trn}) \text{ fr2 t} = 5(0.5930 - 0.1066) * 0.8550 * 0.3125 = 0.6498 \text{ sq. in.}$

$A2 \text{ Formula 2} = 5(\text{tn} - \text{trn}) \text{ fr2 tn} = 5(0.5930 - 0.1066) * 0.8550 * 0.5930 = 1.2331 \text{ sq. in.}$

$A2 = \text{Smaller value of } A2 \text{ Formula 1 and } A2 \text{ Formula 2} = 0.6498 \text{ sq. in.}$

A3 = Smaller value of the following :

$5 * t * t_i * f_{r2} = 5 * 0.3125 * 0.4680 * 0.8550 = 0.6252 \text{ sq. in.}$

$5 * t_i * t_i * f_{r2} = 5 * 0.4680 * 0.4680 * 0.8550 = 0.9363 \text{ sq. in.}$

$2 * h * t_i * f_{r2} = 2 * 0.3750 * 0.4680 * 0.8550 = 0.3001 \text{ sq. in.}$

$= 0.3001 \text{ sq. in.}$

$A41 = (\text{leg})^2 * \text{fr2} = (0.5000)^2 * 0.8550$

$= 0.2138 \text{ sq. in.}$

$A43 = (\text{leg})^2 * \text{fr2} = (0.3214)^2 * 0.8550$

$= 0.0883 \text{ sq. in.}$

$\text{Area Available (Internal Pressure)} = A1 + A2 + A3 + A41 + A43 = 1.5190 \text{ sq. in.}, \text{ which is greater than } A (1.4690)$

Bidell Equipment, Inc.		
Nozzle 2		
Job No: 03-248	Vessel Number: 03-248-521	
Number: 2	Mark Number: N2	
Number: 2		
Date Printed: 5/6/2004		
Nozzle Weld Strength Calculations		
Attachment Weld Strength per Paragraph UW-16		
Weld 41 tmin = smaller of 0.75, t, or tn = smaller of 0.75, 0.3125, or 0.5930		= 0.3125 in.
Weld 41 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + \text{ext. CA}}{0.7} = \frac{0.2188}{0.7}$		= 0.3125 in.
	Weld 41, actual weld leg = 0.5000 in.	
Weld 43 tmin = smaller of 0.75, t, or tn = smaller of 0.75, 0.3125, or 0.5930		= 0.3125 in.
Weld 43 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + ca}{0.7} = \frac{(\text{smaller of } 0.25 \text{ or } (0.3125 * 0.7)) + 0.1250}{0.7} = \frac{0.3438}{0.7}$		= 0.4911 in.
	Weld 43, actual weld leg = 0.5000 in.	
Unit Stresses per Paragraphs UG-45(c) and UW-15		
Nozzle wall in shear = 0.70 * Sn = 0.70 * 17100		= 11970 PSI
Upper fillet, Weld 41, in shear = 0.49 * Material Stress = 0.49 * 17100		= 8379 PSI
Vessel groove weld, in tension = 0.74 * Material Stress = 0.74 * 17100		= 12654 PSI
Inner fillet, Weld 43, in shear = 0.49 * Material Stress = 0.49 * 17100		= 8379 PSI
Strength of Connection Elements		
Nozzle wall in shear = $\frac{1}{2} * \pi * \text{mean nozzle diameter} * t_n * \text{Nozzle wall in shear unit stress} = \frac{1}{2} * \pi * 6.0320 * 0.5930 * 11970$		= 67200 lb.
Upper fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{upper fillet in shear unit stress} = \frac{1}{2} * \pi * 6.6250 * 0.5000 * 8379$		= 43600 lb.
Groove Weld in Tension = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{groove depth} * \text{groove weld tension unit stress} = \frac{1}{2} * \pi * 6.6250 * 0.5000 * 12654$		= 65800 lb.
Inner fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{inner fillet in shear unit stress} = \frac{1}{2} * \pi * 6.6250 * 0.3214 * 8379$		= 28000 lb.
Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)		
W = [A - A1 + 2 tn fr1(E1t - Ftr)] Sv = [1.4690 - 0.2670 + 2 * 0.5930 * 0.8550 * (1.00 * 0.3125 - 1.0000 * 0.2618)] * 20000		= 25100 lb.
W1-1 = (A2 + A5 + A41 + A42) * Sv = (0.6498 + 0.0000 + 0.2138 + 0.0000) * 20000		= 17300 lb.
W2-2 = (A2 + A3 + A41 + A43 + 2 tn t fr1) Sv = (0.6498 + 0.3001 + 0.2138 + 0.0883 + 2 * 0.5930 * 0.3125 * 0.8550) * 20000		= 31400 lb.
W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2 tn t fr1) * Sv = (0.6498 + 0.3001 + 0.0000 + 0.2138 + 0.0000 + 0.0883 + 2 * 0.5930 * 0.3125 * 0.8550) * 20000		= 31400 lb.
Check Strength Paths		
Path 1-1 = Upper fillet in shear + Nozzle wall in shear = 43600 + 67200		= 110800 lb.
Path 2-2 = Upper fillet in shear + Groove weld in tension + Inner fillet in shear = 43600 + 65800 + 28000		= 137400 lb.
Path 3-3 = Upper fillet in shear + Inner fillet in shear + Groove weld in tension = 43600 + 28000 + 65800		= 137400 lb.

MDMT Report by Components				
Design MDMT is -20 °F				
<u>Component</u>	<u>Material</u>	<u>Curve</u>	<u>Pressure</u>	<u>MDMT</u>
Shell 1	SA-106 Gr B			Exempt per UG-20(f), 1-5
Nozzle 1	SA-106 Gr B			Exempt per UG-20(f), 1-5
Head 1	SA-516 Gr 70			Exempt per UG-20(f), 1-5
Nozzle 2	SA-106 Gr B			Exempt per UG-20(f), 1-5

The required design MDMT of -20 °F has been met or exceeded for the calculated MDMT values.

ANSI Flanges Are Not Included in MDMT Calculations.

18" O.D. x 66" S/S

Vessel Number: 03-248-521

Date Printed: 5/6/2004

<u>Component</u>	<u>Design Pressure</u>	<u>Static Head</u>	<u>Vessel MAWP</u> <u>New & Cold</u> <u>UG-98(a)</u>	<u>Component MAWP</u> <u>Hot & Corroded</u> <u>UG-98(b)</u>	<u>Vessel MAWP</u> <u>Hot & Corroded</u> <u>UG-98(a)</u>
Shell 1	655.00 PSI	0.00 PSI	929.99 PSI	708.27 PSI	708.27 PSI
Nozzle 1	655.00 PSI	0.00 PSI	929.99 PSI	708.37 PSI	708.37 PSI
Head 1	655.00 PSI	0.00 PSI	1016.70 PSI	665.91 PSI	665.91 PSI
Nozzle 2	655.00 PSI	0.00 PSI	1034.16 PSI	665.91 PSI	665.91 PSI
NC = Not Calculated Inc = Incomplete					

Component with the lowest vessel MAWP(New & Cold) : Shell 1	
The lowest vessel MAWP(New & Cold) :	929.99 PSI
Component with the lowest vessel MAWP(Hot & Corroded) : Head 1	
The lowest vessel MAWP(Hot & Corroded) :	665.91 PSI
Pressures are exclusive of any external loads.	

Summary Information		
	<u>Dry Weight</u>	<u>Flooded Weight</u>
Shell	575.06 lb.	1109.02 lb.
Head	62.79 lb.	102.41 lb.
Nozzle	98.38 lb.	98.38 lb.
Totals	736.23 lb.	1309.80 lb.
	<u>Volume</u>	
Shell	63.92 Gal.	
Head	4.75 Gal.	
Nozzle	3.08 Gal.	
Totals	71.74 Gal.	
	<u>Area</u>	
Shell	25.92 Sq. Ft.	
Head	3.08 Sq. Ft.	
Nozzle	3.85 Sq. Ft.	
Totals	32.85 Sq. Ft.	

Hydrostatic Test Information (UG-99)

Gauge at Top

Component with controlling ratio is : Shell 1
Component with controlling pressure is : Shell 1

Calculated Test Pressure = $P * 1.3 * \frac{\text{Cold Stress}}{\text{Hot Stress}}$ = $655.00 * 1.3 * \frac{17100}{17100}$ = 851.50 PSI

Job Number: 03-248-523
Calculation Package Revision Level: 0

DESIGN CALCULATIONS INDEX

Calculation Description	Applicable		Pages	Rev. Level
	Yes	No		
Primary Membrane Stress Calcs. (Computer Design Pgm.)	✓		1-10	0
Lifting Lug Calculations		✓		
Horizontal Vessel Saddle Calculations		✓		
Vertical Vessel Skirt Calculations		✓		
Other UG-22 Specified Loadings		✓		
Vessel Impact Testing Exemption Summary	✓		1-10	0

DESIGN CALCULATIONS REVISION CONTROL AND APPROVAL

¹ Drawing No. & Rev. Level	Calc. Package Rev. Level	Revised Calcs. Required	Approval	Date

New design

¹ Whenever new drawings are issued that pertain to the calculation package, or whenever drawings are revised, the current calculations shall be verified and approved as applicable or revised as necessary and approved.

Date Printed: 5/6/2004

VESSEL DESCRIPTION

16" O.D. x 30" S/S

Vessel designed per the ASME Boiler & Pressure Vessel Code,
Section VIII Division 1, 2001 Edition, 2003 Addenda
with Advanced Pressure Vessel, Version: 8.2.1
Vessel is ASME Code Stamped

Job No: 03-248

Vessel Number: 03-248-523

NAMEPLATE INFORMATION

MAWP: 1970.00 PSI
MDMT: -20 °F at 1970.00 PSI
Serial Number(s): 03-248-523
Year Built: 2004
Radiography: RT 1
Postweld Heat Treated: HT
Construction Types: W

Notes

All applicable UG-22 loadings have been considered in this design

Signatures

Engineering:  Date: MAY 06 2004
Mike Fudge

Revision No.:  Date: MAY 06 2004

Table of Contents

Shell 1	1
Lead 1	2
MDMT Summary	3
MAWP Summary	4
Summary Information	5

Bidell Equipment, Inc.

Shell 1

Job No: 03-248
Number: 1

Vessel Number: 03-248-523
Mark Number: S1

Date Printed: 5/6/2004

Cylindrical Shell Design Information

Design Pressure:	1970.00	PSI	Design Temperature:	300	°F
Static Head:	0.00	PSI	Joint Efficiency:	100	%
Shell Material:	SA-106 Gr C		Factor B Chart:	CS-2	
Shell Length:	30.0000	in.	Material Stress (hot):	20000	PSI
Corrosion Allowance:	0.1250	in.	Material Stress (cold):	20000	PSI
External Corrosion Allowance:	0.0000	in.	Actual Circumferential Stress:	19493	PSI
Outside Diameter (new):	16.0000	in.	Actual Longitudinal Stress:	8598	PSI
Outside Diameter (corroded):	16.0000	in.			
Shell Surface Area:	10.47	Sq. Ft.	Specific Gravity:	1.00	
Shell Estimated Volume:	19.82	Gal.	Weight of Fluid:	165.56	lb.
			Total Flooded Shell Weight:	577.19	lb.
			Shell Weight:	411.63	lb.

Minimum Design Metal Temperature Data

Minimum Design Metal Temperature: -20 °F
Material is exempt from impact testing per UG-20(f), 1 through 5

Design Thickness Calculations

Longitudinal Stress Calculations per Paragraph UG-27(c)(2)

$$t = \frac{PR}{2SE + 0.4P} = \frac{1970.00 * 7.0940}{2 * 20000 * 1.00 + 0.4 * 1970.00} = 0.3426 + 0.1250 \text{ (corrosion)} + 0.0000 \text{ (ext. corrosion)} + 0.0668 \text{ (12 1/2\% for pipe)}$$

= minimum of **0.5344** in.

Circumferential Stress Calculations per Appendix 1-1(a)(1)

$$t = \frac{PR_o}{SE + 0.4P} = \frac{1970.00 * 8.0000}{20000 * 1.00 + 0.4 * 1970.00} = 0.7582 + 0.1250 \text{ (corrosion)} + 0.0000 \text{ (ext. corrosion)} + 0.1262 \text{ (12 1/2\% for pipe)} = \text{minimum of } 1.0094 \text{ in.}$$

MAWP for this Shell Section Only

$$P = \frac{SEt}{R_o - 0.4t} = \frac{20000 * 1.00 * 0.7771}{8.0000 - 0.4 * 0.7771} = \text{maximum design pressure of } 2021.29 \text{ PSI}$$

External loads do not control design.

Pipe Selected: Size = **16 in.**, Schedule = **100**, Diameter = **16.0000** in., Wall = **1.0310** in.

Bidell Equipment, Inc.
Head 1

Job No: 03-248
Number: 1

Vessel Number: 03-248-523
Mark Number: H1

Date Printed: 5/6/2004

Ellipsoidal Head Design Information

Design Pressure:	1970.00 PSI	Design Temperature:	300 °F
Static Head:	0.00 PSI	Joint Efficiency:	100 %
Head Material:	SA-516 Gr 70	Factor B Chart:	CS-2
Material Condition:	Normalized	Material Stress (hot):	20000 PSI
Corrosion Allowance:	0.1250 in.	Material Stress (cold):	20000 PSI
External Corrosion Allowance:	0.0000 in.	Actual Head Stress:	19240 PSI
Head Location:	Right	Straight Flange :	2.0000 in.
Outside Diameter :	16.0000 in.	Head Depth (ho) :	4.5000 in.
Thin Out :	0.1250 in.		
K = $\frac{1}{6}[2 + (D/2h)^2]$:	1.00		
Head Surface Area:	2.36 Sq. Ft.	Specific Gravity:	1.00
Head Estimated Volume:	2.89 Gal.	Weight of Fluid:	24.09 lb.
Head Weight:	96.08 lb.	Total Flooded Head Weight:	120.16 lb.

Minimum Design Metal Temperature Data

Minimum Design Metal Temperature: -20 °F
Material is exempt from impact testing per UG-20(f), 1 through 5

Design Thickness Calculations

Design Thickness Calculations per Appendix 1-4(c)

$$\frac{PD_oK}{2SE + 2P(K - 0.1)} = \frac{1970.00 * 16.0000 * 1.00}{2 * 20000 * 1.00 + 2 * 1970.00 * (1.00 - 0.1)} = 0.7239 + 0.1250_{\text{(corrosion)}} + 0.0000_{\text{(ext. corrosion)}} + 0.1250_{\text{(thin out)}}$$

= minimum of **0.9739** in.

Extreme Fiber Elongation Calculation per Paragraph UCS-79

$$\text{elongation} = \frac{75t}{R_f} = \frac{75 * 1.0000}{2.5500} = \text{elongation of } \mathbf{29.40} \%$$

MAWP per UG-32 for this Head Only

$$P = \frac{2SEt}{KD_o - 2t(K - 0.1)} = \frac{2 * 20000 * 1.00 * 0.7500}{1.00 * 16.0000 - 2 * 0.7500 * (1.00 - 0.1)} = \mathbf{2047.78} \text{ PSI}$$

External loads do not control design.

Nominal Head Thickness Selected = **1.0000** in.
Minimum Thickness after forming = **0.8750** in.

Bidell Equipment, Inc.

Nozzle 1

Job No: 03-248

Number: 1

ID Number: 1

Vessel Number: 03-248-523

Mark Number: N1

Date Printed: 5/6/2004

Nozzle Design Information

Design Pressure:	1970.00	PSI	Design Temperature:	300	°F
Static Head:	0.00	PSI	Nozzle Efficiency (E):	100	%
Nozzle Material:	SA-106 Gr B		Joint Efficiency (E ₁):	1.00	
			Factor B Chart:	CS-2	
External Projection:	6.0000	in.	Allowable Stress at Design Temperature (S _n):	17100	PSI
Internal Projection:	0.5000	in.	Allowable Stress at Ambient Temperature:	17100	PSI
Inside Corrosion Allowance:	0.1250	in.	Correction Factor (F):	1.00	
External Corrosion Allowance:	0.0000	in.	Passes through a Category A Joint:	No	
Nozzle Pipe Size:	3		Nozzle Pipe Schedule:	XXH	
Nozzle ID (new):	2.3000	in.	Nozzle Wall Thickness(new):	0.6000	in.
Nozzle ID (corroded):	2.5500	in.	Nozzle Wall Thickness(corroded):	0.4750	in.
Outer "h" Limit:	1.5625	in.	Upper Weld Leg Size(Weld 41):	0.6250	in.
Internal "h" Limit:	0.8750	in.	Internal Weld Leg Size(Weld 43):	0.5000	in.
OD, Limit of Reinforcement:	5.1000	in.	Outside Groove Weld Depth:	1.0310	in.

Minimum Design Metal Temperature

Minimum Design Metal Temperature: -20 °F
Material is exempt from impact testing per UG-20(f), 1 through 5

Reinforcing Pad Information

Reinforcing Material:	SA-106 Gr B	Allowable Stress at Design Temperature(S _p):	17100	PSI
		Allowable Stress at Ambient Temperature:	17100	PSI
Reinforcing Plate Thickness(t _e):	0.3750 in.	Repad to Vessel Weld Leg Size(Weld 42):	0.3125	in.
OD, Reinforcing Plate(D _p):	7.6250 in.	Repad to Nozzle Groove Weld Depth:	0.3750	in.

Host Component: Shell 1 - Shell 1

Material:	SA-106 Gr C	Shell wall thickness(new):	1.0310	in.
Material Stress(S _v):	20000	Shell wall thickness - 12 1/2% for pipe (corroded):	0.7771	in.

Nozzle Detail Information




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41):	0.6250 in.
Internal Weld Leg Size(Weld 43):	0.5000 in.
Nozzle Wall Thickness(t _n):	0.6000 in.
Outside Groove Weld Depth:	1.0310 in.
Repad to Vessel Weld Leg Size(Weld 42):	0.3125 in.
Repad Thickness(t _e):	0.3750 in.

Nozzle passes through the vessel, attached by a groove weld.
Pipe Size: 3 Schedule: XXH
Nozzle is adequate for UG-45 requirements.
Opening is adequately reinforced for Internal Pressure.
Weld Strength Paths are adequate.

Nozzle 1

Number: 1

Mark Number: N1

Nozzle Reinforcement Calculations

Area Available - Internal Pressure

Area Available (Internal Pressure) = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 2.0530 sq. in., which is **greater** than A (2.0376)

Bidell Equipment, Inc. Nozzle 1		
Job No: 03-248 Number: 1 ID Number: 1	Vessel Number: 03-248-523 Mark Number: N1	
Date Printed: 5/6/2004		
Nozzle Weld Strength Calculations		
Attachment Weld Strength per Paragraph UW-16		
Weld 41 tmin = smaller of 0.75, te, or tn = smaller of 0.75, 0.3750, or 0.4750		= 0.3750 in.
Weld 41 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + \text{ext. CA}}{0.7} = \frac{0.2500}{0.7}$		= 0.3571 in.
	Weld 41, actual weld leg = 0.6250 in.	
Weld 42 tmin = smaller of 0.75, t, or te = smaller of 0.75, 0.7771, or 0.3750		= 0.3750 in.
Weld 42 Leg min. = $\frac{0.5 * t_{\min} + \text{ext. CA}}{0.7} = \frac{0.5 * 0.3750 + 0.0000}{0.7}$		= 0.2679 in.
	Weld 42, actual weld leg = 0.3125 in.	
Weld 43 tmin = smaller of 0.75, t, or tn = smaller of 0.75, 0.7771, or 0.4750		= 0.4750 in.
Weld 43 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + ca}{0.7} = \frac{(\text{smaller of } 0.25 \text{ or } (0.4750 * 0.7)) + 0.1250}{0.7} = \frac{0.3750}{0.7}$		= 0.5357 in.
	Weld 43, actual weld leg = 0.5000 in.	
Unit Stresses per Paragraphs UG-45(c) and UW-15		
Nozzle wall in shear = 0.70 * Sn = 0.70 * 17100		= 11970 PSI
Upper fillet, Weld 41, in shear = 0.49 * Material Stress = 0.49 * 17100		= 8379 PSI
Vessel groove weld, in tension = 0.74 * Material Stress = 0.74 * 17100		= 12654 PSI
Inner fillet, Weld 43, in shear = 0.49 * Material Stress = 0.49 * 17100		= 8379 PSI
Outer fillet, Weld 42, in shear = 0.49 * Material Stress = 0.49 * 17100		= 8379 PSI
Repad groove weld, in tension = 0.74 * Material Stress = 0.74 * 17100		= 12654 PSI
Strength of Connection Elements		
Nozzle wall in shear = $\frac{1}{2} * \pi * \text{mean nozzle diameter} * t_n * \text{Nozzle wall in shear unit stress} = \frac{1}{2} * \pi * 3.0250 * 0.4750 * 11970$		= 27000 lb.
Upper fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{upper fillet in shear unit stress} = \frac{1}{2} * \pi * 3.5000 * 0.6250 * 8379$		= 28800 lb.
Groove Weld in Tension = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{groove depth} * \text{groove weld tension unit stress} = \frac{1}{2} * \pi * 3.5000 * 1.0310 * 12654$		= 71700 lb.
Inner fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{inner fillet in shear unit stress} = \frac{1}{2} * \pi * 3.5000 * 0.3214 * 8379$		= 14800 lb.
Outer fillet in shear = $\frac{1}{2} * \pi * \text{Plate OD} * \text{weld leg} * \text{outer fillet in shear unit stress} = \frac{1}{2} * \pi * 7.6250 * 0.3125 * 8379$		= 31300 lb.
Repad groove weld = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{Groove Depth} * \text{repad groove weld in tension unit stress} = \frac{1}{2} * \pi * 3.5000 * 0.3750 * 12654$		= 26100 lb.
Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)		
W = [A - A1 + 2 tn fr1(E1t - Ftr)] Sv = [2.0376 - 0.0458 + 2 * 0.4750 * 0.8550 * (1.00 * 0.7771 - 1.0000 * 0.7581)] * 20000		= 40100 lb.
W1-1 = (A2 + A5 + A41 + A42) * Sv = (0.8475 + 0.5130 + 0.3340 + 0.0000) * 20000		= 33900 lb.
W2-2 = (A2 + A3 + A41 + A43 + 2 tn t fr1) Sv = (0.8475 + 0.2244 + 0.3340 + 0.0883 + 2 * 0.4750 * 0.7771 * 0.8550) * 20000		= 42500 lb.
W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2 tn t fr1) * Sv = (0.8475 + 0.2244 + 0.5130 + 0.3340 + 0.0000 + 0.0883 + 2 * 0.4750 * 0.7771 * 0.8550) * 20000		= 52800 lb.
Check Strength Paths		
Path 1-1 = Outer fillet in shear + Nozzle wall in shear = 31300 + 27000		= 58300 lb.
Path 2-2 = Upper fillet in shear + Repad groove weld + Groove weld in tension + Inner fillet in shear = 28800 + 26100 + 71700 + 14800		= 141400 lb.
Path 3-3 = Outer fillet in shear + Inner fillet in shear + Groove weld in tension = 31300 + 14800 + 71700		= 117800 lb.

Bidell Equipment, Inc.		
Nozzle 1		
Job No: 03-248		Vessel Number: 03-248-523
Number: 1		Mark Number: N1
Number: 1		
Date Printed: 5/6/2004		

Plate Strength = $A5 * Sp = 0.5130 * 17100$	= 8772 lb.
Outer fillet weld strength(31300) is greater than plate strength(8772).	

Bidell Equipment, Inc.
Nozzle 2

Vessel Number: 03-248-523
Mark Number: N2

Job No: 03-248
Number: 2
D Number: 2

Date Printed: 5/6/2004

Nozzle Design Information

Design Pressure:	1970.00	PSI	Design Temperature:	300	°F
Static Head:	0.00	PSI	Nozzle Efficiency (E):	100	%
Nozzle Material:	SA-106 Gr B		Joint Efficiency (E ₁):	1.00	
			Factor B Chart:	CS-2	
External Projection:	6.0000	in.	Allowable Stress at Design Temperature (S _n):	17100	PSI
Internal Projection:	0.6250	in.	Allowable Stress at Ambient Temperature:	17100	PSI
Inside Corrosion Allowance:	0.1250	in.	Correction Factor (F):	1.00	
External Corrosion Allowance:	0.0000	in.	Passes through a Category A Joint:	No	
Nozzle Pipe Size:	6		Nozzle Pipe Schedule:	XXH	
Nozzle ID (new):	4.8970	in.	Nozzle Wall Thickness(new):	0.8640	in.
Nozzle ID (corroded):	5.1470	in.	Nozzle Wall Thickness(corroded):	0.7390	in.
Outer "h" Limit:	1.9428	in.	Upper Weld Leg Size(Weld 41):	0.6250	in.
Internal "h" Limit:	1.5350	in.	Internal Weld Leg Size(Weld 43):	0.6250	in.
OD, Limit of Reinforcement:	10.2940	in.	Outside Groove Weld Depth:	1.0310	in.

Minimum Design Metal Temperature

Minimum Design Metal Temperature: -20 °F
Material is exempt from impact testing per UG-20(f), 1 through 5

Reinforcing Pad Information

Reinforcing Material:	SA-106 Gr B	Allowable Stress at Design Temperature(S _p):	17100	PSI
		Allowable Stress at Ambient Temperature:	17100	PSI
Reinforcing Plate Thickness(t _e):	0.5000	Repad to Vessel Weld Leg Size(Weld 42):	0.3750	in.
OD, Reinforcing Plate(D _p):	10.7500	Repad to Nozzle Groove Weld Depth:	0.5000	in.

Host Component: Shell 1 - Shell 1

Material:	SA-106 Gr C	Shell wall thickness(new):	1.0310	in.
Material Stress(S _v):	20000	Shell wall thickness - 12½% for pipe (corroded):	0.7771	in.

Nozzle Detail Information




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41):	0.6250	in.
Internal Weld Leg Size(Weld 43):	0.6250	in.
Nozzle Wall Thickness(t _n):	0.8640	in.
Outside Groove Weld Depth:	1.0310	in.
Repad to Vessel Weld Leg Size(Weld 42):	0.3750	in.
Repad Thickness(t _e):	0.5000	in.

Nozzle passes through the vessel, attached by a groove weld.
Pipe Size: 6 Schedule: XXH
Nozzle is adequate for UG-45 requirements.
Opening is adequately reinforced for Internal Pressure.
Weld Strength Paths are adequate.

Job No: 03-248 Number: 2 ID Number: 2			Bidell Equipment, Inc. Nozzle 2			Vessel Number: 03-248-523 Mark Number: N2			Date Printed: 5/6/2004		
Required Shell Thickness per Paragraph UG-37(a)											
$tr = \frac{PR_o}{SE + 0.4P} = \frac{1970.00 * 8.0000}{20000 * 1 + 0.4 * 1970.00}$						= 0.7581 in.					
Nozzle Required Thickness Calculations											
Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)											
$trn = \frac{PR_n}{SE - 0.6P} = \frac{1970.00 * 2.5735}{17100 * 1 - 0.6 * 1970.00}$						= 0.3185 in.					
Strength Reduction Factors											
$fr1 = \frac{S_n}{S_v} = \frac{17100}{20000} = 0.8550$						$fr2 = \frac{S_n}{S_v} = \frac{17100}{20000} = 0.8550$					
$fr3 = \frac{S_n}{S_v} = \frac{17100}{20000} = 0.8550$						$fr4 = \frac{S_p}{S_v} = \frac{17100}{20000} = 0.8550$					
UG-45 Thickness Calculations											
Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)											
$t = \frac{PR_n}{SE - 0.6P} + Ca + ext. Ca = \frac{1970.00 * 2.5735}{17100 * 1.00 - 0.6 * 1970.00} + 0.1250 + 0.0000$						= 0.4435 in.					
Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)											
$t = \frac{PR_o}{SE + 0.4P} + Ca + ext. Ca = \frac{1970.00 * 8.0000}{20000 * 1 + 0.4 * 1970.00} + 0.1250 + 0.0000$						= 0.8831 in.					
Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)											
$t = \text{minimum thickness of standard wall pipe} + Ca + ext. Ca$						= 0.3700 in.					
Nozzle Minimum Thickness per Paragraph UG-45(b)											
$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)}$						= 0.3700 in.					

Nozzle Reinforcement Calculations		
Area Required for Internal Pressure		
A = d tr F + 2 tn tr F (1 - fr1) = (5.1470 * 0.7581 * 1.00) + (2 * 0.7390 * 0.7581 * 1.00 * (1 - 0.8550))		= 4.0644 sq. in.
Area Available - Internal Pressure		
A1 Formula 1 = d(E1 t - F tr) - 2tn(E1 t - F tr)(1 - fr1) = 5.1470 * (1.00 * 0.7771 - 1.00 * 0.7581) - 2 * 0.7390 * (1.00 * 0.7771 - 1.00 * 0.7581) * (1 - 0.8550) = 0.0937 sq. in.		
A1 Formula 2 = 2(t + tn)(E1 t - F tr) - 2tn(E1 t - F tr)(1 - fr1) = 2 * (0.7771 + 0.7390)(1.00 * 0.7771 - 1.00 * 0.7581) - 2 * 0.7390 * (1.00 * 0.7771 - 1.00 * 0.7581) * (1 - 0.8550) = 0.0535 sq. in.		
A1 = Larger value of A1 Formula 1 and A1 Formula 2		= 0.0937 sq. in.
A2 Formula 1 = 5(tn - trn) fr2 t = 5(0.7390 - 0.3185) * 0.8550 * 0.7771 = 1.3969 sq. in.		
A2 Formula 2 = 2(tn - trn) fr2 (2.5 tn + te) = 2(0.7390 - 0.3185) * 0.8550 * (2.5 * 0.7390 + 0.5000) = 1.6880 sq. in.		
A2 = Smaller value of A2 Formula 1 and A2 Formula 2		= 1.3969 sq. in.
A3 = Smaller value of the following : 5 * t * ti * fri2 = 5 * 0.7771 * 0.6140 * 0.8550 = 2.0398 sq. in. 5 * ti * tj * fri2 = 5 * 0.6140 * 0.6140 * 0.8550 = 1.6117 sq. in. 2 * h * ti * fri2 = 2 * 0.5000 * 0.6140 * 0.8550= 0.5250 sq. in.		
		= 0.5250 sq. in.
A41 = (leg) ² * fr3 = (0.6250) ² * 0.8550		= 0.3340 sq. in.
A42 = Allowable Weld 42 area * fr4 = 0.0000 * 0.8550		= 0.0000 sq. in.
A43 = (leg) ² * fr2 = (0.4464) ² * 0.8550		= 0.1704 sq. in.
A5 = (Dp - d - 2tn) te fr4 = (10.2940 - 5.1470 - 2 * 0.7390) * 0.5000 * 0.8550		= 1.5685 sq. in.
Area Available (Internal Pressure) = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 4.0885 sq. in., which is greater than A (4.0644)		

Job No: 03-248 Number: 2 ID Number: 2		Bidell Equipment, Inc. Nozzle 2		Vessel Number: 03-248-523 Mark Number: N2	
Date Printed: 5/6/2004					
Nozzle Weld Strength Calculations					
Attachment Weld Strength per Paragraph UW-16					
Weld 41 tmin = smaller of 0.75, te, or tn = smaller of 0.75, 0.5000, or 0.7390				= 0.5000 in.	
Weld 41 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + \text{ext. CA}}{0.7}$				$= \frac{0.2500}{0.7}$ = 0.3571 in.	
				Weld 41, actual weld leg = 0.6250 in.	
Weld 42 tmin = smaller of 0.75, t, or te = smaller of 0.75, 0.7771, or 0.5000				= 0.5000 in.	
Weld 42 Leg min. = $\frac{0.5 * t_{\min} + \text{ext. CA}}{0.7}$				$= \frac{0.5 * 0.5000 + 0.0000}{0.7}$ = 0.3571 in.	
				Weld 42, actual weld leg = 0.3750 in.	
Weld 43 tmin = smaller of 0.75, t, or tn = smaller of 0.75, 0.7771, or 0.7390				= 0.7390 in.	
Weld 43 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + \text{ca}}{0.7}$				$= \frac{(\text{smaller of } 0.25 \text{ or } (0.7390 * 0.7)) + 0.1250}{0.7}$ $= \frac{0.3750}{0.7}$ = 0.5357 in.	
				Weld 43, actual weld leg = 0.6250 in.	
Unit Stresses per Paragraphs UG-45(c) and UW-15					
Nozzle wall in shear = 0.70 * Sn = 0.70 * 17100				= 11970 PSI	
Upper fillet, Weld 41, in shear = 0.49 * Material Stress = 0.49 * 17100				= 8379 PSI	
Vessel groove weld, in tension = 0.74 * Material Stress = 0.74 * 17100				= 12654 PSI	
Inner fillet, Weld 43, in shear = 0.49 * Material Stress = 0.49 * 17100				= 8379 PSI	
Outer fillet, Weld 42, in shear = 0.49 * Material Stress = 0.49 * 17100				= 8379 PSI	
Repad groove weld, in tension = 0.74 * Material Stress = 0.74 * 17100				= 12654 PSI	
Strength of Connection Elements					
Nozzle wall in shear = $\frac{1}{2} * \pi * \text{mean nozzle diameter} * t_n * \text{Nozzle wall in shear unit stress}$				= 81700 lb.	
$\frac{1}{2} * \pi * 5.8860 * 0.7390 * 11970$				= 54500 lb.	
Upper fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{upper fillet in shear unit stress}$				= 135700 lb.	
$\frac{1}{2} * \pi * 6.6250 * 0.6250 * 8379$				= 38900 lb.	
Groove Weld in Tension = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{groove depth} * \text{groove weld tension unit stress}$				= 53000 lb.	
$\frac{1}{2} * \pi * 6.6250 * 1.0310 * 12654$				= 65800 lb.	
Inner fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{inner fillet in shear unit stress}$					
$\frac{1}{2} * \pi * 6.6250 * 0.4464 * 8379$					
Outer fillet in shear = $\frac{1}{2} * \pi * \text{Plate OD} * \text{weld leg} * \text{outer fillet in shear unit stress}$					
$\frac{1}{2} * \pi * 10.7500 * 0.3750 * 8379$					
Repad groove weld = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{Groove Depth} * \text{repad groove weld in tension unit stress}$					
$\frac{1}{2} * \pi * 6.6250 * 0.5000 * 12654$					
Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)					
W = [A - A1 + 2 tn fr1(E1t - Ftr)] Sv = [4.0644 - 0.0937 + 2 * 0.7390 * 0.8550 * (1.00 * 0.7771 - 1.0000 * 0.7581)] * 20000				= 79900 lb.	
W1-1 = (A2 + A5 + A41 + A42) * Sv = (1.3969 + 1.5685 + 0.3340 + 0.0000) * 20000				= 66000 lb.	
W2-2 = (A2 + A3 + A41 + A43 + 2 tn t fr1) Sv = (1.3969 + 0.5250 + 0.3340 + 0.1704 + 2 * 0.7390 * 0.7771 * 0.8550) * 20000				= 68200 lb.	
W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2 tn t fr1) * Sv = (1.3969 + 0.5250 + 1.5685 + 0.3340 + 0.0000 + 0.1704 + 2 * 0.7390 * 0.7771 * 0.8550) * 20000				= 99500 lb.	
Check Strength Paths					
Path 1-1 = Outer fillet in shear + Nozzle wall in shear = 53000 + 81700				= 134700 lb.	
Path 2-2 = Upper fillet in shear + Repad groove weld + Groove weld in tension + Inner fillet in shear = 54500 + 65800 + 135700 + 38900				= 294900 lb.	
Path 3-3 = Outer fillet in shear + Inner fillet in shear + Groove weld in tension = 53000 + 38900 + 135700				= 227600 lb.	

Bidell Equipment, Inc.		
Nozzle 2		
Job No: 03-248		Vessel Number: 03-248-523
Number: 2		Mark Number: N2
D Number: 2		
Date Printed: 5/6/2004		

Plate Strength = $A5 * Sp = 1.5685 * 17100$	= 26821 lb.
Outer fillet weld strength(53000) is greater than plate strength(26821).	

MDMT Report by Components				
Design MDMT is -20 °F				
Component	Material	Curve	Pressure	MDMT
Shell 1	SA-106 Gr C			Exempt per UG-20(f), 1-5
Head 1	SA-516 Gr 70			Exempt per UG-20(f), 1-5

The required design MDMT of -20 °F has been met or exceeded for the calculated MDMT values.

ANSI Flanges Are Not Included in MDMT Calculations.

Job No: 03-248	Bidell Equipment, Inc. 16" O.D. x 30" S/S	Vessel Number: 03-248-523
Date Printed: 5/6/2004		

Job No: 03-248	Bidell Equipment, Inc. 16" O.D. x 30" S/S	Vessel Number: 03-248-523
Date Printed: 5/6/2004		

Job No: 03-248	Bidell Equipment, Inc. 16" O.D. x 30" S/S	Vessel Number: 03-248-523
Date Printed: 5/6/2004		

Job No: 03-248	Bidell Equipment, Inc. 16" O.D. x 30" S/S	Vessel Number: 03-248-523
Date Printed: 5/6/2004		

Job No: 03-248	Bidell Equipment, Inc. 16" O.D. x 30" S/S	Vessel Number: 03-248-523
Date Printed: 5/6/2004		

MAWP Report by Components					
<u>Component</u>	<u>Design Pressure</u>	<u>Static Head</u>	<u>Vessel MAWP</u> <u>New & Cold</u> <u>UG-98(a)</u>	<u>Component MAWP</u> <u>Hot & Corroded</u> <u>UG-98(b)</u>	<u>Vessel MAWP</u> <u>Hot & Corroded</u> <u>UG-98(a)</u>
Shell 1	1970.00 PSI	0.00 PSI	2361.85 PSI	2021.29 PSI	2021.29 PSI
Head 1	1970.00 PSI	0.00 PSI	2426.34 PSI	2047.78 PSI	2047.78 PSI

NC = Not Calculated Inc = Incomplete

MAWP Report by Components					
<u>Component</u>	<u>Design Pressure</u>	<u>Static Head</u>	<u>Vessel MAWP New & Cold UG-98(a)</u>	<u>Component MAWP Hot & Corroded UG-98(b)</u>	<u>Vessel MAWP Hot & Corroded UG-98(a)</u>
Shell 1	1970.00 PSI	0.00 PSI	2361.85 PSI	2021.29 PSI	2021.29 PSI
Head 1	1970.00 PSI	0.00 PSI	2426.34 PSI	2047.78 PSI	2047.78 PSI

NC = Not Calculated Inc = Incomplete

MAWP Report by Components					
<u>Component</u>	<u>Design Pressure</u>	<u>Static Head</u>	<u>Vessel MAWP New & Cold UG-98(a)</u>	<u>Component MAWP Hot & Corroded UG-98(b)</u>	<u>Vessel MAWP Hot & Corroded UG-98(a)</u>
Shell 1	1970.00 PSI	0.00 PSI	2361.85 PSI	2021.29 PSI	2021.29 PSI
Head 1	1970.00 PSI	0.00 PSI	2426.34 PSI	2047.78 PSI	2047.78 PSI

NC = Not Calculated Inc = Incomplete

Summary	
Component with the lowest vessel MAWP(New & Cold) : Shell 1	
The lowest vessel MAWP(New & Cold) :	2361.85 PSI
Component with the lowest vessel MAWP(Hot & Corroded) : Shell 1	
The lowest vessel MAWP(Hot & Corroded) :	2021.29 PSI
Pressures are exclusive of any external loads.	

Summary	
Component with the lowest vessel MAWP(New & Cold) : Shell 1	
The lowest vessel MAWP(New & Cold) :	2361.85 PSI
Component with the lowest vessel MAWP(Hot & Corroded) : Shell 1	
The lowest vessel MAWP(Hot & Corroded) :	2021.29 PSI
Pressures are exclusive of any external loads.	

Summary	
Component with the lowest vessel MAWP(New & Cold) : Shell 1	
The lowest vessel MAWP(New & Cold) :	2361.85 PSI
Component with the lowest vessel MAWP(Hot & Corroded) : Shell 1	
The lowest vessel MAWP(Hot & Corroded) :	2021.29 PSI
Pressures are exclusive of any external loads.	

Summary	
Component with the lowest vessel MAWP(New & Cold) : Shell 1	
The lowest vessel MAWP(New & Cold) :	2361.85 PSI
Component with the lowest vessel MAWP(Hot & Corroded) : Shell 1	
The lowest vessel MAWP(Hot & Corroded) :	2021.29 PSI
Pressures are exclusive of any external loads.	

Summary	
Component with the lowest vessel MAWP(New & Cold) : Shell 1	
The lowest vessel MAWP(New & Cold) :	2361.85 PSI
Component with the lowest vessel MAWP(Hot & Corroded) : Shell 1	
The lowest vessel MAWP(Hot & Corroded) :	2021.29 PSI
Pressures are exclusive of any external loads.	


Summary	
Component with the lowest vessel MAWP(New & Cold) : Shell 1	
The lowest vessel MAWP(New & Cold) :	2361.85 PSI
Component with the lowest vessel MAWP(Hot & Corroded) : Shell 1	
The lowest vessel MAWP(Hot & Corroded) :	2021.29 PSI
Pressures are exclusive of any external loads.	

Summary	
Component with the lowest vessel MAWP(New & Cold) : Shell 1	
The lowest vessel MAWP(New & Cold) :	2361.85 PSI
Component with the lowest vessel MAWP(Hot & Corroded) : Shell 1	
The lowest vessel MAWP(Hot & Corroded) :	2021.29 PSI
Pressures are exclusive of any external loads.	

Summary	
Component with the lowest vessel MAWP(New & Cold) : Shell 1	
The lowest vessel MAWP(New & Cold) :	2361.85 PSI
Component with the lowest vessel MAWP(Hot & Corroded) : Shell 1	
The lowest vessel MAWP(Hot & Corroded) :	2021.29 PSI
Pressures are exclusive of any external loads.	

Summary Information		
	<u>Dry Weight</u>	<u>Flooded Weight</u>
Shell	411.63 lb.	577.19 lb.
Head	96.08 lb.	120.16 lb.
Totals	507.71 lb.	697.35 lb.
	<u>Volume</u>	
Shell	19.82 Gal.	
Head	2.89 Gal.	
Totals	22.71 Gal.	
	<u>Area</u>	
Shell	10.47 Sq. Ft.	
Head	2.36 Sq. Ft.	
Totals	12.83 Sq. Ft.	


Hydrostatic Test Information (UG-99)	
Gauge at Top	
Component with controlling ratio is : Shell 1	
Component with controlling pressure is : Shell 1	
Calculated Test Pressure = $P * 1.3 * \frac{\text{Cold Stress}}{\text{Hot Stress}}$	
$= 1970.00 * 1.3 * \frac{20000}{20000}$	2561.00 PSI




SOUR SERVICE MATERIAL

ALL Material on this Requisition/Purchase order shall meet the following Chemical and Physical Properties and shall be accompanied by Mill Test Certificates verifying this


- Percent Manganese over Percent Carbon shall be greater than or equal to 2.5 $\left(\frac{\%MN}{\%C}\right)$
- Percent Carbon plus one-quarter Percent Manganese $\left(\%C + \frac{\%MN}{4}\right)$ shall be less than or equal to .55
- Hardness shall not exceed Brinell hardness No. 220




PLAN VIEW
TRUE ORIENTATION



BASE PLATE
GUSSET DETAIL



LIFTING LUG DETAIL
N.T.S. (CUT TO SUIT)



ELEVATION VIEW
NOT TRUE ORIENTATION

OF MATERIAL					
Item	Qty	Size	Description	Mat'l Spec.	HEAT No. or LOG No.
1	ONE	30"	OD x 5/8" Nom. I. ROLLED CAN x 5'-6" LG.	SA-516-70N	
2	2	30"	OD x 3/4" Nom. I. 2:1 SE HEAD c/w 2" SF	SA-516-70N	
3	ONE	30"	OD x 3/8" Nom. I. ROLLED CAN x 13.5" LG	SA-516-70N	
4	ONE	3/4"	L. BASE PLATE 31" x 31" SQUARE	SA-36	
5	2	8"	300# RFWN FLANGE XXH BORE	SA-105 N	
6	ONE	2"	300# RFWN FLANGE XXH BORE	SA-105 N	
7	ONE	8"	SCH 160 SMLS PIPE x 5" LG BOE,POE	SA-106-B	
8	ONE	8"	SCH 160 SMLS PIPE x 6" LG BBE	SA-106-B	
9	ONE	8"	XXH WALL SMLS PIPE x 11 1/2" LG BOE,POE	SA-106-B	
10	ONE	2"	XXH WALL SMLS PIPE x 4 1/4" LG BOE,POE	SA-106-B	
11	ONE	1"	SCH 160 SMLS PIPE x AS REQ'D TOE,POE	SA-106-B	
12	ONE	1.5"	SCH 160 SMLS PIPE x 3" LG BOE,POE	SA-106-B	
13	ONE	1.5"	SCH 160 SMLS PIPE x 15 3/4" BOE,TOE	SA-106-B	
14	3	8"	XXH LR 90 Deg. BW ELBOW	SA-234-WPB	
15	ONE	2"	XXH WALL LR 90 Deg. BW ELBOW	SA-234-WPB	
16	ONE	1.5"	SCH 160 LR 90 Deg. BW ELBOW	SA-234-WPB	
17	ONE	1"	6000# F.S. THR'D FULL COUPLING	SA-105 N	
18	3	2"	3000# F.S. THREDOLET ON 30" RUN	SA-105 N	
19	ONE	2"	3000# F.S. THREDOLET ON FLAT RUN	SA-105 N	
20	4	3/4"	3000# F.S. THREDOLET ON 30" RUN	SA-105 N	
21	2	2"	6000# F.S. HEX HEAD PLUG	SA-105 N	
22	2	3/4"	6000# F.S. HEX HEAD PLUG	SA-105 N	
23	ONE	6"	L. 9# DENSITY x 28 3/4" OD MESH PAD	316 SS	
24	10	3/8"	L. x 1 1/2" BAR MESH SUPPORTS	SA-36	
25	ONE		ASME NAME PLATE c/w MNTG. BRKT.	SA-36	
26	ONE	3/8"	L. INLET BAFFLE 16" LG x AS REQ'D.	SA-516-70N	
27	ONE	3/8"	L. INLET BAFFLE 8" LG x AS REQ'D.	SA-516-70N	
28	8	3/8"	L. x 3 1/2" WIDE x 12 1/2" LG. GUSSETS	SA-36	
29	2	3/8"	L. REPADS 8 3/4" ID x 12 3/4" OD	SA-516-70N	
30	2	1/2"	L. PLATE x 4" WIDE x 6" LG.	SA-36	
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					



NOZZLE SCHEDULE									
Ref.	Size	Rating	Type	Service	FILLET WELD SIZE			PROJECTION	
					W.D.	A (W#1)	B (W#2)	C (W#3)	H EXT. PROJ.
A	8"	300#	RFWN	GAS INLET	1.4,8	1/2"	5/16"	1/2"	1/2" AS SHOWN
B	8"	300#	RFWN	GAS OUTLET	1.4,8	1/2"	5/16"	1/2"	1/2" AS SHOWN
C	1"	6000#	CPLG	DUMP	3	3/8"		3/8"	3/8"
D	1.5"		PIPE	MANUAL DRAIN	2.5	3/8"			
E	2"	3000#	TOL	LIQUID LEVEL CONTROLLER	6	3/8"			
F	2"	3000#	TOL	HIGH LEVEL SHUTDOWN	6	3/8"			
G _{1,2}	3/4"	3000#	TOL	GAUGE GLASS	6	3/8"			
H	2"	3000#	TOL	INSPECTION OPENING	6	3/8"			
J	2"	3000#	TOL	INSPECTION OPENING	6	3/8"			
K	3/4"	3000#	TOL	PRESSURE INDICATOR (PLUGGED)	6	3/8"			
L	3/4"	3000#	TOL	TEMPERATURE INDICATOR (PLUGGED)	6	3/8"			
M _{1,2}	6"			SKIRT ACCESS					
N	2"	300#	RFWN	BYPASS INLET	3,8	3/8"		3/8"	3/8" AS SHOWN
P									
Q									
R									

DRAWN: A. PROCHAZKA				DATE: AUG 07/01				SCALE: 3/4" = 1'-0"				1st STAGE SCRUBBER 30" O.D.x 5'-6"S/S			
CHK'D:				GAS COMPRESSION				CUSTOMER: BIDELE EQUIPMENT INC.				PROJECT: STOCK UNIT			
DATE: AUG 07				ISSUED TO: SHIP / ABSA				SHOP ORDER: 01-104				DWG.No:01-104-501			
REV				REV				REV				REV			
DATE				DATE				DATE				DATE			
DESCRIPTION				DESCRIPTION				DESCRIPTION				DESCRIPTION			
DRAWING ISSUE RECORD				REVISIONS				3236 - 50th AVENUE S.E. CALGARY, ALTA, T2B-3A3				PHONE: (403) 235-5877 FAX: (403) 272-7749			


U				We constructed in strict accordance with 1998 edition of the ASME Code 2000 ADDENDA for Unfired Pressure Vessels Section VIII Div. 1			
DESIGN		HYDROTEST					
Internal Press.	655 PSIG	852 PSIG					
External Press.	ATMOS.	ATMOS.					
Temperature	300 Deg.F	AMBIENT					
Min. Design Metal Temp. - 20 Deg.F AT 655 PSIG							
Corr. Allowance	0.125 in 3.18 mm	Radiography RT-1					
Mat'l Tests	NIL PER ASME UG-201	FULL PER UW 11a					
Postweld Heat Tr. SEE NOTE # 4		Volume 31.0 ft ³ 0.878 m ³					
Wt. full of water	lb 2500	kg 1134	Shipping Wt. 2500 lb 1134 kg				
MATERIAL		TYPE					
Shell	SA-516-70N	0.610	0.625				
Head...End/Top	SA-516-70N	0.602	0.688				
Head...End/Bottom	SA-516-70N	0.602	0.688				
Flange	SA-105 N	SA-106-B	SA-105 N				
Nozzle Neck	SA-106-B	SA-105 N	SA-234-WPB				
Bolts/Studs	SA-193-B7M	SA-194-2HM	316 SS FLEXITALLIC				
Special Procedures:							
Service: SOUR GAS SERVICE							
Registered Welding Procedures: WPS 2111.2 AQP 1338							
C R N: -							
Serial No. 01-104-501		Customer P.O.#					
Surface Prep. SEE NOTE #2							
Finish ONE COAT OF SHOP PRIMER							
Insulation NONE							
NOTES:							
1. TACK WELDS USED = WPS # BE-3 / BE-4							
2. INTERNALLY @ EXTERNALLY CLEANED, PICKLED & OILED							
3. 2" THREDOLET TO HAVE MAX. HOLE OF NO GREATER THAN 2 1/8" O.D.							
4. PWHT @ 1150 Deg.F FOR ONE HOUR							
ASME Eng. Per: MIKE FUDGE Date: AUG 07/01							

APPROVED
FOR CONSTRUCTION

CUSTOMER PER DATE
ENGINEERING PER DATE
SHOP PROD. PER DATE



ELEVATION VIEW



VIEW A - A

SOUR SERVICE MATERIAL

ALL Material on this Requisition/Purchase order shall meet the following Chemical and Physical Properties and shall be accompanied by Mill Test Certificates verifying this



- Percent Manganese over Percent Carbon ($\frac{\%MN}{\%C}$) shall be greater than or equal to 2.5
- Percent Carbon plus one-quarter Percent Manganese ($\%C + \frac{\%MN}{4}$) shall be less than or equal to .55
- Hardness shall not exceed Brinell hardness No. 220

OF MATERIAL					
Item	No.	Size	Description	Mat'l Spec.	HEAT No. or LOG No.
1	ONE	18"	SCH 40 SMLS PIPE x 30" LG.	SA-106-B	
2	2	18"	OD x 5/8" Norm. L 2:1 SE HEAD c/w 2" SF	SA-516-70N	
3	ONE	6"	300# RFWN FLANGE SCH 160 BORE	SA-105 N	
4	ONE	6"	600# RFWN FLANGE XXH BORE	SA-105 N	
5	ONE	6"	SCH 160 SMLS PIPE x 5 3/4" LG BOE,POE	SA-106-B	
6	ONE	6"	XXH WALL SMLS PIPE x 5 1/2" LG BOE,POE	SA-106-B	
7	2	3/4"	3000# F.S. THREADOLET ON 18" RUN	SA-105 N	
8	2	3/4"	3000# F.S. THREADOLET ON 6" RUN	SA-105 N	
9	3	3/4"	6000# F.S. HEX HEAD PLUG	SA-105 N	
10	ONE		ASME NAME PLATE c/w MNTG. BRKT.	SA-36	
11	ONE	3/8"	t. REPAD x 6 3/4" ID x 10 3/4" OD	SA-106-B	
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					


NOZZLE SCHEDULE									
Ref.	Size	Rating	Type	Service	FILLET WELD SIZE			PROJECTION	
					W.D.	A (W41)	B (W42)	C (W43)	H EXT. PROJ.
A	6"	300#	RFWN	GAS INLET / INSPECTION OPENING AS PER UG-46(7)	3,8	3/8"		3/8"	3/8" AS SHOWN
B	6"	600#	RFWN	GAS OUTLET / INSPECTION OPENINGS AS PER UG-46(7)	4,8	3/8"	5/16"	0"	0" 9"
C	3/4"	3000#	TOL	DRAIN	6	3/8"			
D	3/4"	3000#	TOL	TEMPERATURE CONNECTION	6	3/8"			
E	3/4"	3000#	TOL	TEST CONNECTION	6	3/8"			
F	3/4"	3000#	TOL	TEST CONNECTION	6	3/8"			
G									
H									
J									
K									
L									
M									
N									
P									
Q									
R									

DRAWN: A. PROCHAZKA		DATE: AUGUST 07/01		SCALE: 1.5" = 1'-0"		CHK'D:	
2nd STAGE SUCTION BOTTLE				18" O.D. x 2'-6" S/S			
BIDELL EQUIPMENT				GAS COMPRESSION			
3236 - 50th AVENUE S.E. CALGARY, ALTA T2B-3A3				PHONE: (403) 235-5877 FAX: (403) 272-7749			
CUSTOMER: BIDELL EQUIPMENT INC.		PROJECT: STOCK UNIT		SHOP ORDER: 01-104		REVISION:	
DWG.No:01-104-512		0					

DATE	REV	ISSUED TO	REV	DATE	BY	DESCRIPTION
AUG07	0	ISSUED TO SHOP / ARSA				
DRAWING ISSUE RECORD						
REVISIONS						



ELEVATION VIEW



VIEW A - A

SOUR SERVICE MATERIAL

ALL Material on this Requisition/Purchase order shall meet the following Chemical and Physical Properties and shall be accompanied by Mill Test Certificates verifying this

- Percent Manganese over Percent Carbon shall be greater than or equal to 2.5 $\left(\frac{\%MN}{\%C}\right)$
- Percent Carbon plus one-quarter Percent Manganese $\left(\%C + \frac{\%MN}{4}\right)$ shall be less than or equal to .55
- Hardness shall not exceed Brinell hardness No. 220

LIST OF MATERIAL					
Item	No. Req'd	Size	Description	Mat'l Spec.	HEAT No. or LOC No.
1	ONE	18"	SCH 80 SMLS PIPE x 30" LG.	SA-106-B	
2	2	18"	OD x 7/8" Nom. t. 2:1 SE HEAD c/w 2" SF	SA-516-70N	
3	ONE	6"	600# RFWN FLANGE XXH BORE	SA-105 N	
4	ONE	4"	600# RFWN FLANGE XXH BORE	SA-105 N	
5	ONE	6"	XXH WALL SMLS PIPE x 7" LG BOE,POE	SA-106-B	
6	ONE	4"	XXH WALL SMLS PIPE x 5 3/8" LG BOE,POE	SA-106-B	
7	3	3/4"	3000# F.S. THREDOLET ON 18" RUN	SA-105 N	
8	3	3/4"	3000# F.S. THREDOLET ON 6" RUN	SA-105 N	
9	ONE	3/4"	3000# F.S. THREDOLET ON 4" RUN	SA-105 N	
10	3	3/4"	6000# F.S. HEX HEAD PLUG	SA-105 N	
11	ONE		ASME NAME PLATE c/w MNTG. BRKT.	SA-36	
12	ONE	3/8"	1. REPAID x 6 3/4" ID x 10 3/4" OD	SA-106-B	
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					

NOZZLE SCHEDULE									
Ref.	Size	Rating	Type	Service	FILLET WELD SIZE			PROJECTION	
					W.D.	A (W#1)	B (W#2)	C (W#3)	EXT. PROJ.
A	6"	600#	RFWN	GAS INLET / INSPECTION OPENING AS PER UG-46(7)	4,8	3/8"	5/16"	0"	10"
B	4"	600#	RFWN	GAS OUTLET / INSPECTION OPENINGS AS PER UG-46(7)	3,8	5/8"		5/8"	AS SHOWN
C	3/4"	3000#	TOL	DRAIN	6	3/8"			
D	3/4"	3000#	TOL	TEMPERATURE CONNECTION	6	3/8"			
E	3/4"	3000#	TOL	PRESSURE CONNECTION	6	3/8"			
F	3/4"	3000#	TOL	HIGH TEMPERATURE SHUT-DOWN	6	3/8"			
G	3/4"	3000#	TOL	TEST CONNECTION	6	3/8"			
H	3/4"	3000#	TOL	TEST CONNECTION	6	3/8"			
J									
K									
L									
M									
N									
P									
Q									
R									

DRAWN: A. PROCHAZKA		DATE: AUG 15/01		SCALE: 1.5" = 1'-0"		CHK'D:	
2nd STAGE DISCHARGE BOTTLE 18" O.D. x 2'-6" S/S							
CUSTOMER: BIDELL EQUIPMENT INC. PROJECT: STOCK UNIT SHOP ORDER: 01-104				DWG.No:01-104-522 REVISION: 0			
3236 - 50th AVENUE S.E. CALGARY, ALTA, T2B-3A3				PHONE: (403) 235-5877 FAX: (403) 272-7749			

be constructed in strict accordance
1998 edition of the ASME Code
for Unfired Pressure Vessels Section VIII Div. 1

2000 ADDENDA

DESIGN	DESIGN	HYDROTEST
Internal Press.	1315 PSIG	1710 PSIG
External Press.	ATMOS.	ATMOS.
Temperature	300 Deg.F	AMBIENT
Min. Design Metal Temp. - 20 Deg.F AT 1315 PSIG		
Corr. Allowance 0.125 in 3.18 mm Radiography RT-1		
Mat'l Tests NIL PER ASME UG-201 ASME UW 11a		
Postweld Heat Tr. NONE Volume 4.71 ft ³ 0.13 m ³		
Wt. full of water lb kg Shipping Wt. 750 lb 341 kg		

MATERIAL	Calc.	Min.	Nom.	TYPE	
Shell	SA-106-B	0.797	0.820	0.937	SMLS PIPE
Head...End/Top	SA-516-70N	0.684	0.750	0.875	2:1 SE HEAD
Head...End/Bottom	SA-516-70N	0.684	0.750	0.875	2:1 SE HEAD
Flange	SA-105 N	SA-106-B	SA-105 N	SA-234-WPB	
Bolts/Studs	Nuts			Gaskets	
SA-193-B7M	SA-194-2HM			316 SS FLEXITALLIC	

Special Procedures:

Service: SOUR GAS SERVICE

Registered Welding Procedures: WPS 2111.2 AOP 1338

C.R.N.: -

Serial No. 01-104-522 Customer P.O.#

Surface Prep. SEE NOTE #2

Finish ONE COAT OF SHOP PRIMER

Insulation NONE

NOTES:

- TACK WELDS USED = WPS # BE-3 / BE-4
- INTERNALLY & EXTERNALLY CLEANED, PICKLED & OILED
- PWHT @ 1150 Deg.F FOR ONE HOUR

ASME Eng. Per: MIKE FUDGE Date: AUGUST 15/01

APPROVED
FOR CONSTRUCTION

CUSTOMER PER DATE
ENGINEERING PER DATE
SHOP PROD. PER DATE