



# **Existing Equipment Integrity Assessment Report**

Date July 2023

Page 1 of 1

				L						
, , ,	Client: Yoho F	Resources		District: Inga,		LSD: 10-19-087-23W6				
Facility:		Client F				ef # P003/P004				
Equipment #: S-5		Description: Fi			Jur# N/A	CRN: L9476.213				
MFR: Larsen & D'Amico		Mfr S/N:	S-14287	Mfr Date:	2009	Status: Operating				
Fit for Service: Yes Online PSV Inspection has be	Suitable for S		PSV r Yes	neets Code:	Yes PS'	V set at or below MAWP: Yes				
PSV Capacity Verified:	N/A	-								
Repair / Alteration / PSV Calil		ed	No	-						
· ·	<u> </u>	Current In	spectio	n Results						
2023-07 II UT completed by RJC Integrity  II   The vessel is located inside the Waukesah H24GL Comp Skid (#050954-01)  The nameplate is securely attached to the nameplate bracket and is legible. The ground cable is securely connected to the skid.  The external surfaces of the vessel are painted. The paint is in new-like condition. No corrosion or deformations were visible on the shell of the vessel. No cracks or deterioration were identified in the vessel welds. The vessel is anchored to brackets that are welded to the skid floor. The welds do not appear cracked or corroding, and the skirt adequately supports the vessel. The anchot bolts are right and secure. Only a single nut is present on teach anchor bolt. The piping systems are adequately supported. The valves appear to work correctly; no leaks were identified from the valves or piping connections. The gauges are easily legible, and no leaks were identified from the gauges. The caulking around the PSV outlet piping has failed.  UT   No concerns noted  PSV   The PSV has a nameplate securely attached with the ASME UV designator; it is correctly installed in the vertical position, supported, and piped to a safe location. The seal is intact and set at or below the MAWP of the vessel. The serial number liksted on the nameplate matches the serial number lister on the service tag.  Assessment completed by Aaron Bischoff   UT readings above Nom-C.A and MIL tolerance Tmin (12.5%),. No issues on concerns noted. FGS 10 year / 120 month acceptable. AJB.  VE reviewed; no major concerns noted. AJB  Past PSV Servicing Results  SN C044094 2020-09 serviced by unified Valve. PSV Service report reviewed using PSV assessment calculator. PSV serviced by Unified Valve										
Fort St John. No issues or concern		Past Inspect								
No historical inspections		•								
·	N	NEXT NDE &	Inspect	ion Methods	S					
	□ VI			UT 203:	3	□ BW				
☐ WF	☐ LF			ET		☐ HIC				
☐ CREEP	□ BHN			CDR		☐ MFL				
Other:	-		•							
		Previous	Inspect	tion Plan						
No historical ITP										
		Next In	spectio	n Plan						
Expected damage mechanisms an Primary Areas of degradation: Bott NDE examinations (type & extent): Preparation for next inspection: No PSV: Last service September 2020	tom head and pip : VE on 5-year In one	oing elbows. terval – due July	2028; UT (	on 10-year DUE						

Qualified

Inspector: Aaron Bischoff Qual: IBPV#644 Signature: Report date: 20-Nov-2023 status: Final

"Your success is our goal" nick@irml.ca



Report No:

Inspect	Date: Jul	y 27	7, 202	23	Clie	nt: Yo	oho Re	sources	;		Dis	strict:	Ing	a, B	С		LSD	: 10-1	9-087-23	W6
Facility:								CI	ient R	ef#					IRN	/I Ref #				
Equipm	ent #S-5				Des	scription	: Fuel	Gas S	crubb	er				J	Jur# N/A	4		CRI	N L9476.2	13
MFR:	Larsen 8	ς D'	'Amic	Ю			Mfı	r S/N:	S.	-1428	87	М	fr Dat				atus	: Ope	rating	
	Orien	Ltl	h/ht	OD	)	Cod	de	MAW	/P	N	ΛΑWT		MDM	Т	@	NOI	Ρ	NOT	HT	RT
Vessel	Vert	3	6"	8"		U		150	)		200		-20		150	145	5		Yes	None
	Ext Ins.	No	)	Int. o	coati	ing:		Pr	ocess	con	ditions	s: Sv	veet (	Gas/	Conden	sateMa	anwa	ay: N/A		
Shell	Material		Nom		C/A	T/L	M	aterial	No	om	C/A	\ F	orm	B/F	<b>₹</b> N	/laterial		Nom	C/A	Form
SHEII	CS	(	0.25	0" 0.	063	" Hea	d	CS	0.5	00"	0.06	3"	FB	Hea	ad	CS		0.500	0.063	FB
PSV # 11 Yoho MFR: Mercer					Mfr S/N: C044094 Mfr Date:							)5/17		ake/ odel:	85-1	7151V09	N11			
CRN 1	)G8841.50	CR :	Set15	50psi	Ca	ap 606	scfm	Code I	UV/NB	Serv	Co.	Unit	fied	0	Serv Tag	3252	0F	Last Ser\	Sen	2020
	Size	Тур	e ;	# Ratir	ng		Blo	ck Valve	e Loc	cked/	Carsea	aled								
Inlet	1.0"	Thr	ead	N/A			No	)				_ocat	tion:	Pipir	ng					
Outlet	1.0"	Thr	ead	N/A			No	)			\	Vente	ed to:	Atmo	osphere					
PSV#			MI	FR:				Mfr S/N	1:				Mfr Dat	e:			ake/ odel:			
CRN			Set			ар		Code		Serv				S	Serv Tag	)		Last Ser\		
	Size	Тур	e i	# Ratir	ng		Blo	ck Valve	e Loc	cked/	Carsea	aled								
Inlet											l	_ocat	tion:							
Outlet											\	√ente	ed to:							

NOTE: All measurement are in metric, unless specifically noted – Pressure kPa, Temp C, Length/OD/Thk mm

#### **EXTERNAL INSPECTION**

				1175 1110	FECTION					
Vessel				PSV		Piping & Inst	Piping & Instrumentation			
Item Inspected Disposition		Item Inspected Disposition		Disposition	Item	Inspected	Disposition			
Nameplate	Yes	Good	Properly supported	Yes	Good	Proper material	Yes	Good		
Heads	Yes	Good	Nameplate	Yes	Good	Proper schedule	Yes	Good		
Shell	Yes	Good	Service tag	Yes	Good	Proper flanges	N/A			
Insulation/cladding	N/A		Cap Seal	Yes	Good	Piping condition	Yes	Good		
Coating	Yes	Good	Body - external	Yes	Good	Strains	Yes	Good		
Supports/skirts	Yes	Good	Drainage	Yes	Good	Bolting	Yes	Good		
Anchors	Yes	Good	Block valves	N/A		Supports/hangers	Yes	Good		
Pads/foundations	Yes	Good	Locks/Carseals	N/A		Insulation	N/A			
Grounding	Yes	Good			<u>.</u>	Coating/fireproofing	N/A			
Nozzles	Yes	Good				Instrumentation	N/A			
Bolting	N/A					Pumps & motors	N/A			
Cathodic protection	N/A		7 .	SUMMARY	•	Gauges & recorders	Yes	Good		

Fit for Service: Yes Suitable for Service: Yes PSV meets Code: Yes PSV set at or below MAWP: Yes PSV Capacity Verified: Client to verify.

Repair / Alteration / PSV Calibration Required No No issues noted.



Report No:

#### Vessel

NOTE: All measurements are in Imperial Units unless otherwise noted. Pressure (PSI), Temperature (deg F), Length/OD/Thickness Inches (IN).

The vessel is located inside the Waukesah H24GL Comp Skid (#050954-01)

The nameplate is securely attached to the nameplate bracket and is legible. The ground cable is securely connected to the skid.

The external surfaces of the vessel are painted. The paint is in new-like condition. No corrosion or deformations were visible on the shell of the vessel. No cracks or deterioration were identified in the vessel welds.

The vessel is anchored to brackets that are welded to the skid floor. The welds do not appear cracked or corroding, and the skirt adequately supports the vessel. The anchot bolts are right and secure. Only a single nut is present on teach anchor bolt.

The piping systems are adequately supported. The valves appear to work correctly; no leaks were identified from the valves or piping connections.

The gauges are easily legible, and no leaks were identified from the gauges.

The caulking around the PSV outlet piping has failed.

#### **PSV**

The PSV has a nameplate securely attached with the ASME UV designator; it is correctly installed in the vertical position, supported, and piped to a safe location. The seal is intact and set at or below the MAWP of the vessel. The serial number liksted on the nameplate matches the serial number lister on the service tag.

Inspector: Ryan Cadieux Qual: ISI# 001279 Signature: Report Gate: 27-Jul-2023 status: Final













































UT readings above Nom-C.A and MIL tolerance Tmin (12.5%),. No issues on concerns noted. 5 year / 60 month acceptable.



#### **Corrosion Survey Report**

(780) 242-2204 RyanC@RJCIntegrity.com www.RJCIntegrity.com

Client: Yoho Resources	SN.S-14287 - UT - 001 - RC
Date: Thursday, July 27, 2023	3N.3-14287 - UT - UUI - NC

Work Location: Inga, BC

Examination Standard: ASME V Article 4 - 2021

Acceptance Standard: Client's Spec.

RJC Procedure: RJCI-UT-001 Rev.0

Scanning Surface: O.D.

Material: Carbon Steel

P.O. No.:

Surface Condition: Painted

W.O. No.:

Temperature: Ambient

Other:

Instrument: Olympus Couplant: UTX

Model: Epoch 600 Calibration Block: C.S. Step Wedge Serial No. 3886-20

Serial No.: 140708306 Calibration Block:

Cal Due Date: Monday, January 15, 2024 Scanning Limitation: See comments below

Probe	Ser. No.	Angle	MHz	Crystal Size / Type	Primary Ref. Reflector / Amp. / Distance / dB	Scan Sens.	<b>Calibrated Range</b>
V-110	180002	0°	5 MHz	0.500" / Single	1st Back wall	As required	0.100" - 1.000"

Purpose: To perform an ultrasonic thickness survey.

Results: Refer to attached pages for recorded data.

#### Notes:

- 1. Thickness readings do NOT include paint thickness.
- 2. \* = Assumed nominal thickness
- 3. Piping wall loss between 12.6% 30% = Caution
- 4. Piping wall loss greater then 30% = Urgent

ì	VESSEL DATA												
Vessel Description: Fuel Gas Scrubber													
A No.:	N/A	Vessel ID:	N/S	Manufacturer:	Larsen & D'Amico								
CRN No.:	L9476.213	Year Built:	2009	District:	Inga, BC								
Serial No.:	S-14287	C.A.:	0.063"	LSD:	10-19-087-23W6								

Interpretation	on is in accordance with the above m	entioned standards, to the best of	my professional	ability.		
Print:	Ryan Cadieux	CGSB/SNT Level: II/II	Reg. No.:	18219	Sign:	Ryan Cadwux
Client Repres	sentative:					
Duint		Data			Ci	
Print:		Date:			Sign:	



Band ID	Location	Direction	Material	Nominal (in)	CA (in)		Baseline (in)	Previous (in)	Current (in)	% Wall Loss	Tmin (in)	STCR (mpy)	LTCR (mpy)	Years Remaining	
000	Top Shell	T - B	Carbon Steel	0.250	0.063	Year: Min: Avg:	2009 0.250		2023 0.233 0.234	6.80%	0.187	0.00	1.21	20	Acceptable
	Comments:														Acc
005	Bottom Shell	T - B	Carbon Steel	0.250	0.063	Year: Min: Avg:	2009 0.250		2023 0.232 0.234	7.20%	0.187	0.00	1.29	20	Acceptable
	Comments:														Acc
						Year: Min: Avg:				#DIV/0!	0.000	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
	Comments:		ı												]#
						Year: Min: Avg:				#DIV/0!	0.000	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
	Comments:					1									#
						Year: Min: Avg:				#DIV/0!	0.000	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
	Comments:														#
						Year: Min: Avg:				#DIV/0!	0.000	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0i
	Comments:														#




#### **Vessel Overview**






### Nameplate







#### **TML Locations**



PSV Service report reviewed using PSV assessment calculator. PSV serviced by Unified Valve Fort St John. No issues or concerns at time of servicing, suggested interval of 5 years / 60 months. AJB

PRV INSPECTION AND TEST REPORT

32520F

Fort St John BRANCH: **UVL ID#:** W16001404 Work Order:

Customer PO#: Date: 09/03/2020 YOHO RESOURCES INC Customer **INGA** LSD: Facility: **PSV Location:** Cust Id: 11 YOHO Vessel SN: A#: Valve PO: Cust. Ref.: PO LINE#: Cust. WO#: Cost Centre#: Cust AFE#: **VALVE DATA MERCER** Model: 85-17151V09N11 Serial: C044094 Seat: SOFT Man.: Threaded Inlet: 1" MNPT Orifice: E Conn. Outlet: 1" FNPT Vacuum: Set Press. 150 PSI Back Press.: N/A PSI CDTP: N/A PSI **Temp:** 70 F Cap: 606 SCFM Lift Lever Cap Assembly: Closed RFID: Code Symbol: UV 0G8841.5CR1 **CUSTOMER INSTRUCTIONS** Full Service  $\square$ Instructions: Pretest Required? Reset Required? **CONDITION AS RECEIVED** Fair 10/2017 Visual Condition: **Data Plate Condition:** Date of last service: Seal Condition: Intact Bottom: N/A Top: Insignia: Fittings Attached: Inlet: Outlet: Inlet: Carbon Inlet Plugged: Outlet: Good Outlet Plugged: ☐ Initial Insp. Signoff: K-anna Jobson PRETEST 1 FSJ9/10 Simmer: 153 PSI Set Press: 123 PSI Leakage: 0 BPM Test Gauge: 154 PSI Reseat: Tested By: Sean Moore **Pretest Comments: PRETEST 2** FSJ9/10 Set Press: Test Gauge: Simmer: Reseat: Leakage: Tested By: **Pretest Comments: COMPONENTS INSPECTION** (0 Like New / 1 Minor /2 Medium / 3 Major) CORRODED GROOVED CLEAN PITTED DENTED SCALE COMMENTS ITEM DISC NOZZLE 1 П П П П CAP-LEVER ASSY П П COMP SCREW and LC AS FOUND: AS LEFT SPRING and BUTTONS SPINDLE / STEM STEM RETAINER DISC HOLDER GUIDE / UPPER RING LOWER RING RING PIN(S) П **BELLOWS** 81-095001 GASKET / SEALS  $\square$ П CONNECTION ENDS 1 OTHER П П NOZZLE: MIN/MAX ACT -SPRING NUMBER: DISC: Min: ACT -Randy Rowsell Sean Moore Randy Rowsell Disassembly: Inspection: Reassembly: **FINAL TEST** Air **Test Medium** Simmer: 148 PSI Set Pressure: 150 PSI Reseat: 121 PSI Leakage Acceptable: B.P. Test: 60 PSI Vacuum: N/A ADJ. RING SETTING (NOTCHES): Upper: N/A Lower: Test Gauge: FSJ9/10 Set Press Def POP Dale Welsh Tested by: 09/16/2020 Date Final Tested: **FINAL INSPECTION:** тор: 🔽 Bottom: End Protectors Installed: Painted: Palletized: Ship Container: Flex Gaskets Supplied: SEAL: Randy Rowsell Final Inspection: **Customer Inspection:** Comments: