


BILL OF MATERIAL				
MARK	QTY	COMPONENT DESCRIPTION	MATERIAL	WT
1	2	END: PLATE 6.35mm (1/4") THK. x 3645mm (11'-11 1/2") DIA.	G40.21-38WT	
2	-	-		
3	5	SHELL: PLATE 6.35mm (1/4") THK. x 2438mm (7'-11 1/2") x 11491mm (37'-8 7/16") LG.	G40.21-38WT	
4	8	C6 X 8.2 CHANNEL END PLATE STIFFENERS	G40.21-44W	
5	-	-		
GL	-	PROVISIONS TO GROUND TO SKID AT EACH END	-	
7	-	-		
8	-	-	G40.21-44W	
9	4	LIFTING LUGS ATMI-STD-001 (REFER TO DWG#ATMI-STD-100-01)	G40.21-44W	
10	2	TAILING LUG ATMI-STD-003 (REFER TO DWG#ATMI-STD-100-01)	G40.21-44W	
11	1	NAMEPLATE C/W BRACKET ATMI-STD-006 (REFER TO DWG#ATMI-STD-100-01)		
12	1	SHELL MANWAY 24" ROUND	G40.21-44W	
13	1	ELECTRICAL MOUNTING PLATE 915MM (36") X 915mm (36") PAINTED TO MATCH TANK COLOR		
14				
15				
16	2	TANK ROOF SAFETY HARNESS LUG REFER TO (REFER TO ATMI-STD-007)	G40.21-44W	
17	2	TANK LIFTING DEVICE REFERENCE TO ULC S601-14	G40.21-44W	
18				
26	-	-		



- STICK WELD CHIME IN AND OUT
- FULL BOLT UP FIELD READY
- SEE NOZZLE SCHEDULE FOR VALVES

1. ALL DIMENSIONS ARE IN MILLIMETERS. DIMENSIONS IN BRACKETS ARE IMPERIAL CONVERSIONS FOR SHOP REFERENCE ONLY.
2. ALL NOZZLE PROJECTIONS GIVEN ARE ALONG THE NOZZLE CENTERLINE.
3. FLANGE AND BOLT HOLES TO STRADDLE PRINCIPAL CENTERLINES OF TANKS
4. ATM INSPECTION LEVEL 1.

CADD DWG – DO NOT MANUALLY CHANGE