

## Field Inspection Report - Paramount\_Resources

### POU0620\_03/15/2003\_VT\_EXTERNAL

<b>Vessel Number</b>	POU0620	<b>Vessel Name</b>	FUEL GAS SCRUBBER	<b>Province</b>	
<b>District</b>	INVENTORY	<b>LSD</b>	00-00-000-00W0	<b>Location</b>	URBAN YARD CALGARY
<b>Method</b>	VT	<b>Access</b>	EXTERNAL	<b>Cleaning</b>	
<b>Inspection Date (mm/dd/yyyy)</b>	03/15/2003	<b>Inspection Interval (months)</b>	60	<b>Next Inspection (mm/dd/yyyy)</b>	03/15/2008
<b>CRN</b>	L-8912.213	<b>Skid Number</b>	PKG0607	<b>Service</b>	STOCK
<b>Manway</b>	No	<b>Internal Coating</b>	No	<b>Status</b>	Stock
<b>MAWP (PSI)</b>	150	<b>MAWP (kPa)</b>	1034.22	<b>Outstanding NCRs</b>	0
<b>MAWT (°C)</b>	37.78	<b>MAWT (°F)</b>	100		

#### General

#### Safety Valves

PSV POU0621 Shell side. Set pressure: 125 PSI / 861.85 KPa. MAWP: 150 PSI / 1034.22 KPa. Capacity: 279 SCFM / 7.47441 m3/hr.

#### External Condition

VISUAL EXTERNAL INSPECTION REVEALED NO APPARENT DEFECTS, ASSOCIATED PIPING AND CONNECTIONS VISUALLY INSPECTED WITH NO APPARENT DEFECTS NOTED.

#### Internal Condition

#### Recommendations

<b>Suitable to be returned to Service</b>	YES	<b>Repairs complete (AB-40 attached)</b>	N/A



101, 56 Cuendet Industrial Way, Sylvan Lake, AB T4S 0B6

---

## Field Inspection Report - Paramount\_Resources

### POU0620\_03/15/2003\_VT\_EXTERNAL

---

Repairs are still required	NO	Suggested Inspection interval (Months)	60
Glenn Allen MWS Inspector	Signature		05/25/2003 Date (mm/dd/yyyy)

---

### Pictures

---

-No pictures for this inspection-	
-----------------------------------	--