

NORDIC NDT CORP.
Box 32 RR2 Site 7
Grande Prairie, AB T8V 2Z9
Phone780-402-0256
FAX780-402-0356
Toll Free1-866-888-0256
arrhead780-305-3710

NORDIC NDT CORP.

RADIOGRAPHIC EXAMINATION REPORT

3901

PAGE 1 OF 1

Client: BLUESTAR WELDING

Date: FEB 18/05

Location: GRANDE PRAIRIE

Job/AFE#: 10252-P

Description: LINE HEATER MANIFOLD PIPING

P.O.#:

Material: CS

Exposure Device # 1464

Source # 17840B

Ir¹⁹² EFSS: .145"

Kodak ☒ AGFA ☐ Class 1

Acceptance Code
☐ ASME B31.3 Normal Serv.
☒ ASME B31.3 Severe Cyclic
☐ ASME Sect. VIII Div.1 UW51
☐ ASME Sect. VIII Div.1 UW52
☐ CSA Z.662 (sweet service)
☐ CSA Z.662 (sour service)
☐ Other:

Film No.	Size, Location Thickness	Welder Sym.	Tech. No.	SOD Inches	OFD Inches	# of Exp.	Accept	Type and location of inclusions, discontinuities (circle rejectable locations)	Reject
<u>XM-1</u>	<u>3" x .750"</u>	<u>BA</u>	<u>R-3a</u>			<u>4</u>	☒		
<u>2</u>		<u>BA</u>					☒		
<u>3</u>		<u>AW</u>					☒		
<u>4</u>		<u>AW</u>					☒		
<u>5</u>		<u>AW</u>					☒		
<u>6</u>		<u>AW</u>					☒		
<u>7</u>		<u>BC</u>					☒		
<u>8</u>		<u>BC</u>					☒		
<u>9</u>		<u>AW</u>					☒		
<u>10</u>		<u>AW</u>					☒		
<u>11</u>		<u>AW</u>					☒		
<u>12</u>		<u>AW</u>					☒		
<u>13</u>		<u>AW</u>					☒		
<u>14</u>		<u>AW</u>					☒		
<u>15</u>		<u>AW</u>					☒		
<u>16</u>		<u>BC</u>					☒		
<u>17</u>		<u>BC</u>					☒		
<u>18</u>		<u>BC</u>					☒		
<u>19</u>		<u>BC</u>					☒		
<u>20</u>		<u>BC</u>					☒		

Legend: AB - Arc Burns IC - Internal Concavity IUC - Internal Undercut
BT - Burn Through IP - Inadequate Penetration EUC - External Undercut
CK - Crack EP - Excessive Penetration POR - Porosity
MA - Misalignment LF - Lack of Fusion SL - Slag
HB - Hollow Bead LC - Low Cover

Techniques: Single Wall Exposure: R-1, -2, -2a, -6, -7
Double Wall Exposure: R-3, -3a, -4, -5, -8
*All procedures utilize one film per cassette unless otherwise specified.
SOD = source to object distance
OFD = object to film distance
OFD + SOD = source to film distance

Welds	Film	Summary
<u>20</u> -2" welds	<u>-3.5" x 8.5"</u>	Unit # <u>4</u> Kilometers: <u>0</u>
-3" welds	<u>-3.5" x 17"</u>	In <u>1000</u> Out <u>1400</u> Hrs. <u>4</u>
-4" welds	<u>-4.5" x 8.5"</u>	In _____ Out _____ Hrs. _____
-6" welds	<u>-4.5" x 17"</u>	Technician: <u>J. Baird</u>
-8" welds		Assistant: <u>L. Karpisek</u>
-10 welds		
-12" welds		
		Cost Estimate: \$ <u>460⁰⁰</u> (+ GST)

Radiograph Interpretation by:

SNT-TC-1A II

C.G.S.B. Lev. II

C.G.S.B. No. 3979

Report contents are the interpretation of the technician and do not in any way imply a guarantee.

I am in full agreement with report contents:

Client Representative:

Cyle Feb 19 2005

NORDIC NDT CORP.

Box 32, R.R.2, Site 7, Grande Prairie AB. T8V 2Z9
Phone: (780) 402-0256 Fax: (780) 402-0356

 Natural Resources Canada / Ressources naturelles Canada

This certifies that / La présente certifie que
Dwayne Merle Baird
has qualified according to the CANCGSB Standard 48.9712-2000 as follows:
est qualifié selon la norme CANCGSB 48.9712-2000 comme suit:

METHOD MÉTHODE	LEVEL NIVEAU	SECTOR SECTEUR	CERT DATE DATE CERT	EXPIRY DATE DATE EXPIERT	EXPIRY EXPIRATION
RT	2	ENC	09/12/01		05/12/31
PT	2	ENC	01/10/11		05/12/31
NT	2	ENC	00/05/22		05/12/31

REG NO / NO MATRICULE: 3979
ISSUE DATE / DATE D'ÉMISSION: 03/01/23
MANAGER, CERTIFYING AGENCY / GESTIONNAIRE, ORGANISME DE CERTIFICATION: Richard V. Murphy

 Natural Resources Canada / Ressources naturelles Canada

Your certification card is only valid when presented with this identity card
Votre certificat de poche est valide seulement s'il est présenté avec cette carte d'identité



Name / Nom: Dwayne Merle Baird
Reg. No. / No. matricule: 3979
Issue Date / Date d'émission: 2002/02/14
Expiry Date / Expiration: 2005/12/31

 Atomic Energy Control Board / Commission de contrôle de l'énergie atomique

Qualified Operator / Opérateur qualifié
Dwayne Baird
NAME / NOM: Dwayne Baird
1986.04.18
ISSUE DATE / DATE D'ÉMISSION: 1986.04.18
Canada
OPERATOR / OPÉRATEUR: [Signature]
SIGNATURE: [Signature]

Qualified Operator / Opérateur qualifié
pursuant to Section 18 of the Atomic Energy Control Regulations, for the purpose of operating an exposure device containing a prescribed substance.
en vertu de l'article 18 du Règlement sur le contrôle de l'énergie atomique afin d'utiliser un dispositif d'exposition contenant une substance prescrite.

Card Number / No de la carte: 000863
Issuing Officer's Signature / Signature de l'agent responsable: [Signature]

Dwayne Baird CGSB# 3979



HEAT TREATMENT INSTRUCTIONS

JOB NO.: 10252-P CUSTOMER: Pure Energy

DESCRIPTION: Lineheater Coil

DATE: February 18, 2005

COMPONENT DESCRIPTION:

DWG. NO. AND LINE NO.	DIAMETER	THICKNESS	MATERIAL	LENGHT	WEIGHT
1931-06	4 1/2" O.D.	1.031"	AISI 4130	10'	

TYPE OF HEAT TREATMENT: STRESS RELIEVE

Temperature to raised from 800°F (426°C) to 1150°F (621°C) at maximum rate of 400°F
(°C) per hour. NOTE: MUST NOT EXCEED 400°F (222°C) PER HOUR.

(Calculated rate=400°F/h. Divided by governing metal thickness)

Temperature to be held at 1150°F (621°C) plus or minus 25°F (14°C) for
240minutes.

Temperature to be lowered from 1150°F (621°C) to 800°F (426°C) at a maximum rate of 400°F
(°C) per hour. NOTE: MUST NOT EXCEED 500°F (278°C) PER HOUR.

(Calculated rate=500°F/h. Divided by governing metal thickness)

Additional requirements:

- Job number and description required on heat treatment charts along with operator signature & date.
- Verification of furnace thermocouple calibration required.
- A sufficient number of thermocouples shall be located to control and maintain uniform distribution of temperature on all vessels and parts. Thermocouples shall be directly attached to the item or provision shall be made for thermocouple placement at bottom, center and top of the furnace charge in accordance with the ASME Code.
- No welding shall be performed on vessels or parts.

Furnace Heat Number: 11608

Furnace Operator Signature: *D. Muller*

Date: Feb 18, 05

Q.C. Inspector Signature: *C. Zelle*

Date: February 18, 2005

JOB #10252 BLUESTAR

QCI DATE

DATE: Feb 28/05

10252-P
02/28/05
CZL

Ph. (780) 539-5525

Chart # 11608

Feb 18, 05

Muller

10252-P

02/19/05

CM

4 hr 5 min Soak

@ 1150 + 25-

pg 1 of 2

10252-P

14:00
01 642°F
02 642°F

1999

CHART NO. 1906ANI

0 200 400 600 800 1000 1200 1400 1600 1800 2000

Feb. 18. 05

14:00

01 642°F

02 642°F

3

01CH

50mm/h

1999

YOM JWA

JOB # 10252-BLUESTAR

QCI

DATE

QCM

DATE

28/

Feb/05

- Start of Cycle

10252-P
02/28/05
CM

Feb. 18. 05
22:00
01 537°F
02 537°F

01 -- End of Cycle

Pg 2 of 2

Feb. 18. 05
20:00
01 844°F
02 844°F
50mm/h

Feb. 18. 05
18:00
01 2008°F
02 1148°F
50mm/h

Norweld Stress Ltd.

11434 91st Ave.

Grande Prairie, AB

T8V 6K6

Ph. (780) 539-5525

Chart # 11608

Feb. 18. 05

10252-P

02/28/05

CPL

ФАХ: (780) 539-5916

CHART / SHEET NUMBER 11608

CLIENT Blue Star Weaving JOB NO. 10252-P
SHIP _____ STATE/ CUST P.O. NO. FEB 19, 05
PROVINCE CHL

PROCEDURE REFERENCE			
RATE OF RISE UNRESTRICTED SOAK TEMP.		$+250$ °F HR. MAX 800 °F °F	
RATE OF COOL UNRESTRICTED FROM °F		400 °F HR. MAX 800 °F °F	
$1150 + 25 -$			
SOAK PERIOD HRS.		MINS.	
4 hrs.		5 min.	
Ph.	PREHEAT °F MIN.	°F MAX	INSULATION REMOVED AT °F
ϕ			
SPECIAL REMARKS Left in Oven until ambient temp.			
RECORDER NUMBER 126719130	CHART SPEED 50 mm/min	CALIBRATED $July 105$	

APPROVED BY _____ DATE _____

[illegible]

EQUIPMENT CONSUMABLES	QUANTITY
Stress Oven 35	
Stress relief Linchpins	
coil as requested	

SIGHT TIME					HOURS
TECH	DATE	START	FINISH	REGULAR	O.T.
L.m.	02/15/05	7 PM			

TRAVEL TIME TECH	DATE	HOURS	VEHICLE	MILEAGE

This image shows a full page of blank graph paper. The grid consists of small squares formed by thin black lines. There are approximately 20 columns and 25 rows of squares. A thicker vertical line runs down the right side of the page, about one-fifth of the way from the edge, creating a margin. Another thicker horizontal line runs across the top of the page, about one-tenth of the way from the edge, creating a header space. The rest of the page is filled with the standard grid pattern.

NAME LEE MULLER DATE FEB 17 65

NAME CHRIS FLETCHER DATE 2/20/17

NAME CHRIS FLETCHER DATE 2-2-78



PRESSURE TEST EXAMINATION GUIDE		
PRESSURE TEST PREPARATION		Q.C. INSP.
1.	All punch list items corrected.	✓
2.	Test blinds are of correct thickness.	✓
3.	All items which could be damaged by test isolated or removed (control valves, safety valves, instruments, expansion joints, etc.)	✓
4.	Equipment with internals (i.e. filters) that could be damaged isolated as required.	✓
5.	Vents and drains correctly installed.	✓
6.	Open and Closed position of all valves verified.	✓
7.	Shipping bars in place - bellows.	✓
8.	Hanger stops in place.	✓
JOB #10252 BLUESTAR QCI _____ DATE _____ QCM <i>[Signature]</i> DATE <i>Feb 28/05</i>		
PRESSURE TEST COMPLETION		Q.C. INSP.
1.	All temporary blinds (blanks) removed.	✓
2.	Temporary gaskets changed for correct gaskets.	✓
3.	Temporary supports removed.	✓
4.	Shipping bars removed from bellows.	✓
5.	Spring hanger stops removed - cold setting checked.	✓
6.	Safety valves - "UV" or "V" symbol and correct set pressure and capacity installed.	✓
7.	Safety valve vents are correct size - adequately supported - drain holes and or weather hoods installed.	✓
8.	Screens for pumps and compressors installed (initial start-up and permanent screens).	✓
Q. C. Inspector Signature: <i>[Signature]</i>		Date: <i>Feb 24, 05</i>

10252-P
02/28/05
[Signature]



Hydrostatic Test Report

Date: FEB. 24. 2005

Job Number: 10252-P

Customer: PURE ENERGY

Product Used For Test: H₂O

Test Conducted By: DAKER PRESSURE TEST

Test Pressure: 15,000 PSI

Holding Time @ Test Pressure: 1 HOUR

Results: NO LEAKS

Authorized Inspector Witnessing Test: HARVEY WOODY

Comments: _____

JOB #10252 BLUESTAR	
QCI _____	DATE _____
QCM <u>RAW</u>	DATE <u>FEB 28 / 05</u>

CFL
Quality Control Manager

10252-P
02/29/05
CFL

EQUIPMENT CALIBRATION LOG			
EQUIPMENT DESCRIPTION: <i>WGI 20,000 PSI PRESSURE GAUGE</i>			
IDENTIFICATION NO.: <i>BSPG 20000 1</i>		CALIBRATION INTERVAL:	

Calibration Date	Calibration Record Verified	Date of First Use	Calibration Expiry Date
<i>FEB 19, 2005</i>	<i># 43237</i>	<i>FEB 24, 2005</i>	<i>AUG 2005</i>

Calibration requirements and Instructions:

EQUIPMENT CALIBRATION LOG			
EQUIPMENT DESCRIPTION: <i>WGI 20000 PSI PRESSURE GAUGE</i>			
IDENTIFICATION NO.: <i>BSPG 20000 2</i>		CALIBRATION INTERVAL:	

Calibration Date	Calibration Record Verified	Date of First Use	Calibration Expiry Date
<i>FEB 19, 2005</i>	<i># 43237</i>	<i>FEB 24, 2005</i>	<i>AUG 2005</i>

Calibration requirements and Instructions:

JOB # *10252* **BLUESTAR**

QCI _____ DATE _____

QCM *[Signature]* DATE *Feb 28/05*

*10252-P
02/29/05
CPL*



10252-1
02/20/05
c-76

CERTIFICATE OF CALIBRATION
#43237

BSPG 20000 1

ORDER NO. 102414
SERIAL NUMBER JW050217-5
DIAL SIZE 4" WGI
PRESSURE RANGE 0-20,000 PSI
SUB DIVISIONS 2000 PSI
CONNECTION 1/2" NPT
INSPECTOR G.J.P. WOWK

AMBIENT TEMPERATURE 20C
DEADWEIGHT SN# 8604
TEST MEDIUM OIL
MAXIMUM ERROR +140 PSI
DATE February 18, 2005
LOCATION TESTED 9535 - 42 AVE
EDMONTON, ALBERTA, T6E 5R2

TESTED GAUGE

DEADWEIGHT

UPSCALE ERROR

0

0

0

2000	PSI	2000	PSI	0	PSI
4000	PSI	4000	PSI	0	PSI
6000	PSI	6000	PSI	0	PSI
8000	PSI	8000	PSI	0	PSI
10,000	PSI	10,000	PSI	0	PSI
12,000	PSI	12,000	PSI	0	PSI
14,000	PSI	14,000	PSI	0	PSI
16,000	PSI	16,000	PSI	0	PSI
18,000	PSI	17,970	PSI	+30	PSI
20,000	PSI	19,860	PSI	+140	PSI

TECHNICIAN:

Michael Kowalski

Q.C. Manager:

Lynn Wowk

Invoice: PCL-50227

****ALL TEST EQUIPMENT IS TRACEABLE TO N.I.S.T. STANDARDS.**

****CUSTOMER STANDARD DOCUMENT CS-004.**



10252-0
02/23/05
CZL

CERTIFICATE OF CALIBRATION
#43222

BSPG 20000 2

ORDER NO.	102414	AMBIENT TEMPERATURE	20C
SERIAL NUMBER	JW050217-6	DEADWEIGHT	SN# 8604
DIAL SIZE	4" WGI	TEST MEDIUM	OIL
PRESSURE RANGE	0-20,000 PSI	MAXIMUM ERROR	-100 PSI
SUB DIVISIONS	2000 PSI	DATE	February 18, 2005
CONNECTION	1/2" NPT	LOCATION TESTED	9535 - 42 AVE
INSPECTOR	G.J.P. WOWK	EDMONTON, ALBERTA, T6E 5R2	

<u>TESTED GAUGE</u>		<u>DEADWEIGHT</u>		<u>UPSCALE ERROR</u>	
0		0		0	
2000	PSI	2100	PSI	-100	PSI
4000	PSI	4030	PSI	-30	PSI
6000	PSI	6000	PSI	0	PSI
8000	PSI	8000	PSI	0	PSI
10,000	PSI	10,000	PSI	0	PSI
12,000	PSI	12,000	PSI	0	PSI
14,000	PSI	14,000	PSI	0	PSI
16,000	PSI	16,000	PSI	0	PSI
18,000	PSI	18,000	PSI	0	PSI
20,000	PSI	20,000	PSI	0	PSI

TECHNICIAN:

Michael Kowalski


Q.C. Manager:

Lynn Wowk

Invoice: PCL-50227

**ALL TEST EQUIPMENT IS TRACEABLE TO N.I.S.T. STANDARDS.

**CUSTOMER STANDARD DOCUMENT CS-004.



JOB #/0252-BLUESTAR

QCI _____ DATE _____

QCM *[Signature]* DATE Feb 28/05



NCR #

NONCONFORMITY REPORT

JOB NUMBER:

DESCRIPTION OF NONCONFORMANCE:

N/A

SIGNATURE OF ORIGINATOR:

DATE:

PROPOSED DISPOSITION, REPAIRS OR METHOD OF IDENTIFICATION:

QCM APPROVAL:

DATE:

AUTHORIZATION INSPECTORS ACCEPTANCE:

DATE:

NONCONFORMANCE RECTIFIED:

QCM VERIFICATION:

DATE:

AUTHORIZED INSPECTORS ACCEPTANCE:

DATE: