



TEST ONLY REPORT

CERTIFICATION NUMBER

EP150609-2

DATE: 6/9/2015 LOC: JOB NUMBER: 95032014

CUSTOMER: FMC CONTACT: PHONE NUMBER: LH-0010

CONDITION RECEIVED				VALVE INFORMATION			
Received By	ELI PEMBERTON			PN #	NOT		
Date Received	6/9/2015			SERIAL #	772798 NOT		
Inspected By	MARTY BURR			Location	NOT		
Seal	NOT			Vessel Type	SCRUBBER		
Seal ID	NOT			KN #	1D1V1E1		
Name Plate	INTACT			ID #	NOT		
PARTS				PRE-TEST			
Gasket Set		PRE-TEST	140	Inlet	1	MNPT	
Nozzle		AS FOUND		Outlet	1	FNPT	
Body		SET PRESSURE @	140	Service	GAS		
Disc		LEAKED	NO	Manufacturer	MERCER		
Disc Holder				Style	THREADED		
Guide				Code Stamp	UV	NB	
Stem/Spindle		PASS/FAIL	PASS	Cap/Bonnet	SECURED		
Disc Retainer		RESET	YES	Belows Rating	NOT		
Spring		SET PRESSURE	150	CRN#	EP150609-2		
Comp. Screw/Adj. Bolt				ASME	NOT		
Lock Nut				Code Applied	TEST ONLY		
Upper Button/Washer				CRITICAL DIMENSIONS			
Lower Button/Washer				Measured Manufacturer			
Soft Goods Kit		Date Tested	6/9/2015	Nozzle Length Min			
Adj. Ring - lower		Test & F. Inspection By	EP	Nozzle Seat Step Min			
Adj. Ring Pin - lower		Witnessed By	MB	Nozzle Seat D Max			
Adj. Ring - upper		Test Media	NITROGEN	Nozzle Seat OD Min			
Adj. Ring Pin - upper		Gauge 1	CRYSTAL	Disc Thickness Min			
Bonnet		Gauge 2	NONE	Disc Inside Step Min			
Cap		Final Test Pressure	150 PSI	Disc Outside Step Min			
Lift Lever		Leakage Rate PSI	PSI/MIN	Disc Seat OD Min			
Inlet Condition		Back Pressure Test	PASS	Additional Comments:			
Inlet Flange Face		Test Only	YES				
Outlet Condition		Repair Req.	NO				
Outlet Flange Face		Replaced	NO	REF #			
Mfg. Nameplate		FINAL TEST RESULTS		PART DESCRIPTION	PART #	CODE	QTY
O-Ring		Set Pressure:	150 PSI				
Fasteners		Capacity:	329 SCFM				
Coatings		Cap:	SEALED				
DEFINITION CODES G= Good P= Poor D= Damaged R= Replaced C= Corroded N= N/A		Isolation Valve:	YES IN PLACE				
		Tarpon Tag:	YES TEST				
		Pressure Test:	PASS 30 SEC				
		Cap Code:	PASS 2015				
		FINAL TEST COMMENTS:					
		VALVE PASSED @	150 PSI				
		VALVE #	2 OF 4				

ADDITIONAL COMMENT: ADJUST SET PRESSURE TO 150

CUSTOMER SIGNATURE	TESTER SIGNATURE	WITNESS SIGNATURE
	ELI PEMBERTON	MARTY BURR