

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

(A) 2972608

1. Manufactured and certified by NATCO CANADA LTD. 9423 Shepard Rd. SE Calgary, Alberta T2C 1E2
(Name and address of Manufacturer)
2. Manufactured for CHEVRON CANADA RESOURCES 500 - 5th Ave SW Calgary, Alberta
(Name and address of Purchaser)

3. Location of installation LSD: 11-22-49-12 WSM
(Name and address)

4. Type HORIZONTAL REBOILER/SURGE TANK LM-2895 M3154.2 D-6083-52 N/A 1994
(Horiz., vert., or sphere) (Tank, separator, etc.) (Mfg's serial No.) (CRN) (Drawing No.) (Nat'l Bd No.) (Year built)

5. ASME Code, Section VIII, Div. 1992 A'92
Edition and Addenda (date) Code Case No. Special Service per UG-120(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, shell of heat exchangers, or chamber of multi-chamber vessels
6. Shell (a) No. of course(s) 6 (b) Overall length (ft & in.) 35' 0"

Course(s)			Material	Thickness		Long Joint (Cat. A)			Circum. Joint (Cat. A, B & C)			Heat Treatment	
No	Diameter, in.	Length (ft & in.)	Spec./Grade or Type	Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time
1-3	48"	3x10'0"	SA 516-70N	375	125	1	FULL	100	1	FULL	100	1150	1 hr
4&5	48x24"	4' 7"	SA 516-70N	375	125	1	FULL	100	1	FULL	100	1150	1 hr
5	24"	0' 10"	SA 516-70N	375	125	1	FULL	100	1	FULL	100	1150	1 hr

7. Heads: (a) SA 516-70N (b) ---
(Mat'l Spec. No., Grade or Type) H.T. - Time & Temp (Mat'l Spec. No., Grade or Type) H.T. - Time & Temp

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical	Conical	Hemispherical	Fiat	Side to Pressure		Category A				
		Min.	Corr.	Crown	Knuckle	Ratio	Apex Angle	Radius	Diameter	Convex	Concave	Type	Full	Spot	None	Eff.
(a)	END	481	125			2:1					Yes	N/A	None			100
(b)																

If removable, bolts used (describe other fastening) N/A
(Mat'l Spec. No., Grade, size, No.)

8. Type of jacket N/A Jacket closure N/A
(Describe as ogee & weld, bar, etc.)

If bar, give dimensions N/A If bolted, describe or sketch

9. MAWP 127 psi at max. temp. 400 °F Min. design metal temp. -20 °F at 127 psi
(internal) (external) (internal) (external)

10. Impact test No Exempt per UG-20f
(Indicate yes or no and the component(s) impact tested)

11. Hydro, pneu. or comb. test press. 191 psi Proof test N/A

Items 12 and 13 to be completed for tube sections.

12. Tubesheet SA 516-70N 23.125" 2.375 .125" Bolted
Stationary (Mat'l Spec. No.) Dia., in. (subject to press.) Nom. thk., in. Corr. Allow., in. Attachment (welded or bolted)

Floating (Mat'l Spec. No.) Dia., in. Nom. thk., in. Corr. Allow., in. Attachment

13. Tubes SA-179 .750" 14.9WG 78 U
Mat'l Spec. No., Grade or Type O.D., in. Nom. thk., in. or gauge Number Type (Straight or U)

Items 14-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers.

14. Shell (a) No. of course(s) 1 (b) Overall length (ft & in.): 1' 1"

No	Course(s)		Material	Thickness		Long Joint (Cat. A)			Circum. Joint (Cat. A, B & C)			Heat Treatment	
	Diameter, in	Length (ft & in.)	Spec./Grade or Type	Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time
1	24"	1' 1"	SA 106B	.375	125	SMLS	None	100	1	FULL	100	1150	1 hr

15. Heads: (a) SA 516-70N (b) ---
(Mat'l Spec. No., Grade or Type) H.T. - Time & Temp (Mat'l Spec. No., Grade or Type) H.T. - Time & Temp

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full	Spot
(a)	END	.312	.125			2:1					Yes	N/A	None	100
(b)														

If removable, bolts used (describe other fastening) 20 - 1 1/4 x 2" long studs c/w nuts SA 193-B7M / 194-2HM
(Mat'l Spec. No., Grade, Size, No.)

(A) 2972608

16. MAWP 155 (internal) (external) psi at max. temp 545 (internal) (external) °F Min. design metal temp -20 °F at 545 ps

17. Impact test No. Exempt per UG-20F and UCS-66
(Indicate yes or no and the component(s) impact tested)

18. Hydro., pneu. or comb. test press 233 psi Proof test N/A

19. Nozzles, inspection, and safety valve openings

Purpose (inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Flange Type	Material		Nozzle Thickness		Reinforcement Material	How Attached		Location (Insp. Open)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
T.S. Inlet	1	4"	RF/N	SA106B	SA105N	.337	.125	Integral	Welded	Welded	T.S. She
T.S. Outlet	1	4"	RF/N	SA106B	SA105N	.337	.125	Integral	Welded	Welded	T.S. She
Spares	2	1"	CPLG	SA105N	--	6000#	.125	Integral	Welded	--	Nozzle
Spares	2	3/4"	CPLG	SA105N	--	6000#	.125	Integral	Welded	--	Nozzle

20. Supports: Skirt No (Yes or No) Lugs Nil (No.) Legs Nil (No.) Others Saddles - 2 (Describe) Attached S. Side Shell - Weld (Where and How)

21. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:

(List the name of part, item number, mfg's. name and identifying number)

Tube side channel and "U" tube bundle Serial No. 94-2716, Altex Heat Exchanger Ltd., U-26,435, CRN M3578.2

22. Remarks: Tube Surface Area 551 sq.ft. (51.18 m²)

Volume: 337 cu/ft (10.67 m³)

Vessel Type: Amine Reboiler/ Surge Tank

Tag No: E-4400

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1,

U Certificate of Authorization No. 11313 Expires September 9, 19 95

Date June 16/94 Name NATCO CANADA LTD. Signed [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Alberta and employed by Alberta Labour - Boiler & Pressure Vessel Safety of Alberta have inspected the pressure vessel described in this Manufacturer's Data Report on June 16, 19 94, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date June 16, 94 Signed [Signature] Commissions Alberta #11
(Authorized Inspector) (Nat'l Board incl. endorsement, State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the statements on this report are correct and that the field assembly construction of all parts of this vessel conforms with the requirements of ASME Code, Section VIII, Division 1,

U Certificate of Authorization No. _____ Expires _____, 19 _____

Date _____ Name _____ Signed _____
(Assembler) (Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by _____ of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Nat'l Board incl. endorsement, State, Province and No.)

As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

(Name and address of manufacturer)

(Name and address of purchaser)

(Name and address)

1944-1945

（四）

Shop Order: 6083-52

ORM U-2 MANUFACTURER'S PARTIAL TA REPORT

A Part of a Pressure Vessel Fabricated by One Manufacturer for Another Manufacturer
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

(A) 2972608

1. Manufactured and certified by Altex Heat Exchanger Ltd., 6831-42 Street, Edmonton, Alberta, T6B 2X
(Name and address of manufacturer)
2. Manufactured for Natco Canada, 9423 Shepard Road S.E., CALGARY, Alberta, T2C 1E2
(Name and address of purchaser)
3. Location of installation Chevron Canada Resources, West Pembina Gas Plant 11-22-49-12 WSM
(Name and address)
4. Type Heat Exchanger 94-2716 M3578.2 94-2716-Drwg 1-REV 3 1994
(Name or part, tank) (Manufacturer's No. of Part) (CRN) (Drawing No.) (Part's Ed. No.) (Year Built)
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1. 1992
Year
- 1993
Addenda (Date)
- Code Case No. _____ Special service per UG 120(c) _____

6. (a) Drawing prepared by Altex Heat Exchanger Ltd. (b) Description of part inspected Channel and "U" Tube Channel
7. Postweld heat treatment: Temp. 1150 °F Time 60 minutes (Channel and "U" Bends on Tube Bundle)
Items 8-13 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

8. Shell: _____
Matl. (Spec. No., Grade) _____ Nom. Thk. (in.) _____ Cor. Allow. (in.) _____ Diam. I.D. (ft & in.) _____ Length (overall) (ft & in.) _____

9. Seams: _____
Long. (Weld, Dbl., Sngl., Lap, Butt) _____ R.T. (Spot or Full) _____ Eff. (%) _____ H.T. Temp. (°F) _____ Time _____ Girth (Weld, Dbl., Sngl., Lap, Butt) _____ R.T. (Spot, Partial, or Full) _____ No. of Cores _____

10. Heads: (a) Matl. _____ (Spec. No., Grade) _____ (b) Matl. _____ (Spec. No., Grade) _____

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)									
(b)									

If removable, bolts used (describe other fastenings) _____
(Matl., Spec. No., Gr., Size, No.)

11. Type of Jacket _____ Proof Test _____

12. Jacket Closure _____
(Describe as open & weld, bar, etc.) _____ If bar, give dimensions _____
If bolted, describe or sketch.

13. MAWP _____ psi at max. temp. _____ °F. Min. temp. (when less than -20°F) _____
Hydro., pneu., or comb. test press. _____ psi.

Items 14 and 15 to be completed for tube sections

14. Tubesheets: SA516-70N 23.125" 2.375" .125 Intermediate
Stationary Matl. (Spec. No., Gr.) _____ Diam. (in.) (Subject to pressure) _____ Nom. Thk. (in.) _____ Cor. Allow. (in.) _____ Attach. (Weld, Bolted) _____

- _____ SA179 .750" 14 BWG 78 "U" Type
Floating Matl. (Spec. No., Gr.) _____ Diam. (in.) _____ Nom. Thk. (in. or gauge) _____ No. _____ Type (straight or "U") _____

Items 16-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

16. Shell: SA106B .375" .125" 23.250" 1'-1"
Matl. (Spec. No., Gr.) _____ Nom. Thk. (in.) _____ Cor. Allow. (in.) _____ Diam. I.D. (ft & in.) _____ Length (overall) (ft & in.) _____

17. Seams: _____
Long. (Weld, Dbl., Sngl., Lap, Butt) _____ R.T. (Spot or Full) _____ Eff. (%) _____ H.T. Temp. (°F) _____ Time _____ Girth (Weld, Dbl., Sngl., Lap, Butt) _____ R.T. (Spot, Partial, or Full) _____ No. of Cores _____

18. Heads: (a) Matl. SA516-70N (Spec. No., Grade) _____ (b) Matl. _____ (Spec. No., Grade) _____

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a) <u>End</u>	<u>.3125</u>	<u>.125"</u>			<u>2:1 S/E</u>			<u>23.125"</u>	<u>Concave</u>

If removable, bolts used (describe other fastenings) 20-1 1/2" x 9" Long SA193-B7M Studs c/w SA194-2HM Nuts
(Matl., Spec. No., Grade, Size, No.)

Form U-2 (Back)

19. MAWP 155 psi at max. temp. 545 F. Min. temp. (when less than -20 F) -20
Hydro. pneu. or comb. test press. 233 psi.

Items below to be completed for all vessels where applicable

20. Nozzles, Inspection and Safety Valve Openings:

[illegible]

21. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or no) (No) (No) (Describe) (Where and how)

22. Remarks: This form represents a replacement Channel and "U" Tube Bundle. Unit exempt from Impact testing as per UG20(f) and USC-66. Effective tube surface 551 sq. ft. Channel and "U" Tube Bundles built to Drwg. 94-2716-Drwg-1-REV 5.

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

to the ASME Code for Pressure Vessels, Section VIII, Division 1.
 "U" Certificate of Authorization No. 26,435 expires July 13, 1995
 Date May 9/94 Co. name Altex Heat Exchanger Ltd. Signed [Signature]
(Manufacturer) (Inspector)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Alberta and employed by Dept. of Labour, Boiler and Pressure Vessel Safety

of Alberta have inspected the pressure vessel described in this Manufacturer's Partial Data Report on 9 May
19 94, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this part in accordance with the ASME Boiler
and Pressure Vessel Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or
implied, concerning the part described in this Manufacturer's Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable
in any manner for any personal injury or property damage or loss of any kind resulting from or connected with this inspection.
Date 9 May 94 Signed D. W. Koster Commission Alberta
(When a Board member inspects, please print name and title)