

ELECTRICAL EXHIBIT

BATTERY TEST REPORT



Client / Project Name:	Fuelled / Capstone C600S Natural Gas Gen Inspection	Form No:	PHO-Q-500.3.05 R2
PES Project No:		Contract / PO / AFE:	
Client Reference:		Building / Skid No:	
Location:	Capstan Hauling 10102 95 Ave, Clairmont, AB T8X 0M6	Building / Skid Name:	600 kw Capstone C600S
Test Equipment Used:	Fluke 1587 FC	Test Equip Serial No:	59470166

GENERATOR INFORMATION

Manufacturer:	Capstone	Serial No:	9269
Model:	C-600S	Year:	2016

INSPECTION

P/N	SER. NO	Battery No.	Cell Condition	Voltage	ENGINE FILTER	DESICCANT/SEAL
513182201358	000417	BAY-B #1	N/A	288.6 VDC	BAY-B INSTALLED	BAY-B INSTALLED
513182201358	000393	BAY-B #2	N/A	290.4 VDC		
513182201358	000415	BAY-C #1	N/A	289.6 VDC	BAY-C INSTALLED	BAY-C INSTALLED
513182201125	000413	BAY-C #2	N/A	290.3 VDC		
513182201358	000402	BAY-D #1	N/A	292.9 VDC	BAY-D INSTALLED	BAY-B INSTALLED
513182201358	000385	BAY-D #2	N/A	291.5 VDC		

NOTES

Please reference attached pictures

INSPECTION AND APPROVAL

Phoenix Rep	Name: Matt Cox Role:	Signature: <i>Matt Cox</i>	Date: Oct 17, 2023
Client Rep	Name: Role:	Signature:	Date: