



 RAE Engineering and Inspection Ltd 4810 - 93 Street Edmonton, AB, T6E 5M4 ph: 780-469-2401 fx: 780-468-2422		Inspection Date:		21-Nov-24		Ultrasonic Thickness Examination									
		Report Date:		6-Dec-24											
		Page:		1 of 7											
Client:		Midstream Equipment				Report Number:		24-PR0003757-CJ-UT-01							
Facility:		Valhalla				Location/LSD:		14-30-074-08 W6							
Equipment Number:		A0639408 (Unit-1223)				Client Representative:		N/A							
Equipment Description:		Horizontal Separator				Client Contact:		N/A							
JOB DESCRIPTION															
Procedure:		NDE Technical Manual Rev. 2 (NDE-701B)				Surface Condition:		☐ Coated ☐ Bare Steel ☒ Painted ☐ Ground ☐ Blasted ☐ Buffed							
Acceptance Code:		ASME Sec. VIII Div. 1 / ASME B31.3				Surface Temp:		☐ < 0 °C ☒ 0 - 120 °C ☐ 120 - 260 °C ☐ > 260 °C							
Material:		Carbon Steel													
EQUIPMENT, TECHNIQUE & CALIBRATION															
Instrument 1 Mfr:		GE		Model:		DMSGO+		S/N:		GOPLS17070020		Cal. Due:		14-May-25	
Instrument 2 Mfr:				Model:				S/N:				Cal. Due:			
Cal Block 1 S/N:		21-2504		1 or 2 Point Cal:		☐ 1 ☒ 2		Calibrated Range:		0.250" - 1.000"		Couplant:		UTX	
Cal Block 2 S/N:				1 or 2 Point Cal:		☐ 1 ☐ 2		Calibrated Range:				Couplant:			
	Probe Model	Freq MHz	Angle	Dia. (in)	Probe Type		Manufacturer	Serial #	Cable Length	Vel. (m/sec)	Ref dB	Scan dB	Range (in)		
					Single	Dual									
1	FH2E	5.0	0°	0.25	☐	☒	Stresstel	15A00JGG	4'	5850	60	As Needed	2		
2					☐	☐									
Scope: Conduct 0° straight beam ultrasonic testing on Horizontal Separator assessing the <i>components</i> for any signs of wall thinning due to corrosion, erosion, laminations, or inclusions.															
Results: The measurements obtained from the inspection locations showed the thickness of all of the components inspected to be consistent in thickness, however no nominal thicknesses were available for some CMLs . There were no signs of wall thinning, internal corrosion, erosion, laminations or inclusions at the time of inspection. All piping measurements were within the 12.5% mill tolerance, as per ASTM specifications with the exception of CML 65, which was found to be lower than that.															
Please see the following pages for the pictures of the nameplate and the overall view, the isometric drawings, and the thickness measurements.															
Nominal ASME Tolerance Corrosion Allowance  1) Black - Within ASME Tolerance 2) Blue - ≤ Nominal minus ASME Tolerance 3) Red - ≤ Nominal minus ASME Tolerance minus CA or ≤ Nominal minus ASME Tolerance (if CA = N/S)															
1 ST Technician		Chaitanya Joshi								CGSB#:		CGSB Level:			
		PRINT								SNT#:		SNT Level:			
2 ND Technician										CGSB#:		CGSB Level:			
		PRINT								SNT#:		SNT Level:			



RAE Engineering and Inspection Ltd
4810 - 93 Street Edmonton, AB, T6E 5M4
ph: 780-469-2401 fx: 780-468-2422

Inspection Date:	21-Nov-24
Report Date:	6-Dec-24
Page:	2 of 7

Ultrasonic Thickness Examination

Client:	Midstream Equipment	Report Number:	24-PR0003756-CJ-UT-01
Facility:	Valhalla	Location/LSD:	15-11-025-09 W6
Equipment Number:	A0532999 (Unit-1183)	Client Representative:	N/A
Equipment Description:	Dual Chamber Scrubber	Client Contact:	N/A

FLAGGED CMLs

CML #	CML Description	Nom. [in]	Mil. [in]	CA [in]	Ave. [in]	Min. [in]
65	4 XH 90° Elbow	0.337	0.042	N/S	0.296	0.289



- 1) Black - Within ASME Tolerance
- 2) Blue - $\leq$ Nominal *minus* ASME Tolerance
- 3) Red - $\leq$ Nominal *minus* ASME Tolerance *minus* CA or $\leq$ Nominal *minus* ASME Tolerance (if CA = N/S)

CA: Corrosion Allowance | Nom.: Nominal | Mil.: Manufacturer's Undertolerance = Piping - 12.5% - ASME IIA-2, SA-530 OR Plate - 0.010in/0.25mm or 6% - ASME VIII Div. 1, UG-16



RAE Engineering and Inspection Ltd
4810 - 93 Street Edmonton, AB, T6E 5M4
ph: 780-469-2401 fx: 780-468-2422

Inspection Date:	21-Nov-24
Report Date:	6-Dec-24
Page:	3 of 7

Ultrasonic Thickness Examination

Client:	Midstream Equipment	Report Number:	24-PR0003757-CJ-UT-01
Facility:	Valhalla	Location/LSD:	14-30-074-08 W6
Equipment Number:	A0639408 (Unit-1223)	Client Representative:	N/A
Equipment Description:	Horizontal Separator	Client Contact:	N/A

PHOTOGRAPHS



View of Nameplate & LSD



View of Equipment




RAE Engineering and Inspection Ltd
4810 - 93 Street Edmonton, AB, T6E 5M4
ph: 780-469-2401 fx: 780-468-2422

Inspection Date:	21-Nov-24
Report Date:	6-Dec-24
Page:	4 of 7

Ultrasonic Thickness Examination

Client:	Midstream Equipment	Report Number:	24-PR0003757-CJ-UT-01
Facility:	Valhalla	Location/LSD:	14-30-074-08 W6
Equipment Number:	A0639408 (Unit-1223)	Client Representative:	N/A
Equipment Description:	Horizontal Separator	Client Contact:	N/A

EQUIPMENT CML ISO DRAWING



 RAE Engineering and Inspection Ltd 4810 - 93 Street Edmonton, AB, T6E 5M4 ph: 780-469-2401 fx: 780-468-2422		Inspection Date:		21-Nov-24		Ultrasonic Thickness Examination											
		Report Date:		6-Dec-24													
		Page:		5 of 7													
		Client:		Midstream Equipment				Report Number:		24-PR0003757-CJ-UT-01							
Facility:		Valhalla				Location/LSD:		14-30-074-08 W6									
Equipment Number:		A0639408 (Unit-1223)				Client Representative:		N/A									
Equipment Description:		Horizontal Separator				Client Contact:		N/A									
CML DATA																	
Units: inches																	
CML	Description					01	02	03	04	05	06	07	08	09	10	11	12
05	6 Nozzle													Min. =	1.410	Ave. =	1.416
	Nom:	N/S	Mil:	N/S	CA: N/S	1.413	1.410	1.418	1.423								
10	Lower Head													Min. =	1.458	Ave. =	1.469
	Nom:	1.438	Mil:	N/S	CA: 0.125	1.465	1.468	1.465	1.474	1.458	1.460	1.468	1.476	1.474	1.477	1.471	1.473
15	Bottom Shell													Min. =	1.484	Ave. =	1.494
	Nom:	1.500	Mil:	N/S	CA: 0.125	1.492	1.491	1.497	1.502	1.499	1.484	1.491	1.497	1.494	1.493	1.489	1.495
20	Lower Shell													Min. =	1.497	Ave. =	1.505
	Nom:	1.500	Mil:	N/S	CA: 0.125	1.513	1.514	1.516	1.510	1.506	1.500	1.498	1.500	1.497	1.499	1.500	1.507
25	Bottom Shell													Min. =	1.488	Ave. =	1.502
	Nom:	1.500	Mil:	N/S	CA: 0.125	1.496	1.489	1.488	1.493	1.496	1.506	1.510	1.511	1.504	1.505	1.507	1.513
30	Mid Shell													Min. =	1.502	Ave. =	1.513
	Nom:	1.500	Mil:	N/S	CA: 0.125	1.515	1.518	1.502	1.507	1.509	1.508	1.515	1.519	1.517	1.518	1.520	1.513
35	Bottom Shell													Min. =	1.491	Ave. =	1.507
	Nom:	1.500	Mil:	N/S	CA: 0.125	1.491	1.499	1.498	1.503	1.502	1.506	1.510	1.514	1.513	1.517	1.521	1.515
40	Bottom Shell													Min. =	1.510	Ave. =	1.518
	Nom:	1.500	Mil:	N/S	CA: 0.125	1.521	1.519	1.516	1.518	1.516	1.519	1.525	1.522	1.517	1.519	1.516	1.510
45	Upper Shell													Min. =	1.509	Ave. =	1.512
	Nom:	1.500	Mil:	N/S	CA: 0.125	1.510	1.515	1.514	1.513	1.511	1.510	1.509	1.515	1.511	1.514	1.512	1.509
50	Lower Head													Min. =	1.483	Ave. =	1.494
	Nom:	1.438	Mil:	N/S	CA: 0.125	1.483	1.488	1.491	1.497	1.503	1.495	1.494	1.497	1.492	1.499	1.492	1.500
55	4 XH 90° Elbow													Min. =	0.321	Ave. =	0.325
	Nom:	0.337	Mil:	0.042	CA: N/S	0.321	0.324	0.325	0.326	0.323	0.328						
60	4 XH 90° Elbow													Min. =	0.335	Ave. =	0.337
	Nom:	0.337	Mil:	0.042	CA: N/S	0.335	0.338	0.339	0.335	0.337	0.336						
65	4 XH 90° Elbow													Min. =	0.289	Ave. =	0.296
	Nom:	0.337	Mil:	0.042	CA: N/S	0.302	0.306	0.293	0.289	0.290	0.293						
70	2 XH 90° Elbow													Min. =	0.258	Ave. =	0.262
	Nom:	0.218	Mil:	0.027	CA: N/S	0.263	0.267	0.260	0.258								
75	2 160 90° Elbow													Min. =	0.312	Ave. =	0.315
	Nom:	0.344	Mil:	0.043	CA: N/S	0.312	0.314	0.316	0.318								
80	2 XH 90° Elbow													Min. =	0.198	Ave. =	0.200
	Nom:	0.218	Mil:	0.027	CA: N/S	0.199	0.198	0.203	0.201								
85	2 XH 90° Elbow													Min. =	0.219	Ave. =	0.222
	Nom:	0.218	Mil:	0.027	CA: N/S	0.221	0.219	0.225	0.222								
90	2 XH 3"X2" Tee													Min. =	0.269	Ave. =	0.368
	Nom:	0.218	Mil:	0.027	CA: N/S	0.395	0.401	0.383	0.385	0.419	0.416	0.269	0.272				
NPS = Nominal Pipe Size Sch = Schedule Rating = Flange Pressure Rating Nom = Nominal CA = Corrosion Allowance Ave = Average Min = Minimum Mil = Manufacturer's Undertolerance = Piping - 12.5% - ASME IIA-2, SA-530 OR Plate - 0.01in/0.25mm or 6% - ASME VIII Div. 1, UG-16																	



RAE Engineering and Inspection Ltd
4810 - 93 Street Edmonton, AB, T6E 5M4
ph: 780-469-2401 fx: 780-468-2422

Inspection Date:	21-Nov-24
Report Date:	6-Dec-24
Page:	6 of 7

Ultrasonic Thickness Examination

Client:	Midstream Equipment	Report Number:	24-PR0003757-CJ-UT-01
Facility:	Valhalla	Location/LSD:	14-30-074-08 W6
Equipment Number:	A0639408 (Unit-1223)	Client Representative:	N/A
Equipment Description:	Horizontal Separator	Client Contact:	N/A

CALIBRATION CERTIFICATE



RAE Engineering and Inspection Ltd.

OVER
50
YEARS

NDE-709D Thickness Gage Horizontal Linearity Certificate of Calibration

Instrument Make:	GE	Transducer Make:	Stresstel
Instrument Model:	DMSGO+	Transducer Model:	0.250" 5MHz
Instrument S/N:	GOPLS17070020	Transducer S/N:	15A00JGG
Temperature:	20°C	Couplant:	UTX

Table 1: Thickness Gage Horizontal Linearity Data

CALIBRATION BLOCK S/N	CALIBRATION BLOCK THICKNESS (IN)	BACKWALL NUMBER	MEASURED LENGTH (IN)	DEVIATION (IN)	TOLERANCE (IN)	ACCEPTABLE
20-3222	0.040	1st	0.038	0.002	±0.006	Yes
22-1408	0.100	1st	0.100	0.000	±0.006	Yes
22-1408	0.200	1st	0.201	0.001	±0.006	Yes
22-1408	0.300	1st	0.300	0.000	±0.006	Yes
22-1408	0.400	1st	0.400	0.000	±0.006	Yes
22-1408	0.500	1st	0.500	0.000	±0.006	Yes
15-1096	1.000	1st	1.000	0.000	±0.006	Yes
15-1096	2.000	1st	2.000	0.000	±0.006	Yes
15-1096	3.000	1st	3.000	0.000	±0.006	Yes
15-1096	4.000	1st	4.001	0.001	±0.006	Yes

Technician Name: Hyekyong Jun
(CGSB 17600)

Signature: _____

Date: May 14th, 2024

Calibration Due: May 14th, 2025



RAE Engineering and Inspection Ltd
4810 - 93 Street Edmonton, AB, T6E 5M4
ph: 780-469-2401 fx: 780-468-2422

Inspection Date:	21-Nov-24
Report Date:	6-Dec-24
Page:	7 of 7

Ultrasonic Thickness Examination

Client:	Midstream Equipment	Report Number:	24-PR0003757-CJ-UT-01
Facility:	Valhalla	Location/LSD:	14-30-074-08 W6
Equipment Number:	A0639408 (Unit-1223)	Client Representative:	N/A
Equipment Description:	Horizontal Separator	Client Contact:	N/A

CERTIFICATIONS

Method	Level	Expiry Date
UT	1	24-Oct-29
Corrective Lenses Required:		☐ Yes ☒ No
By:	Zong Jun Wang	
Title:	NDE Level 3	
Signature:		
Date:	22-Oct-24	



RAE Engineering and Inspection Ltd.

Certification Record

This is to certify that:

Chaitanya Joshi

The above named employee has satisfactorily met the qualification requirements of the RAE Engineering and Inspection Ltd. written practice that meets the requirements of ASNT recommended practice SNT-TC-1A 2020 edition

Certification No.: RAE-710B-078