

Certificate of Inspection

LIGHTNING ENERGY LTD
605 5 AVENUE SW SUITE 2000
CALGARY, AB
T2P 3H5

PREFERRED RE-INSP. INTERVAL: 2.00 Yr.

YEAR BUILT: 2003
CRN: R2263.2
SERIAL #: 12892

LOCATION: LSD 3-31-54-22 W5M
DESCRIPTION: HORIZONTAL FLARE KNOCKOUT DRUM
COMPANY CODE:
MANUFACTURER: BILTON WELDING & MANUFACTURING LTD

VOLUME: 17.4 M3
HEATING SURFACE:
SURFACE AREA:
Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	690 KPA	100 C	-29 C	SV1	689 KPA	110 M3/MIN	

OWNER INSTRUCTIONS/REMARKS:

PRESSURE RELIEF VALVE TO BE SERVICED BY AN AUTHORIZED SAFETY VALVE SERVICING COMPANY EVERY TWO YEARS.

THE INLET AND/OR OUTLET BLOCK VALVES AROUND THE PRESSURE RELIEF VALVE MUST ALWAYS BE CAR-SEALED OR CHAIN-LOCKED OPEN. THIS PROCEDURE TO BE DOCUMENTED AND CONTROLLED.

Safety Codes Officer: MCDONALD, GLEN

Signature: 

3: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

The owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.