

## Field Inspection Report - Long\_Run 3162220\_06/01/2011\_UT\_External

<b>Vessel Number</b>	3162220	<b>Vessel Name</b>	CHILLER	<b>Province</b>	Alberta
<b>District</b>	NORTHERN - AB	<b>LSD</b>	03-26-074-01W6	<b>Location</b>	PUSKWASKAU
<b>Method</b>	UT	<b>Access</b>	External	<b>Cleaning</b>	
<b>Inspection Date (mm/dd/yyyy)</b>	06/01/2011	<b>Inspection Interval (months)</b>	60	<b>Next Inspection (mm/dd/yyyy)</b>	06/01/2016
<b>CRN</b>	N1345.2	<b>Skid Number</b>	PKG62777	<b>Service</b>	
<b>Internal Access</b>	No	<b>Internal Coating</b>	No	<b>Status</b>	In Service
<b>MAWP (PSI)</b>	250	<b>MAWP (kPa)</b>	1723.7	<b>Outstanding NCRs</b>	0
<b>MAWT (°C)</b>	66.11	<b>MAWT (°F)</b>	151		

### General

Kick off UT report entered only to show next inspection due dates in the database.  
UT survey last performed by Probe in 2011.

### Safety Valves

PSV P99578 Tube side. Set pressure: 1320 PSI / 9101.14 KPa. MAWP: 1320 PSI / 9101.14 KPa. Capacity: 21007 SCFM / 594.85 m3/min.

PSV P99586 Shell side. Set pressure: 250 PSI / 1723.7 KPa. MAWP: 250 PSI / 1723.7 KPa. Capacity: 0 SCFM / 0 m3/min.

### External Condition

### Internal Condition

### Recommendations

UT due again in 2016.

## Field Inspection Report - Long\_Run 3162220\_06/01/2011\_UT\_External

<b>Suitable to be returned to Service</b>	Yes	<b>Suggested Inspection interval (Months)</b>	60
<b>Repairs are still required</b>	No		
Duane Paetkau Cert #000087 <b>Inspector</b>			02/05/2013 <b>Date (mm/dd/yyyy)</b>
		<b>Signature</b>	

### Pictures

-No pictures for this inspection-	
-----------------------------------	--