

## Field Inspection Report - Long\_Run 3162275\_07/17/2012\_VT\_External

<b>Vessel Number</b>	3162275	<b>Vessel Name</b>	COOLER	<b>Province</b>	Alberta
<b>District</b>	NORTHERN - AB	<b>LSD</b>	03-26-074-01W6	<b>Location</b>	PUSKWASKAU
<b>Method</b>	VT	<b>Access</b>	External	<b>Cleaning</b>	Good
<b>Inspection Date (mm/dd/yyyy)</b>	07/17/2012	<b>Inspection Interval (months)</b>	60	<b>Next Inspection (mm/dd/yyyy)</b>	07/17/2017
<b>CRN</b>	N1357.2	<b>Skid Number</b>	PKG62778	<b>Service</b>	
<b>Internal Access</b>	No	<b>Internal Coating</b>	No	<b>Status</b>	In Service
<b>MAWP (PSI)</b>	550	<b>MAWP (kPa)</b>	3792.14	<b>Outstanding NCRs</b>	0
<b>MAWT (°C)</b>	204.44	<b>MAWT (°F)</b>	400		

### General

### Safety Valves

PSV P99589 Tube side. Set pressure: 550 PSI / 3792.14 KPa. MAWP: 550 PSI / 3792.14 KPa. Capacity: 0 SCFM / 0 m3/min.

### External Condition

All visible header box surfaces and nozzles appear in good condition. Name plate is intact and legible. Vessel supports, foundation, electrical grounding and external coating appear good. Associated piping, supports and components appear in good condition and alignment with no signs of leaks or defects present at the time of inspection. No evidence of short studding or nut rounding at time of inspection.

Verify PSV protection and PSV's are properly installed with any block valves locked/sealed open. Verify vessel has Alberta CRN and A# stamping, PSV has correct code stamp, set pressure and MWS tagging, and was last serviced within the required interval guidelines.

Assign inspection interval.

### Internal Condition

### Recommendations



101, 56 Cuendet Industrial Way, Sylvan Lake, AB T4S 0B6

---

## Field Inspection Report - Long\_Run 3162275\_07/17/2012\_VT\_External

---

<b>Suitable to be returned to Service</b>	Yes	<b>Suggested Inspection interval (Months)</b>	60
<b>Repairs are still required</b>	No		
Doug Gohmann, MWS <b>Inspector</b>	<b>Signature</b>		08/08/2012 <b>Date (mm/dd/yyyy)</b>

---

### Pictures

---

-No pictures for this inspection-	
-----------------------------------	--