

Field Inspection Report - Long_Run 3162196_06/01/2011_UT_External

Vessel Number	3162196	Vessel Name	LOW TEMP SEPARATOR	Province	Alberta
District	NORTHERN - AB	LSD	03-26-074-01W6	Location	PUSKWASKAU
Method	UT	Access	External	Cleaning	
Inspection Date (mm/dd/yyyy)	06/01/2011	Inspection Interval (months)	60	Next Inspection (mm/dd/yyyy)	06/01/2016
CRN	N1348.2	Skid Number	PKG62777	Service	SWEET
Internal Access	No	Internal Coating	No	Status	In Service
MAWP (PSI)	1320	MAWP (kPa)	9101.14	Outstanding NCRs	0
MAWT (°C)	66.11	MAWT (°F)	151		

General

Kick off UT report entered only to show next inspection due dates in the database.
UT survey last performed by Probe in 2011.

Safety Valves

PSV P99578 Shell side. Set pressure: 1320 PSI / 9101.14 KPa. MAWP: 1320 PSI / 9101.14 KPa. Capacity: 21007 SCFM / 594.85 m3/min.

External Condition

Internal Condition

Recommendations

UT due again in 2016.

Suitable to be returned to Service	Yes	Suggested Inspection interval (Months)	60



101, 56 Cuendet Industrial Way, Sylvan Lake, AB T4S 0B6

Field Inspection Report - Long_Run 3162196_06/01/2011_UT_External

Repairs are still required	No		
Duane Paetkau Cert #000087 Inspector	Signature		02/05/2013 Date (mm/dd/yyyy)

Pictures

-No pictures for this inspection-