

Field Inspection Report - Long_Run 518943_03/09/2017_UT_External

Vessel Number	518943	Vessel Name	INLET SEPARATOR	Province	Alberta
District	EASTERN - AB	LSD	05-10-033-26W4	Location	WIMBORNE
Method	UT	Access	External	Cleaning	Good
Inspection Date (mm/dd/yyyy)	03/09/2017	Inspection Interval (months)	72	Next Inspection (mm/dd/yyyy)	03/09/2023
CRN	R9068.213	Skid Number	SKD1040	Service	Sweet
Internal Access	No	Internal Coating	No	Status	In Service
MAWP (PSI)	1480	MAWP (kPa)	10204.3	Outstanding NCRs	0
MAWT (°C)	37.78	MAWT (°F)	100		

General

2017 Ultrasonic Corrosion Survey.

Safety Valves

PSV CR0151 Shell side. Set pressure: 1480 PSI / 10204.3 KPa. MAWP: 1480 PSI / 10204.304 KPa. Capacity: 14442 SCFM / 408.95 m³/min.

External Condition

Refer to the latest VT External inspection report as part of this thorough inspection.

Internal Condition

The vessel was UT inspected for wall loss. Mountain West Services Ultrasonic Corrosion Survey Project #C31505, as reported on Drawing #9, noted all vessel thickness readings to be above ASME Section VIII, Div. 1 code requirements at time of inspection. The calculated retirement date is 2037 with a program maximum of 20 years. The associated piping was also inspected with no notable wall loss recorded. Next inspection is 6 years or 1/2 remaining life, whichever is less.

Recommendations

Recommend 6 year interval for next UT inspection. Ultrasonic Corrosion Survey due again in 2023.

Field Inspection Report - Long_Run 518943_03/09/2017_UT_External

Suitable to be returned to Service	Yes	Suggested Inspection interval (Months)	72
Repairs are still required	No		
Duane Paetkau ABSA ISBPV:000087, API 570:24422, NB Cert. 222 Inspector			11/14/2017 Date (mm/dd/yyyy)
	Signature		

Pictures

-No pictures for this inspection-	
-----------------------------------	--