



101, 56 Cuendet Industrial Way, Sylvan Lake, AB T4S 0B6

Field Inspection Report - Long_Run

568797_12/30/2011_VT_Internal

Vessel Number	568797	Vessel Name	BULLET	Province	Alberta
District	NORTHERN - AB	LSD	07-04-071-18W5	Location	SNIPE LAKE
Method	VT	Access	Internal	Cleaning	
Inspection Date (mm/dd/yyyy)	12/30/2011	Inspection Interval (months)	60	Next Inspection (mm/dd/yyyy)	12/30/2016
CRN	A223.4.5.3.2.8.0	Skid Number	N/A	Service	SWEET
Internal Access	Yes	Internal Coating	No	Status	In Service
MAWP (PSI)	250	MAWP (kPa)	1723.7	Outstanding NCRs	0
MAWT (°C)	53.33	MAWT (°F)	128		

General

Kick off internal inspection report entered for reference only to show next internal inspection due dates in the database.

ABSA ESR indicates the vessel is due for next internal inspection 12/30/16.

Safety Valves

PSV P110884 Shell side. Set pressure: 250 PSI / 1723.7 KPa. MAWP: 250 PSI / 1723.7 KPa. Capacity: 6515 SCFM / 184.48 m3/min.

External Condition

Internal Condition

Recommendations

ABSA ESR indicates the vessel is due for next internal inspection 12/30/16.

Suitable to be returned to Service	Yes	Suggested Inspection interval (Months)	60
------------------------------------	-----	--	----



101, 56 Cuendet Industrial Way, Sylvan Lake, AB T4S 0B6

Field Inspection Report - Long_Run

568797_12/30/2011_VT_Internal

Repairs are still required	No	
Duane Paetkau Cert 000087 Inspector	Signature	11/14/2014 Date (mm/dd/yyyy)

Pictures

-No pictures for this inspection-
