

Client: Long Run

PKG #: PKG74808

Field: Redwater

Equipment #: 640530

LSD: 02/12/058/23W4

PSV #: P133179

BC: _____



Identified Concern:

PSV tags are hanging from the nameplate for installation at next opportunity. PSV serial number and set pressure currently unknown.

Proposed Action:

Attach PSV tags at next opportunity and obtain nameplate information. Forward to Mountain West.

Inspector: Doug Gohmann

Date: 04-11-2017