



1/4" STRIPPING GAS TO H-800 EXTERNAL STRIPPING GAS COLUMN SEE DWG B7113-041 SHT 1 OF 2

1" FUEL GAS FROM H-800 SEE DWG B7113-041 SHT 1 OF 2

**NOTES**

- 1) VENTED O/S BUILDING FOR DIAPHRAGM BREAKEGE AND INTERNAL RELIEF WITH AT LEAST EQUAL NOMINAL PIPE SIZE OF THE VENT OUTLET TO PREVENT IMPEDANCE UPON THE REGULATORS INTERNAL RELIEF CAPABILITY.
- 2) SOV-100A & ZSC-100 IS INTEGRAL TO ESDV-100A.

CUSTOMER REFERENCE	T.B.A	CUSTOMER	TRIDENT EXPLORATION LTD.	JOB NO.	B7113-04
PROJECT	DEHYDRATION PACKAGE / CBM COMPRESSOR STATION	DESIGN	KB	DATE	04/09/22
TITLE	CSA B149.3-00 BURNER STANDARD P&ID	SCALE	N.T.S.	DRAWING NUMBER	B7113-041 SHT. 2 OF 2
ISSUED FOR CONSTRUCTION	REVISION	BY	CHKD.	DATE	
0		KB		04/09/22	

