

# Certificate of Inspection

**FORT ENERGY CORPORATION**  
444 7 AVENUE SW SUITE 1000  
CALGARY, AB  
T2P 0X8

PREFERRED RE-INSP. INTERVAL: Yr.

YEAR BUILT: 2005

CRN: P-4080.2

SERIAL #: 054468-210

VOLUME: 0.032 M3

HEATING SURFACE:

SURFACE AREA:

COMPANY CODE: AC-610

DESCRIPTION: LPG PRODUCT COOLER

LOCATION: LSD 15-10-62-6 W5M (FORT ASSINIBOINE)

MANUFACTURER: PROPAK SYSTEMS LTD

**Safety Valves**

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	3792 KPA	204 C	-29 C	SV1			TO BE INSTALLED

**OWNER INSTRUCTIONS/REMARKS:**

NOT SUBJECT TO ANNUAL FEES AS PER INFORMATION BULLETIN IB03-003 (g)  
AIR COOLED OR PLATE TYPE HEAT EXCHANGERS;

Owner to verify integrity of vessel by periodic inspection program.

Verify that vessel/boiler is protected by an acceptable ASME Code pressure relief device, of adequate capacity, set at no more than maximum pressure authorized and installed in accordance with the Safety Codes Act & Regulations.

Vessel/Boiler to be installed in accordance with the Safety Codes Act and Regulations.

**Safety Codes Officer:** IONEL, BLAIR

**Signature:** 

**NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:**

The owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.