

Certificate of Inspection Permit

FORT ENERGY CORPORATION
444 7 AVENUE SW SUITE 1000
CALGARY, AB
T2P 0X8

PREFERRED RE-INSP. INTERVAL: 4.00 Yr.

YEAR BUILT: 2005

CRN: R7061.2

SERIAL #: 054468-101

VOLUME: 1.73 M3

HEATING SURFACE: 159.41 M2

SURFACE AREA:

COMPANY CODE: TEC-2187

DESCRIPTION: GAS/GAS EXCHANGER

LOCATION: LSD 15-10-62-6 W5M (CORBETT GAS PLT)

MANUFACTURER: PROPAK SYSTEMS LTD

Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
SHELL	8963 KPA	66 C	-29 C	SV1	8963 KPA	604 M3/MIN	ON PIPING
TUBE A	8963 KPA	66 C	-29 C	SV1	8963 KPA	604 M3/MIN	ON PIPING

OWNER INSTRUCTIONS/REMARKS:

'PRV'S TO BE PLACED ON A REGULAR SERVICING SCHEDULE'

Safety Codes Officer: EBERT, PHIL

Signature: 

NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

owner or person in charge shall report all accidents involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.