

# Certificate of Inspection Permit

**FORT ENERGY CORPORATION**  
444 7 AVENUE SW SUITE 1000  
CALGARY, AB  
T2P 0X8

PREFERRED RE-INSP. INTERVAL: 4.00 Yr.

YEAR BUILT: 2005

CRN: P3175.2

SERIAL #: 054468-106

VOLUME: 2.63 M3

HEATING SURFACE:

SURFACE AREA:

COMPANY CODE: TEC-2188

DESCRIPTION: LOW TEMPERATURE SEPARATOR

LOCATION: LSD 15-10-62-6 W5M (CORBETT GAS PLT)

MANUFACTURER: PROPAK SYSTEMS LTD

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	Safety Valves			
				VALVE ID	SETTING	CAPACITY	LOCATION
COIL	8963 KPA	66 C		SV1	8894 KPA	604 M3/MIN	ON PIPING
VESSEL	8963 KPA	66 C	-29 C	SV1	8894 KPA	604 M3/MIN	ON PIPING

**OWNER INSTRUCTIONS/REMARKS:**

'PRV TO BE PLACED ON A REGULAR SERVICING SCHEDULE'

**Safety Codes Officer:** EBERT, PHIL

**Signature:** \_\_\_\_\_

**NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:**

The owner or person in charge shall report all accidents involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.