



CERTIFIED  
 BRIAN HINTON  
 2801



1. COOLER STRUCTURE MUST BE ADEQUATELY SUPPORTED AT ALL FOUR CORNERS AS SHOWN TO INSURE STRUCTURAL AND MECHANICAL INTEGRITY. 7/8\"/>

WC-215-3

ITEM	SERVICE	NOZZLES		REFERENCE DIMENSIONS			BUNDLE WEIGHT	V&D	COUPLINGS	PRESS	SHUTTER-OPERATOR	BUG SCRIN	CODE	DESIGN PRESS.	TOLERANCES: (ALL DIMENSIONS IN INCHES) MECHANICAL EQUIPMENT ±1/2" PER 10'-0" NOZZLE ±1/2"	AMERCOOL TYLER, TEXAS	
		INLET	OUTLET	A INLET	B OUTLET	C										MODEL:	QUANTITY:
4 AC	ANTIFREEZ COOLER NATURALGAS CLR-1 NATURALGAS CLR-2 NATURALGAS CLR-3	(1)3.00- SCH XS PIPE (1)3.00-300 # RF SCH 16 (1)2.00-600 # RF SCH 16 (1)2.00-600 # RF SCH 16	(1)3.00- SOCH XS PIPE (1)3.00-300 # RF SCH 16 (1)2.00-600 # RF SCH 16 (1)2.00-600 # RF SCH 16	37.6250 41.0000 41.0000 41.0000	37.6250 41.0000 41.0000 64.8750	98.0625 98.2500 97.6875 97.6875	706 479 608 537	1" & 1 1/2" 6000#			VCI MANUAL VCI MANUAL VCI MANUAL VCI MANUAL	YES YES YES YES	NONE CRN CRN CRN	14 655 1315 1315	STRUCTURAL - Hand Tool Clean WITH 1 COAT Service #6004 FRAME - Hand Tool Clean WITH 1 COAT Service #6004 HEADER - Hand Tool Clean WITH 1 COAT Service #6004 CUSTOMER: UNIVERSAL COMPRESSION CALGARY LOCATION: unknown REFERENCE: EH10435	60vc	1
DRY WEIGHT: 4960.		FAN INFORMATION:		27 5000 60 IN. DIAMETER,		4 BLADE,		42261 ACFM,		7.648 DEG.		CERTIFIED BY		DATE		REV	JOB: SB-01C455

AMERCOOL  
 TYLER, TEXAS

EQUIPMENT OUTLINE  
 MODEL: 60vc; QUANTITY: 1  
 DRAWN: HP DATE: 03/08/20  
 CHECKED: SCALE: NONE  
 REV JOB: SB-01C455