Explanation	Input Values	Unit of Measure/Format
SAP Equipment # (if known)		
Equipment Type	3101_Generator Elec	
Equipment Description	Thermo Electric Generator	
Maintenance Plant	CAY_Hamburg	choose from drop down
Area Level 3	CHIN_Chinchaga	choose from drop down
Plant/Battery/Well	unknown	choose from drop down
Bottom Hole Location	0	
Surface Location	01-07-096-12W6	
Process	0	choose from drop down
Cost Centre	GP ARS	
SAP Superior Equipment # (if known)		
Equipment Status	SURP-Surplus	choose from drop down
Manufacturer	Global Thermoelectric	
Model	8550N-24-SI-SO	
A#	/	
Serial Number	8500-1711-NOD	
Skid ID#	/	
Tech ID/P&ID	/	
Controllable Asset Indicator	Controllable Asset	choose from drop down
AMPERAGE	/	
OWNER	Conoco	
Phase	/	
RATED OUTPUT	582 W@19C	
Service Med, liq/gas/steam/air	GAS	choose from drop down
VOLTAGE OUTPUT	27.1	

Has the unit been isolated from the process?
Method of Isolation: Double Block and YES choose from drop down Bleed?
Method of Isolation: Blinded?
Has the unit been disconnected from the choose from drop down choose from drop down process? le: Spool Piece Removed YES choose from drop down How was the unit preserved? Compression as per MOC 24014 Technical Bulletin 2009-05 Compressor Preservation choose from drop down How was the unit preserved? Has A&OI Specialist provided preservation support for vessels and other equipment How was the unit preserved? choose from drop down Additional comments/Free Text

Additional Comments			
Fuel Pressure 55 Kpa			

Data Complete Yes/No Yes

Home Pkg Page