



**MERCER VALVE**  
**CANADA LTD.**

#1, 12181 44TH STREET S.E. CALGARY ALBERTA PH:403-215-6961

**AUTHORIZED BLUE TAG ASSEMBLER**  
**CALIBRATION REPORT**

12517  
66174350

<b>DATE</b>	July 07, 2010
<b>CUSTOMER:</b>	Enerflex Ltd.
<b>ADDRESS</b>	10121 Barlow Trail NE Calgary, AB T3J 3C6
<b>SERIAL NUMBER</b>	592026
<b>PRODUCT NUMBER</b>	91-34H12T82U1
<b>INLET AND OUTLET</b>	1.5" 300 RF X 2" 150 RF "H" Orifice
<b>SERIES SAFETY RELIEF VALVE</b>	9100
<b>SET PRESSURE</b>	300 PSI
<b>LEAK TEST</b>	0 BPM @ 285.0 PSI
<b>CAPACITY</b>	4,471 SCFM AIR
<b>BACK PRESSURE</b>	
<b>TEMPERATURE</b>	70F
<b>COLD SET</b>	
<b>TRIM</b>	STD
<b>CANADIAN REGISTRATION #</b>	0G8841.5C
<b>QUOTE ORDER NUMBER</b>	2094667 REV.1
<b>WORK ORDER NUMBER</b>	212335
<b>CUSTOMER P.O. NUMBER</b>	MP527114
<b>LOCATION:</b>	
<b>CUSTOMER ID#:</b>	
<b>CUSTOMER REFERENCE:</b>	

THE VALVES PURCHASED ON THE ABOVE WORK ORDER NUMBER WERE BUILT PER SECTION VIII, DIVISION 1 OF THE ASME BOILER AND PRESSURE VESSEL CODE.

  
\_\_\_\_\_  
CERTIFIED INDIVIDUAL  
QUALITY CONTROL