



#1, 12181 44TH STREET S.E. CALGARY ALBERTA PH:403-215-6961

AUTHORIZED BLUE TAG ASSEMBLER
CALIBRATION REPORT

DATE	6/11/2012
CUSTOMER:	Enerflex Ltd
ADDRESS	10121 Barlow Trail NE Calgary, AB T3J 3C6
SERIAL NUMBER	810532 ✓
PRODUCT NUMBER	91-34H12T82U1 ✓
INLET AND OUTLET	1.5" 300 RF X 2" 150 RF "H" Orifice
SERIES SAFETY RELIEF VALVE	9100
SET PRESSURE	300 PSI ✓
LEAK TEST	0 BPM @ 285.0 PSI
CAPACITY	4,471 SCFM AIR
BACK PRESSURE	
TEMPERATURE	70 F
COLD SET	
TRIM	STD
CANADIAN REGISTRATION #	0G8841.5C
QUOTE ORDER NUMBER	2101655
WORK ORDER NUMBER	217434
CUSTOMER P.O. NUMBER	MP552801
LOCATION:	PSV-0300
CUSTOMER ID#:	
CUSTOMER REFERENCE:	

THE VALVES PURCHASED ON THE ABOVE WORK ORDER NUMBER WERE BUILT PER SECTION VIII, DIVISION 1 OF THE ASME BOILER AND PRESSURE VESSEL CODE.



CERTIFIED INDIVIDUAL
QUALITY CONTROL