




| Without MFE |         |  |
|-------------|---------|--|
| .170 - up   | 5 yr    |  |
| .160 - .169 | 4 yr    |  |
| .150 - .159 | 3 yr    |  |
| .140 - .149 | 2 yr    |  |
| .130 - .139 | 1 yr    |  |
| under .130  | Patch   |  |
|             | Replace |  |
|             | Floor   |  |
|             | Shell   |  |



| With MFE    |         |  |
|-------------|---------|--|
| .140 - .150 | 5 yr    |  |
| .130 - .139 | 4 yr    |  |
| .120 - .129 | 3 yr    |  |
| .110 - .119 | 2 yr    |  |
| .100 - .109 | 1 yr    |  |
| under .100  | Patch   |  |
|             | Replace |  |
|             | Floor   |  |
|             | Shell   |  |



Comments:

Installation Inspection - External

---



---



---



---



---



---



---

Inspected by: **Ryan Novick** Digitally signed by Ryan Novick  
Date: 2020.08.31 11:16:38 -06'00'

Date:

Husky Inspector: **Ryan Novick**

Date: **31/08/2020**