

66172953
 A600042

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 (Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)
 As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by Enerflex Ltd., 10121 Barlow Trail NE, Calgary, Alberta, T3J 3C6
(Name and address of manufacturer)
2. Manufactured for Husky Oil Operations Ltd., Box 4490, Stn. D Calgary Alberta, T2P 3G7
(Name and address of purchaser)
3. Location of installation McMullen TCP, LSD: 03-35-078-25 W4
(Name and address)
4. Type Horizontal 31834226 V2132.213 31833-V406 Rev.2 --- 2010
(Horizontal or vertical, tank) (Manufacturer's serial Number) (CRN) (Drawing Number) (National Board number) (Year built)
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 2007
Year
- to 2009
[Addenda (date)] (Code Case numbers) [Special service per UG-120(d)]
6. Shell: SA-106B 0.687" 0.0625" 0' - 11.376" 3' - 0" S/S
(Material spec. number, grade) (Nominal thickness) (Corr. allow.) (Inner diameter) (Length overall)
7. Seams: Seamless Pipe --- 1.0 --- --- Type 1 Spot 0.70 1
(Long. welded, dbl., sngl., lap, butt) (R.T. (spot or full)) (Eff., %) (H.T. temp.) (Time, hr) (Girth, welded, dbl., sngl., lap, butt) (R.T. (spot or full)) (Eff., %) No. of courses
8. Heads: (a) Material SA-516-70N (b) Material SA-516-70N
(Spec. no., grade) (Spec. no., grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	N2 End	0.5625"	0.0625"	---	---	SE 2:1	---	---	---	Concave
(b)	N3 End	0.5625"	0.0625"	---	---	SE 2:1	---	---	---	Concave

If removable, bolts used (describe other fastenings) ---
(Material spec. number, grade, size, number)

9. MAWP 1270 PSIG --- at max. temp. 350°F
(Internal) (External) (Internal) (External)
- Min. design metal temp. -20°F at 1270 PSIG . Hydro., pneu., or comb. test pressure 1651 PSIG
 Proof Test ---

10. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain)	Number	Diameter or Size	Type	Material	Nominal Thickness	Reinforcement Material	How Attached	Location
N1 - Inlet/Insp	1	4"NPS	CL600 RFWN	SA-105N/SA-106B	0.531"	---	UW16.1(c)	Shell
N2 - Outlet	1	4"NPS	CL600 RFWN	SA-105N/SA-106B	0.531"	---	UW16.1(c)	Head
N3 - Inspection	1	1.5"NPS	CL600 RFLWN	SA-105N	0.625"	---	UW16.1(c)	Head
N4 - Drain	1	0.75"	CL600 Studolet	SA-105N	1.935"	---	UW16.1(c)	Shell

11. Supports: Skirt No Lugs --- Legs --- Other --- Attached Interconnected Piping
(Yes or no) (Number) (Number) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:
- (Name of part, item number, Manufacturer's name and identifying stamp)
- Vessel Type: Stage # 2 Discharge Bottle Construction Drawing: 31834-V406 Rev.2
- Impact testing: exempt, per UG-20(f)(1-5), UCS-66(c) Volume: 3.1 Cu. Ft.
- Relief Valve installed on piping in accordance with UG-125

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. "U" Certificate of Authorization Number 33,658 expires November 26, 2011.

Date 27 Sept 2010 Co. name Enerflex Ltd. Signed [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by Enerflex Ltd. at Calgary, Alberta, Canada

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Alberta and employed by ABSA

have inspected the component described in this Manufacturer's Data Report on OCT 08 2010 and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date OCT 08 2010 Signed [Signature] Commissions ALTA # 58
(Authorized Inspector) (National Board (incl. endorsements), State, Province and Number)