

EO# 66048297

Certificate of Inspection

C.T.

RENAISSANCE ENERGY LTD
3000, 425 FIRST ST. SW

CALGARY, AB
T2P 3L8

PREFERRED RE-INSP. INTERVAL: Yr.

YEAR BUILT: 1998

CRN: H2451.2

SERIAL #: 5349

LOCATION: LSD 10-36-54-24 W5M, GALLOWAY

DESCRIPTION: VERTICAL THREE PHASE SEPARATOR

COMPANY CODE:

MANUFACTURER: R J V GAS FIELD SERVICE LTD.

VOLUME: 0.26 M3

HEATING SURFACE:

SURFACE AREA:

Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	9930 KPA	38 C	-1 C	SV1	9928 KPA	109 M3/MIN	

OWNER INSTRUCTIONS/REMARKS:

NOT SUBJECT TO ANNUAL FEES AS PER REGULATIONS PART 4 SECTION 28 (i)

VESSELS HAVING A CAPACITY OF 0.5 M3 OR LESS THAT ARE LOCATED IN WELL HEAD PLANTS OR BATTERIES;

PRESSURE RELIEF VALVE TO BE SERVICED BY AN AUTHORIZED SAFETY VALVE SERVICING COMPANY EVERY FOUR YEARS.

VERIFY VESSEL THICKNESS BY ULTRASONIC EXAMINATION, ANALYZE AND FORWARD A COPY TO THE ABSA SAFETY CODES OFFICER FOR REVIEW.

Safety Codes Officer: MCDONALD, GLEN

Signature:

Glen McDonald

NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

The owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.