

EQ # 66069760

Certificate of Inspection

HUSKY OIL OPERATIONS LTD.
CALGARY/WESTERN CANADA UPSTREAM
BOX 6525, STN D
ATTN: GREG MURRAY
CALGARY, AB
T2P 3G7

PREFERRED RE-INSP. INTERVAL: Yr.

FH-FW

100/03-21-049-19W5/00

YEAR BUILT: 2002
CRN: K9276.2
SERIAL #: 005740-200

LOCATION: ~~LSD 12-27-49-19 W5M~~

DESCRIPTION: VERTICAL SEPARATOR

VOLUME: 0.212 M3

COMPANY CODE:

HEATING SURFACE:

MANUFACTURER: NUSCO SUPPLY & MANUFACTURING INC

SURFACE AREA:

Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	9928 KPA	38 C	-29 C	SV1			TO BE INSTALLED



OWNER INSTRUCTIONS/REMARKS:


NOT SUBJECT TO ANNUAL FEES AS PER REGULATIONS PART 4 SECTION 28 (i)
VESSELS HAVING A CAPACITY OF 0.5 M3 OR LESS THAT ARE LOCATED IN WELL HEAD PLANTS OR BATTERIES;

OWNER TO VERIFY INTEGRITY OF VESSEL BY PERIODIC INSPECTION PROGRAM.

VERIFY THAT VESSEL/BOILER IS PROTECTED BY AN ACCEPTABLE ASME CODE PRESSURE RELIEF VALVE, OF ADEQUATE CAPACITY, SET AT NO MORE THAN MAXIMUM PRESSURE AUTHORIZED AND INSTALLED IN ACCORDANCE WITH THE SAFETY CODES ACT & REGULATIONS.

VESSEL/BOILER TO BE INSTALLED IN ACCORDANCE WITH THE SAFETY CODES ACT AND REGULATIONS.

Safety Codes Officer: DENYS, METRO

Signature: 

REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

The owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.