

66177805

Technical Safety Authority of Saskatchewan

Boiler and Pressure Vessel Safety Unit #330 - 1855 Victoria Avenue REGINA SK S4P 3T2

Report Number: 208792
Previous Inspector:
Licence Number: 21014 - (Acceptance Pending)
Serial - Unit Number: 130495-111003
Plant: 0 (pieces)

Equipment:

Bld/Offfield: Hot Water Process Pilot
Address: 10-04-50-24W3M
City/Town: Lloydminster
LLD: 10-04-50-24W3M
Community: Lloydminster
District: 5

Owned By:

Huaky Energy (403) 750 - 4930 (Phone)
c/o Ray Trachuk (403) 750 - 5004 (Fax)
4429- 44th Street Hwy 16 East
Lloydminster, Saskatchewan S9V 0Z8
Canada

Item Type: 04 - Gas / Oil Separator (Provincial)

Inspector Description:

Owner Description: V 908 WATER SEPARATOR

CRN: V5361 23

Mobility: Stationary

NB:

Shell WP: 6205

Manufacturer: Bromley Mechanical Services Inc.

Tube WP:

Manufactured Date: 2011-01-01 2011-09-06

Diameter (m): 0.61

Last Internal Insp.:

Length (m): 1.52

Inspection Method: Acceptance

Next Inspection Date: 2017-03-13 (yyyy-mm-dd)

Install Permit No.: 14772

Assigned to Inspector: 0445 - Larry Holuk

Previous Conditions:

Empty box for previous conditions.

Inspection Conditions: A - Acceptable R - Repairs or Corrective Action Required N - Not Applicable
C - Comments or Recommendations I - Incomplete/Object Not Exposed/Not Operating

- 1. Safety Valve: A
2. Level Gauge: A
3. Pressure / Temp Gauge: A
4. Tubesheet: N
5. Tubes: N
6. Insulation: A
7. Inspection Openings: A
8. Associated Piping: A
9. Shell: I
10. Heads: I
11. Data Report: .
12. Sack Design Registration:
13. Nameplate:
14. Other:

Comments/Repairs or Corrective Action Required:

Empty lines for comments/repairs.

Unable to do inspection on: (yyyy-mm-dd)

Reason inspection was not done:

Items Classified with an "R" must be repaired or corrected by: (yyyy-mm-dd)

and the Boiler and Pressure Vessel Safety Unit must be notified in writing by fax or mail. Please include the Licence No. and the Serial Number on all correspondence.

(306) 787-1443 Phone/1-866-530-8509 (Phone - Toll free in SK)
(306) 787-9273 Fax/1-866-760-9255 (Fax - Toll free in SK)

Holuk, Larry
952, 122 3rd Avenue North
SASKATOON Saskatchewan S7K 2H6
(306) 933 - 5073 (Work)
(306) 220 - 3195 (Cell)
Larry.Holuk@tsask.ca (Email)

This report was discussed with the owner or his representative.

A copy of this report was mailed to the owner/representative by regular mail on: (yyyy-mm-dd)

2017-03-13
Inspection Date (yyyy-mm-dd)

Signature of Inspector

0445
Inspector Number

Signature of Person receiving report

CLIENT