

Certificate of Inspection Permit

#66196750

HUSKY OIL OPERATIONS LTD
BOX 6525 STN D
CALGARY/WESTERN CDA UPSTREAM
ATTN DALE MARTIN
CALGARY, AB
T2P 3G7

Max. Inspection Interval: .00 Yr.
Year Built: 2013
CRN: V9651.2
Serial #: NWP-08526-001-A
Volume: 0.520 M3
Heating Surface:
Surface Area:

COMPANY CODE:

DESCRIPTION: INDIRECT FIRED HEATER COILS
LOCATION: SPARE, CALGARY
MANUFACTURER: NWP INDUSTRIES INC

Pressure Relief Valves

PART	MAX. ALLOWABLE PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	10204 KPA	93 C	-29 C	SV1			TO BE INSTALLED

Terms and Conditions:

NOT SUBJECT TO ANNUAL FEES AS PER INFORMATION BULLETIN IB06-001 (h)
DIRECT OR INDIRECT FIRED OIL AND GAS PROCESS HEATERS OF THE COIL TYPE;

Owner must establish and maintain an integrity assessment program for this vessel/boiler. Refer to ABSA publication AB-506 for integrity assessment program requirements.

Owner must ensure this vessel/boiler has overpressure protection that is a relief valve that meets the requirements of the ASME Code, or other means accepted by the Administrator expressly for this item.

Owner must ensure this vessel/boiler is designed, constructed, installed, operated, maintained and decommissioned in accordance with the Safety Codes Act and Regulations.

Permit Issued by: TWOREK, JOE

Signature: 

NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

An owner or vendor must notify the Administrator in writing when the pressure equipment identified on this certificate is sold or otherwise disposed of.

The owner or person in charge shall report all accidents involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.